

Fire Protection Engineering Student Class Notes

By

David A. Lucht

Illinois Institute of Technology
Chicago, Illinois

1961 – 1965

Volume 2 of 5

Volume 2

FPE 309 Structural Fire Protection (Continued)

FPE 420 Fire Extinguishing & Detection Systems Fall 1964 Prof. Labes

FPE 303 FPE Laboratory Fall 1963 @ UL, Mr. Jensen

FPE 304 FPE Laboratory Spring 1964 Prof. Labes

VOLUME II

2. FPE 309 (CONTINUED)

3. FPE 420 FIRE EXT. & DET. SYS.

7TH Sem A

4. FPE 303 FPE LAB. (IIT) VL

5TH Sem A

5. FPE 304 FPE LAB (IIT)

6TH Sem. A

Condensation of

Post War Building Studies No. 20
Fire Grading of Buildings, Part I
General Principles and Structural Precautions
Joint British Fire Research Committee

SCOPE OF REPORT

The term "fire grading," as applied to buildings, may be taken to mean the grading of fire precautions in buildings, i.e. the investigation and assigning of suitable fire precautions of any kind to obtain an adequate standard of safety, according to the fire hazard of the building under consideration.

The objects of fire precautions are to safeguard life and property. They are achieved by (a) preventing or reducing the number of outbreaks of fire; (b) limiting the development and spread of a fire in event of an outbreak, and (c) providing for safe exit of occupants.

Although the importance of each of these aspects cannot be overemphasized, it is the purpose of this report to restrict itself to the second stage, i.e. limiting the development and spread of a fire in event of an outbreak.

Any rational system of fire grading should provide a combination of active and passive defence in proper balance to meet the fire hazard in each case. Undue reliance on structural means might be uneconomic as adding unduly to building costs, especially if efficient means of extinguishing the fire can be depended upon. The same emphasis need not be laid on active defence if buildings are so planned internally and constructed as to reduce to a minimum the risk of the occurrence and spread of fire. The broad question is therefore one of striking the right balance between passive and active defence, and of adjusting the total precautions to the hazard so that the most rational and economic combination can be achieved.

Precautions against fire and the fire hazard can be regarded as standing in much the same relation to each other as the strength of a structure and the loads it has to carry. A structural member is designed according to the load it has to carry plus a certain factor of safety. Similarly precautions against fire should be designed according to the fire hazard arising from the contents of the building and its structural character. Whilst the structural engineer is able to estimate with reasonable accuracy the physical loads he has to take into account, there is no means, other than in general terms, of expressing the fire hazard of a building. Recent work has enabled an approximate quantitative measurement to be made of the probable severity of fires in buildings, but this is but one factor of the many which go to make up the total hazard.

A rational scheme of fire grading should be so designed that the protection against the fire hazard would be by that combination of passive and active defence which is appropriate to the hazard involved, having due regard to practicability.

GRADING OF OCCUPANCIES ACCORDING TO
DAMAGE HAZARD

So far as the occupancy is concerned the damage hazard will depend largely on the amounts, natures, and distribution of the combustibile materials, and it is therefore necessary to consider the grading in respect of each of these items.

Thus in a warehouse containing large quantities of combustibile material the damage to the structure and the loss of contents would be much greater than in the case of an office block because of the greater quantity of combustibile material in the former. The fire would be hotter and of longer duration.

The total weight of material is, however, not a sufficient criterion because in this respect the important factor is the total amount of heat that could be liberated. It is therefore necessary, because of the variation in the amount which can be liberated by the combustion of equal weights of different combustible materials, to use as a basis the total heat that can be liberated expressed in British Thermal Units per square foot of floor area.

FIRE LOAD AS A MEANS OF MEASURING DAMAGE
HAZARD

By analogy with structural loads we have adopted the term "fire load" to describe the number of British Thermal Units which could be liberated per sq. ft. of floor area of a compartment by the combustion of the contents of the building and any combustible parts of the building itself. The fire load of a building has been used as the basis of our grading of occupancies. It may be determined simply by multiplying the weight of all combustible materials by their calorific values and dividing by the floor area under consideration. Thus, if a building or any part of a building contains 4000 lb. of combustible material of calorific value 8000 B.Th.U's./lb. over an area of 1000 sq. ft., the fire load would be:

$$\frac{4000 \times 8000}{1000} = 32,000 \text{ B.Th.U's./sq. ft.}$$

As the conception of fire load is new to this country, comprehensive data on the fire loads of various occupancies are not available, but investigations in this country and abroad provide a basis for a tentative grading of a number of common occupancies according to their fire load.

From data obtained from a number of sources relating to floor loads and combustible contents in buildings (including unpublished work of the Building Research Station) it appears that, in general, the fire load of residential buildings, hotels, hospitals, schools, offices, and similar occupancies, does not exceed 100,000 B.Th.U's./sq. ft.; the fire loads of shops and factories using combustible materials are usually greater than 100,000 B.Th.U's./sq. ft., whilst those of warehouses may range up to 1,000,000 B.Th.U's./sq. ft. or more.

These data suggest that a fire load of 100,000 B.Th.U's./sq. ft. would be a convenient limit for distinguishing between buildings of the first group and other occupancies such as factories, and accordingly we propose to describe these as occupancies of low fire loads. The distinction between shops and factories and storage buildings is not well defined; it has been necessary to use the relation which has been brought out by recent work in America and this country between the fire loads of occupancies and the grade of fire resistance of elements of structure required to resist fires due to those fire loads. The relation is considered more fully in a later section of the report and for the present it must suffice to note that a fire in a building having a fire load not exceeding 100,000 B.Th.U's./sq. ft. is approximately equivalent to 1 hour exposure to the heating in the standard test, a fire load between 100,000 and 200,000 B.Th.U's./sq. ft. is similarly equivalent to 2 hours of the standard test, etc. It is clear that a grading of occupancies closely related to the grades of structural fire resistance would be markedly advantageous, and we therefore propose the following grading of occupancies according to fire load:

- (1) Occupancies of Low Fire Load are those in which the fire load does not exceed 100,000 B.Th.U's./sq. ft., e.g. generally domestic buildings, hotels, offices, etc.

4

- (2) Occupancies of Moderate Fire Load are those in which the fire load exceeds 100,000 B.Th.U's/sq. ft. but does not exceed 200,000 B.Th.U's./sq. ft., e.g. generally trade and factory buildings.
- (3) Occupancies of High Fire Load are those in which the fire load exceeds 200,000 B.Th.U's./sq. ft. but does not exceed 400,000 B.Th.U's./sq. ft., e.g. bulk storage buildings.

In occupancies in which the fire load consists chiefly of timber, paper, fabrics, i.e. materials having calorific values of the order of 8000 B.Th.U's./lb., these fire loads correspond to weights of about 12 lb./sq. ft., 12-25 lb./sq. ft. and 25-50 lb./sq. ft. respectively. For these materials the corresponding weights may be used instead of the values in B.Th.U's./sq. ft., but for materials having higher calorific values the above weights must be reduced in proportion to the calorific value of the materials concerned.

EFFECT OF NATURE AND DISTRIBUTION OF FIRE LOAD ON GRADING

The grading, as so far presented, is determined only by the amount and calorific value of the materials contained in the building. The same weights of different materials, which may be of the same calorific value, present considerable differences in general fire risk. For example, materials differ in their ease of ignition and the rate at which they burn; some materials may seriously hinder fire fighting because they emit noxious fumes especially when heated, or encourage the burning of other materials. Again, special risks may be found in a building because a process is introduced which involves application of heat to a combustible material, and there is then risk of frequent outbreaks of fire. It is therefore necessary to distinguish between occupancies which have a given numerical fire load but present no special risks, and those of the same numerical fire load but in which special risk arises from one cause or another. We propose to call the former normal risk fire loads and the latter abnormal risk fire loads, or for short "normal" and "abnormal" although the term "exceptional" has been considered as an alternative to "abnormal."

It is not easy to specify the factors which make an occupancy abnormal. Some are concerned with the materials involved, others relate to the process, but we give below a list of some of the factors which introduce high risks. They are separated into two groups, firstly those relating to materials, and secondly those concerned with processes. The list must be regarded merely as a guide and is not exhaustive.

MATERIALS So far as materials are concerned we are of opinion that the materials described as dangerous goods and explosives in the Memorandum of the Departmental Committee (1933) of the Board of Trade on the Carriage of Dangerous Goods and Explosives in Ships should be taken as a basis on which to grade an occupancy as abnormal.

The substances in the list are divided into seven categories as follows, and presence of an appreciable quantity forming the contents or part of the contents of a building would indicate that the occupancy should be graded as abnormal risk.

1. Explosives
2. Compressed "permanent," liquefied, and dissolved gases.
3. Substances which become dangerous by interaction with (a) water or (b) air. Substances falling under (a) also become dangerous by interaction with moisture in the air and to that extent can be included in (b).
4. All substances with flash point below 150°F.
5. Corrosive substances.
6. Poisonous substances.
7. Miscellaneous
 - A. Oxidizing agents.
 - B. Substances liable to spontaneous combustion.
 - C. Readily combustible solids.

In addition we consider it necessary to add two categories of substances which are likely to create special hazards of fire in buildings as follows:

- 8. Substances likely to spread fire by flowing from one part of a building to another;
 - e.g. All oils, fats and waxes, rubber, lard, bitumen, pitch, etc.
- 9. Substances in such a form as to be readily ignitable:
 - e.g. Wood shavings, paper, pieces of fabric, cotton, rags, fibre, down, flock, kapok and similar materials, flour, coal dusts, metal dusts, and other dusts and powders.

Use of one or other of the following typical processes might also indicate that the occupancies should be graded as abnormal.

- 1. Those involving the application of heat, especially to combustible materials, e.g. gas singeing, ironing, drying rooms and compartments, heat treatment, creosoting, etc.
- 2. Those involving the production of inflammable water or dust, particularly when the latter arises through the use of disintegrators, grinders and such like reducing machines.
- 3. Spray painting with inflammable or explosive liquids.
- 4. Use of inflammable solvents.

It is clear that the presence of small quantities of these materials, or the carrying on of a process on a small scale as an accessory to an otherwise normal occupancy, might not justify grading of the occupancy generally as abnormal. For instance, that part of the occupancy which is regarded as abnormal but has the same numerical fire load as the remainder may be adequately separated from the remainder by fire resisting construction, and it would therefore be unreasonable to grade the whole occupancy as abnormal in such circumstances.

The contents of a building are rarely disposed uniformly over the whole floor area. From the fire protection standpoint it would be undesirable to have all combustible material concentrated on a fraction of the floor area, as the average taken over the whole area would not give a true representation of the actual conditions, and the resulting effects on the structure immediately surrounding would be out of all proportion to those expected on the basis of average fire load. An investigation of the effects of fires suggests that when the fire load over any 10 ft. square of the floor area does not exceed twice the average and the contents are reasonably distributed in such units, the effects on the structure are not appreciably different from those found with a more uniform distribution. For example, if the contents on a floor in an occupancy of low fire load, i.e. not exceeding 100,000 B.Th.U's./sq. ft., were reasonably distributed in units which did not exceed 200,000 B.Th.U's./sq. ft. over any 10 ft. square, the effects on the structure would not differ appreciably from those due to a uniform distribution of 100,000 B.Th.U's./sq. ft.

In almost all occupancies not specifically designed for bulk storage, some part is used for storage. Thus, in offices storage space must be provided for records; in factories and shops reserve stocks, which may locally amount to a fire load of 1,000,000 B.Th.U's./sq. ft. or more, must be kept. If high concentrations of material are taken into account in computing the fire load the result may well be to force that occupancy into a higher classification than could be justified. Again, examination of occupancies which have suffered a complete burn-out indicate that high concentrations of this kind can cause severe damage to a building, but the effects are largely determined by the area over which the concentration of load is spread. If the area is of the order of 100 sq. ft., damage is often serious, and it is desirable that where there is likely to be need for storage space of this kind, it should be properly separated from the remainder by construction of an adequate grade of fire resistance and be limited in area, but the area may be omitted from the computation of fire load.

PROPOSED THREE GRADES OF OCCUPANCY

In order to take account of factors such as those just mentioned and provide greater tolerance in practice, it is thus desirable to qualify the grading scale previously stated as follows:

- REQ. 1HR. 1. OCCUPANCIES OF LOW FIRE LOAD. The fire load of an occupancy is described as low if it does not exceed an average of 100,000 B.Th.U's./sq. ft. of net floor area of any compartment, nor an average of 200,000 B.Th.U's./sq. ft. on limited isolated areas, (provided that storage of combustible material necessary to the occupancy may be allowed to a limited extent if separated from the remainder and enclosed by fire resisting construction of an appropriate grade.)
- 2HR 2. OCCUPANCIES OF MODERATE FIRE LOAD. The fire load of an occupancy is described as moderate if it exceeds an average of 100,000 B.Th.U's./sq. ft. of net floor area of any compartment but does not exceed an average of 200,000 B.Th.U's./sq. ft., nor an average of 400,000 B.Th.U's./sq. ft. on limited isolated areas, provided that storage of combustible material necessary to the occupancy may be allowed to a limited extent if separated from the remainder and enclosed by fire resisting construction of an appropriate grade.
- 4HR 3. OCCUPANCIES OF HIGH FIRE LOAD. The fire load of an occupancy is described as high if it exceeds an average of 200,000 B.Th.U's./sq. ft. of net floor area of any compartment but does not exceed an average of 400,000 B.Th.U's./sq. ft. of net floor area, nor an average of 800,000 B.Th.U's./sq. ft. on limited isolated areas.
- Handwritten notes: ~~100,000~~ NOT > 100 # NEGL. if > 100 # + CUT OFF, NEGL. ECT.

APPLICATION OF GRADING OF OCCUPANCY

Where the intended occupancy is known, it would be possible to determine, with the aid of material calorific value tables, the numerical fire load of the building and hence the proper occupancy grading.

While this grading scale will cover the greater proportion of occupancies, there remain a number which cannot conveniently be included in any one of the above groups. Firstly, there is a group of occupancies in which the fire load exceeds 400,000 B.Th.U's./sq. ft. There are, secondly, other occupancies which have fire loads falling within the limits of one or other of the above grades, but which require individual consideration because of the special risk, which in some cases may be very high, e.g. storage or manufacture of celluloid, but in others very low, e.g. churches and cathedrals. They will include, in addition to the above, such occupancies as underground car parks, flour mills, exhibition buildings, munition factories, tanneries, etc.

-6-

GRADING OF BUILDINGS ACCORDING TO THE FIRE RESISTANCE
OF THEIR STRUCTURAL ELEMENTS

Having graded the hazards, it is now necessary to consider the measures required to give the desired structural protection. The precautions include both passive and active defence measures. Fire fighting is of course assumed to be available in all cases, and we first consider the question of structural resistance to fire by grading buildings on the basis of the fire resistance of their elements in relation to the fire load.

We have taken, as a starting-point for grading, a form of construction so protected that the structural elements will resist a complete burn-out of the combustible contents without failure, and restrict spread of fire out of the compartment in which it starts, irrespective of any other means of dealing with the fire. We then consider other forms of construction giving lower levels of structural protection. It would be unduly onerous to require that every building should be so protected that it would resist a complete burn-out of its contents without collapse, for thereby we should not only eliminate certain forms of construction which have shown themselves to be of great utility, but also would largely increase the cost of building, and at the same time neglect the effect of other means of defence, e.g. fire fighting.

Taking therefore as a starting-point the provision of structural precautions to resist the effects of a complete burn-out, it is clear that different grades of fire resistance will suffice for that purpose according to the fire severity which is determined by the fire load. Thus in a building of high fire load the fire will be longer and hotter, i.e. of greater severity, than the fire in a building of low fire load.

The British Standard 476-1932 enables various elements of structure to be graded according to the time for which they resist a certain standard fire severity determined by a time-temperature curve based on observations in actual fires. Thus if we can establish the relationship between the fire load of a building and the equivalent severity of the test fire expressed in hours of heating under test conditions, a means will be provided whereby buildings may be graded on the basis of their resistance to fire in relation to the fire load.

RELATION OF FIRE SEVERITY TO FIRE LOAD

The relation between standard heating and the temperatures and duration of fires in buildings due to the burning of various amounts of combustibles was first investigated in America. Several tests were carried out in which known weights of timber and paper were ignited and allowed to burn out in a specially built structure, the temperatures reached during the fire being recorded and plotted. It was then possible to match the curves so obtained with the corresponding curves of the various periods of the American standard test, and in this way to assess the equivalent severity of the building fire, i.e. in terms of hours of standard heating. The results of these tests are given in Table 1, where the relation is expressed in terms of the weight per sq. ft. of the combustible material burned, which had calorific values between 7000 and 8000 B.Th.U's./lb., and the fire load in B.Th.U's./sq. ft. The standard heating is expressed in terms of hours of heating according to the standard American time-temperature curve, which is sufficiently close to the British Standard time-temperature curve to permit direct application of the results to the latter.

TABLE 1. EQUIVALENT SEVERITIES OF BUILDING FIRES
(AMERICAN RESULTS)

3

Combustible Content		Equivalent Severity Of Fire in Hours Of Standard Test
Weight lb./sq. ft.	Fire Load* B.Th.U's./sq. ft.	
10	80,000	1
15	120,000	1½
20	160,000	2
30	240,000	3
40	320,000	4½
50	380,000	6
60	432,000	7

British

< 100000 1 HR

1-200000 2 HR

2-400000 4 HR

we seem to have considerable error comparing areas in upper end of curve

*Calorific value of materials 7000-8000 B.Th.U's./lb.

If the calorific value of the materials differs appreciably from that of timber and paper, it would be necessary to adjust the weight of the combustible materials in Col. 1 to give the same fire load, e.g. the weight of a material having a calorific value of 16,000 B.Th.U's. to give an equivalent severity of 1 hour would be 5 lb./sq. ft.

Further data on the relation have been forthcoming from recent work carried out by the Building Research Station. The method adopted in the above tests of measuring the temperatures throughout the fires virtually precludes its application to actual building fires. The Building Research Station has recently developed a method whereby the temperatures reached in the walls, concrete columns, etc., of buildings during a fire can be estimated with sufficient accuracy long after the fire. It depends on the fact that brickwork mortar and concrete made with siliceous aggregates show certain colour and other changes which develop at fairly well defined temperatures. The temperatures so recorded were compared with the temperatures reached in a similar element when subjected to the standard heating for various times. In this way it was again possible to determine the equivalent severity of the building fire, i.e. in terms of the standard heating, and, from a knowledge of the fire load, to obtain the relation between the two quantities. The method, which is more fully described in the Appendix, has the advantage that it can be applied to any building after a fire, and the effects of variations in materials which could not be dealt with in the American tests have been brought out. The results agree reasonably with the data of Table 1 for low fire loads, but indicate that the equivalent fire severities for higher fire loads are somewhat lower than those of Table 1. In arriving at the values which are given in Table 2, the relation between the conditions under test and the building fire has been fully considered. The relation is complex, and it would be beyond the scope of this Report to consider the matter in detail. We have, from a consideration of these two sets of data, adopted as a simple basis for our grading the equivalent severities given in Table 2.



TABLE 2. ASSUMED EQUIVALENT SEVERITIES OF BUILDING FIRES

Fire Load B.Th.U's./sq. ft.	Equivalent Severity of Fire In Hours of Standard Test
Less than 100,000 i.e. low fire load	1
100,000-200,000 i.e. moderate fire load	2
200,000-400,000 i.e. high fire load	4

1955
see further work in notes

In arriving at the above figures we have considered the average results obtained for a number of occupancies, but it was clear that considerable variations could be expected from these average results. For example, there are instances where the severity of the fire would be greater than that expected from Table 2. Conversely there are instances where fire loads may give rise to fires which fall much below the equivalent severity expected, e.g. in stacks of waste paper which, owing to the close packing, cannot burn freely. These results are due essentially to variations in the rate of combustion, but there are not sufficient data to distinguish clearly between the degrees of resistance required. Again, the area of window through which heat can escape is a factor which may be important, for example, in basements with limited exit for heat.

Another factor which may have an important influence is the overall size of the building. It is clear that a very small area of high fire load may not contain sufficient heat to produce the effects expected; in a very large area, on the other hand, there may be concentration of heat at the centre of the area. There is no clear evidence to indicate how important this may be, but we consider that the data will fit the majority of cases, and general experience of the behaviour of buildings in blitz fires accords well with the results. These are points, however, which merit further research.

We conclude from these results that, in a building of low fire load, a fire resistance of 1 hour in the elements of structure would enable the building to withstand a complete burn-out without collapse. Similarly in a building of moderate fire load a fire resistance of 2 hours would be adequate, and for high fire loads 4 hours. We have thus obtained the necessary basis on which to formulate requirements for that grade of building which should resist a complete burn-out without failure and which we propose to call "fully protected construction."

FIRE RESISTANCE REQUIREMENTS FOR FULLY PROTECTED CONSTRUCTION

It is now possible to consider the fire resistance requirements which we propose for buildings of fully protected construction containing occupancies of low, moderate, or high fire loads, which, as indicated in Table 2, may give rise to fires of which the equivalent severities are 1, 2 and 4 hours respectively. To resist these equivalent severities, the elements of structure in the buildings would need to be of at least 1, 2, and 4 hours fire resistance. For convenience it is proposed to describe buildings with elements of structure having a fire resistance of not less than 4 hours as Type 1 construction. Buildings in which the elements of structure (excluding separating walls) have a fire resistance of not less than 2 hours are described as Type 2 construction and those in which the fire resistance is not less than 1 hour as Type 3 construction. For certain elements of structure in each of these types a higher grade of resistance than is indicated by Table 2 is considered desirable. These changes relate to external, separating and division walls and are considered below. The proposed grades of fire resistance are summarized in Table 3.

EXTERNAL WALLS

Whilst in respect of external walls we have generally adhered to the minimum grades of fire resistance to resist a complete burn-out, it is recommended that in the case of external walls of 1 hour fire resistance, their use should be restricted to the walls of buildings of framed construction not exceeding 50 ft. in height. We regard the height limitation as a temporary measure until practical experience justifies its relaxation; the need for framed construction where 1 hour fire resistance is proposed is considered desirable on grounds of stability. In all other cases of low and moderate fire-load occupancies the fire resistance of the external walls should be at least 2 hours, and 4 hours in the case of occupancies of high fire load.

SEPARATING AND DIVISION WALLS

We have considered it desirable, for the purpose of this Report, to avoid the use of the term "party wall" in view of the fact that the term is commonly used in different senses. We have therefore used the term "Separating Wall" where reference is intended to a wall which separates buildings, and the term "Division Wall" where reference is intended to a wall which separates parts of the same building. For separating walls we propose that the fire resistance should be not less than 4 hours irrespective of considerations of the fire load. This is necessary because the occupancy on each side of the wall may vary from time to time. On the other hand, the fire resistance of the division wall can be related to the fire load, so that in the case of an occupancy of high fire load the fire resistance should be not less than 4 hours, and for an occupancy of moderate fire load not less than 2 hours. On this principle the fire resistance of the division wall in a building of low fire load need be only 1 hour, but we consider that on account of the special function which the wall has to perform the fire resistance of 2 hours should be regarded as a minimum, even for occupancies of low fire load, to ensure full protection in all cases. It must be appreciated, however, that in considering separating and division walls there may be factors which justify the use of walls thicker than those which would comply with the proposed standards.

USE OF COMBUSTIBLE MATERIALS

Although a relatively high standard of fire resistance may be obtained with certain combustible elements of structure by taking special precautions, their incorporation in buildings of Types 1-3 construction would defeat the object aimed at in those types. For example, a timber joist floor may be protected by means of pugging and special ceilings so that it affords 1 hour or more fire resistance under test conditions, but fire on the upper surface may ignite the structure and lead to a complete burn-out. We therefore consider that all structural parts of buildings of Types 1-3 construction which are required to have a specified grade of fire resistance should be of incombustible material, except that timber doors which attain the required grade may be used.

FIRE LOADS GREATER THAN 400,000 B.Th.U'S./SQ. FT.

In principle a fire resistance of more than 4 hours would be necessary in the structural elements of buildings where the fire load exceeds 400,000 B.Th.U's./sq. ft. if risk of collapse from a complete burn-out is to be expected. This fire load, which corresponds to about 50/lb./sq. ft. of combustible material of calorific value of 8000 B.Th.U's./lb. may, of course, easily be exceeded in bulk storage warehouses. For such buildings 6 hours protection could be used if desired, but in general it would probably be unduly onerous in some respects to require a 6 hours fire resistance, bearing in mind the fact that under normal conditions supplementary protection is available in the form of fire fighting, etc. It seems, therefore, that whilst it may be left to the discretion of a designer to adopt a 6 hours fire resisting construction, it would be preferable not to make this standard obligatory except for separating and division walls, but rather to require 4 hours fire resistance in the elements on the understanding that the construction should not be regarded as fully protected.

OTHER SPECIAL OCCUPANCIES

In occupancies which are graded as "special" because of the presence of highly inflammable materials, e.g. celluloid, the actual fire severity corresponding to any given fire load may, as previously indicated, exceed the equivalent severity quoted in Table 2. The least fire resistance required may be determined solely from the estimated fire load, but special precautions may be necessary in other respects and each occupancy should be considered individually. It may, however, not be possible from the structural standpoint to describe the construction so determined as fully protected.

TABLE 3

Type of Construction	<u>MINIMUM FIRE RESISTANCE OF STRUCTURAL ELEMENTS IN FULLY PROTECTED BUILDINGS</u>								
	Walls				Columns and Beams Supporting				
	External	Separating Fire Wall	Division compartment cut off	Other Fire-Resisting or Load-Bearing Walls	External Walls	Division Walls	Other Fire-Resisting or Load-Bearing Walls	Floors	Staircases, Floors and Flat Roofs
Type 1	4	4	4	4	4	4	4	4	4
Type 2	2	4	2	2	2	2	2	2	2
Type 3	1* 2†	4	2	1	1* 2†	2	1	1	1

COLS & pilisters panel wall or curtain wall.

* In buildings of framed construction when height does not exceed 50 ft.
† Minimum for load-bearing walls, and other walls exceeding 50 ft. in height.

*important
& must retain
stability*

*seems
unrealistic
to require
> combustibility*

APPENDIX

Condensation of
National Building Studies
Technical Paper No. 4
Investigations On Building Fires
Department of Scientific and Industrial Research

One of the difficulties in the way of systematic developments in the fire grading of buildings is that of correlating the behaviour of elements of structure in laboratory tests with behaviour in actual fires. It is true that general experience shows that elements which behave well in fires also behave well in fire tests, while others which have but a short life behave poorly under test, but there still exists a need for more definite data. While a complete similarity in behaviour would hardly be expected when the variables which may be encountered in an actual fire are contrasted with the necessarily standardised condition of a fire test, it is an important step to determine what temperatures are attained in actual fires and what temperature gradients have existed in the building materials.

The method referred to in the Report for estimating the severity of building fires was developed as a result of studies made on the behavior of various types of building materials.

Visible changes in the appearance of natural stones, cement and lime mortars and concrete after exposure to fire have been observed and recorded on many occasions but no attempt appears to have been made to study their nature or causes. In connection with problems relating to the severity of building fires it is necessary to have available some reasonably reliable method of assessing the temperature and duration of the fires and as direct measurement during a building fire is obviously out of the question, recourse to other means is necessary. In the conduct of full scale fire resistance tests on brickwork, reinforced concrete, etc., at the Fire Testing Station, Mr. C. T. Webster of the Building Research Station had observed that the depth to which certain colour changes occurred in the mortar and concrete varied in a well-defined manner with the duration of heating and it appeared possible that these changes might be adapted for the purpose mentioned above, if it could be established that they occurred at sufficiently well-defined temperatures. The work described in the present paper was carried out to determine to what extent the observed changes were critical and also the temperatures at which they occurred. In the course of the work further changes have been observed which provide a means of assessing the temperatures over a wide range.

Experiments were carried out on samples of aggregates alone and on mortars and concretes.

AGGREGATES

Samples of sands and various types of aggregate were heated in an electric furnace at temperatures from 200°-1,000°C. in steps of 100°C. or in some cases 50°C. for varying periods. The observations and the conclusions drawn are given below.

QUARTZ SAND AND SANDSTONES

In all sands and sandstones except the colourless pure quartz sands there was a marked change in colour at 250°-300°C. This colour change, from the normal yellow or brown to a pink or reddish brown is well known, but no previous recording of the temperature at which it occurs has been found. The change is relatively sharp.

At 200°C. none is apparent after up to 18 hours heating; at 250°C. the colour develops slowly and is fully developed in 18 hours; at 300°C. it is fully developed in 2 hours. At higher temperatures up to 1,000°C. there is generally little further change although some samples show an intensification of the pink or red colour.

As the original yellow or yellow brown colour of many sands is due to the presence of small quantities of iron compounds it seemed that the colour change was most probably dependent upon the presence of iron compounds in the stone or coating the sand grains, and examination of the literature on the effect of temperatures upon the hydrated iron oxides shows a close agreement between the dehydration temperatures of all these compounds and the observed colour-change temperature of 250°-300°C. Fischer^(*) states that limonite decomposes with a colour-change from yellow to red at 300°C. Williams and Thewlis^(*) found Lepidocrite (γ FeO(OH)₂) was converted to the γ oxide at 250°-300°C. Posnjak and Merwin^(*) also found that Goethite (α FeO(OH)) lost very little water below 250°, but was almost completely dehydrated at 300°C. Hansen and Brownmiller^(*) in examining precipitated ferric oxide hydrogel found that it had no structure, as judged by X-ray diffraction after heating at 200°C. but that after heating at 300°C. it had the haematite (Fe₂O₃) structure. There can thus be little doubt that the colour change in sands and sandstones corresponds with the dehydration of the iron compounds and that its presence is a reliable indication that the sample has been heated to a temperature of at least 250°-300°C. (the higher temperature with shorter heating periods).

As mentioned above there is no further change in colour of sands or sandstones, but at 573°C., the inversion temperature of the two forms (α and β) of quartz, there is a considerable expansion of the quartz grains. This usually causes internal rupturing of the grains of sand, and weakens sandstones, often making them friable to handle. Samples which are appreciably weaker or more friable than the unheated stone have therefore been heated above 573°C.

FLINT

Flint gravel showed a colour change at 250°-300°C. similar to that observed with sand or sandstone. The amount of red colour developed varied with the initial colour of the flint. At temperatures above 500°C. some shattering of the flint occurred, partly it is thought as a result of removal of combined water from the flint and partly through the high-low quartz inversion; the absence of such visible effects may not, however, always be a reliable indication that this temperature has not been exceeded. Apart from the visible shattering the lighter coloured fractured surfaces became more white in appearance above this temperature.

Flint that has been held at temperatures above 1,200°C. for any length of time has a lower density than unheated flint, owing to partial conversion to cristobalite.

LIMESTONE

Limestone which contains any hydrated iron oxide was found to develop marked pink or red colours at 250°-300°C in the same way as sandstones. The colour varied considerably but was in practically all cases well defined. It sometimes increased in depth at higher temperatures up to about 600°C. At temperatures above about 700°C. calcination of the limestone occurred, becoming rapid at 850°-900°C.; when calcination occurs the red colour disappears and the specimen disintegrates slowly on exposure to moist air.

IGNEOUS ROCKS

Igneous rocks generally have been found to show no colour change on heating. The more acid types (e.g., granite) sometimes crack or shatter at temperatures above 573°C. through quartz expansion; basic types (dolerite, basalt) show no effect at that temperature but may show expansion effects when heated above about 900°C.

SLAG

Blastfurnace slag aggregates in general are unaffected by temperatures below about 1,200°C.

CRUSHED BRICK AGGREGATE

Crushed brick aggregates show no effect at temperatures below sintering temperature. This may vary, for different types of brick; "flow" of the aggregate will rarely occur below 1,000°C. and may in some cases not be observed below 1,200°C.

CONCRETE AND MORTAR

PORTLAND CEMENT-QUARTZ SAND MORTAR

Cement mortar briquettes (1:3 Portland cement:sand) made with two different sands, one of high and one of low iron content, were stored for one week in water and one week in air. Individual briquettes were then heated for two hours at various temperatures.

The changes in condition and appearance of these briquettes are shown in Table 1. The appearance of a pink colour at 300°C. corresponds with that observed on heating sand alone, but it is less marked and with a sand of low iron content can only just be observed. Most sands used for building mortar have, however, a considerable iron content and in subsequent observation of mortars in buildings which have suffered damage by fire the change has been clearly distinguishable.

TABLE 1. CHANGES IN CEMENT MORTARS HEATED TWO HOURS AT VARIOUS TEMPERATURES

Temperature	Mortar A (Pale Coloured Sand)		Mortar B (Red Sand)	
	Appearance	Strength	Appearance	Strength
Unheated	Grey	-	Buff	-
200°	Slight darkening	V. slight drop	No change	V. slight drop
250°	Ditto	Further ditto	Ditto	As 200°C.
300°	V. slight pink	Ditto	Pink	As 200°
400°	Slightly darker than 300°	Ditto	Ditto	As 200°
600°	As 400°	No appreciable strength	Sl. deeper pink	No appreciable strength
800°	Dark, but not perceptibly pink	Ditto	Deeper red	Ditto
900°	Lighter grey	Ditto	-	-
1,000°	Much lighter grey with no pink	Ditto	Pink nearly disappeared	-

29

Up to a temperature of about 500°C. the strength was not sufficiently affected to modify the apparent condition of the mortar, but at 600°C. it had become conspicuously weak and friable. This change is sufficiently sharp to serve as an indication that the mortar has been heated to at least 550°C. The pink colour was lost at temperatures of 600°-800°C. in the briquettes made with sand of low iron content, but remained with changes in intensity and tint even at 800°C. with the sand of high iron content; this loss of pink colour is discussed later in connection with concretes.

Small blocks of brickwork 12 in. x 9 in. x 9 in., were built with London stock brick and 1:3 Portland cement: sand mortar, using an average building sand and cured for 14 days before test. Thermocouples were embedded at various depths from the centre of one 12 in. x 9 in. face and were connected to a temperature recorder. One block was plastered with 3/4 in. of cement: lime: sand mortar and 1/4 in. of gypsum plaster on the face to be heated. The blocks were heated on one 9 in. x 12 in. face by a gas-fired furnace, the furnace temperature following as closely as possible the standard curve of the British Standard Definitions for Fire Resistance, etc. (B.S. 476, 1932) and the furnace atmosphere being fully oxidising. After completion of the heating period the furnace and specimen were allowed to cool down together.

The test results indicated that the temperatures within the block show very clearly the effect of free moisture in absorbing heat and thus delaying temperature rise above 100°C., and also show the markedly increasing lag in attaining the maximum temperature at greater depths from the heated face. The lag in heating and cooling probably helps to increase the sharpness of the visible changes in the mortar since it lengthens the period at which any portion of the material is at its maximum temperature.

The sand used in the mortar had a rather high iron oxide content and the red colour was developed strongly in each test in the mortar heated to above about 300°C. The discharge of the red colour occurred over the range of temperature roughly 550°-750°, giving an intermediate pinkish grey band about 1 in. wide. The width of this band probably results from the high iron content; it was much smaller in the tests on concrete. At about 900°C. the grey colour was changed to a buff or yellowish grey.

The plaster fell off the face of the block during the test, and its only effect was to reduce the depth of brickwork heated above 300°C. and 600°C. by about 1/2 in. as compared with the unplastered specimen.

PORTLAND CEMENT—FLINT GRAVEL—SAND CONCRETE

The experiments on concrete were carried out mainly on slabs 13 in. x 8 in. x 4 in. or 13 in. x 8 in. x 6 in., heated on one 13 in. x 8 in. face. In most cases the slabs were stored initially for 24 hours in moist air, then for 28 days at 65 per cent relative humidity and 65°F. (18°C.) Thermocouples embedded at various depths in the centre of the slab, and a sheathed-thermocouple in the furnace close to the slab, were connected to a temperature recorder, and heating was carried out as described for the brickwork specimens.

The changes observed in all these concrete slabs on breaking them open were similar and differed only in position according to the period of heating. Changes at four distinct temperatures were noted as follows:

- (1) At 300°C. approximately, the red colouration previously described in the mortars replaced the normal grey of the concrete. This colouration is distinctive and the boundary between the red and grey portions could be readily defined. With different sands it was found to vary in intensity and in some cases needed a practiced eye and suitable lighting to determine the depth affected.

31

(2) At a temperature between 500°C. and 600°C. some cracking of the coarser flint aggregate was observable, and at the upper end of this range the concrete cracked and became friable; this is no doubt mainly a result of the quartz inversion as previously mentioned.

At a temperature similar to or slightly higher than the above a change in colour from the red or pink to grey is observable. This change is most probably due to reaction of the ferric oxide with lime, forming calcium ferrites of lower pigenting power. This is largely confirmed by the persistence of the pink colouration in the case of materials not containing lime, e.g., sandstones, flint gravel, even at 1,000°C. Such a solid reaction will be relatively slow and the temperature at which the red colour disappears may therefore depend on the amount of iron oxide present and upon the time of exposure at the maximum temperatures. The range of variation may be taken as approximately 550°-700°C.

The colour change at this point is intensified by treatment of the broken concrete surface with a dilute acid (10 per cent acetic acid is suitable and convenient to use). The concrete above the quartz inversion temperature absorbs water or the dilute acid rapidly and the colour is darkened markedly, with a dull appearance even on drying again. Below this temperature absorption is slower, like that of the unheated concrete, the acid remains on the surface longer, and reacts with the cement giving a more intense colour with a somewhat glossy appearance.

Although the colour change (without acid treatment) does not by itself indicate a very definite temperature, the change in absorption and colour after acid treatment together with the cracking and friability of the concrete above 600°C. are sufficient to define the depth to which this temperature (600°C.) has been attained.

(3) At temperatures near 1,000°C. the colour of the concrete again changed from a cement grey to a buff shade, but the change in appearance is not always as sharply defined as the other changes at lower temperatures. The depth at which this colour change occurs can however usually be seen and may be taken to indicate a maximum temperature of about 950°C.

(4) Sintering of the concrete occurred at temperatures above about 1,200°C. to an extent which depends largely upon the amount of iron oxide present. Incipient sintering is usually seen as a "crackled" surface, with a yellow colour and individual brown spots where there is a higher iron content.

TABLE 2. MAXIMUM DEPTH (IN INCHES) OF CONCRETE SHOWING CHARACTERISTIC CHANGES ON HEATING

Concrete Heated	Maximum Surface Temperature Attained	Change			
		Development of pink or red 300°C.	Fading of red, friability and high absorption 600°C.	Development of buff 950°C.	Sintering 1,200°C.
1 hr.	950°	2 1/4	3/4	6	6
2 hrs.	1,050°	4	1 1/4	1 1/4	6
4 hrs.	1,230°	5 1/2	2 1/2	1	1/8
6 hrs.	1,250°	6-3/4	3 1/2	1 1/2	1/4

The depths at which the four changes discussed above were observed in slabs heated for 1, 2, 4 and 6 hours respectively are given in Table 2. The maximum temperatures attained in the concrete for these various periods of heating, corresponding to the various grades of Fire Resistance of B.S.D. 476, are shown in Fig. 1. It should be noted that the maxima shown within the concrete are not all attained until after the end of the heating period, the lag depending upon the depth from the heated face.

REPRODUCIBILITY AND INTERPRETATION OF OBSERVED CHANGES IN TERMS OF TEMPERATURE

In the experiments already described the various characteristic changes in appearance of the concrete were found to occur within a fairly short temperature range, the range being due primarily to the duration of exposing of the concrete to the temperature. Further experiments were carried out in a similar manner to determine whether the duration of steady maximum temperature, or the rate of cooling had any effect; no significant differences were found. The effects of carrying out the test with thoroughly wet concrete instead of dry were also found to be not significant.

The following conclusions were drawn with regard to the accuracy with which the changes in appearance can be used to judge the temperatures to which a sample of concrete or mortar has been exposed.

THE RED COLOURATION (300°C.)

The development of the red or pink colouration in concrete or mortar containing natural sands or aggregates of appreciable iron oxide content occurs at 250°-300°C. Unless the period of heating is known to have been prolonged over 6 hours or more the upper limit of this range can be taken as the transition temperature. The demarcation between changed and unchanged concrete or mortar is usually sharp and the depth which has been heated above 300°C. can generally be judged to $\pm 1/8$ in. if a good section is available, or $\pm 1/4$ in. in less favourable circumstances. Greater accuracy is usually possible in the case of cement mortars than with concrete, and with small depths of penetration the demarcation can generally be estimated after some practice to within the lower range.

THE SECOND GREY COLOUR AND CRUMBLING (600°C.)

The second definite change or series of changes occurs around 600°C. with siliceous aggregates, but is less sharp than the 300°C. change. The disappearance of the red or pink colour with return to a grey occurs generally between 600°C. and 700°C., depending upon the time of heating and other factors; expansion effects such as cracking of flint gravels, and general weakening or friability of the concrete or mortar are evident at 500°-600°C. Observation of these effects together, in doubtful cases, with confirmatory observations by acid treatment of the exposed section, make it possible to judge the depth heated above 600°C. to $\pm 1/4$ in., or in less favourable cases $\pm 3/8$ in.

THE BUFF COLOUR (950°C.)

The change from the second grey colour to a buff is often rather ill-defined and its temperature varies with the rate of heating and other factors from about 900°-1,050°C. If it be assumed that this change corresponds to a temperature of 950°C. the error in judging the depth of penetration of this temperature may be only $\pm 1/8$ in. where the penetration is small and the temperature gradient steep, or up to $\pm 1/4$ in. where the penetration is greater.

THE SINTERING POINT (1,200°C.)

Only in cases of exposure to the most severe and prolonged fires is mortar or concrete likely to reach a temperature of 1,200°C. to any significant depth. Sintering above this temperature is generally well marked and the depth affected, if it remains on the concrete or mortar surface and does not spall away on cooling, can often be judged to within $\pm 1/16$ in.

It is concluded from the results of the tests on aggregates, mortars and concretes that changes in the appearance of concrete or mortar at approximately 300°C., 600°C., 950°C., and 1,200°C., are sufficiently reproducible and well defined with most siliceous aggregates to make it possible to assess with reasonable accuracy the temperatures attained by sections of concrete or mortar that have been subjected to heat above any of these temperatures. The change at 300°C. (development of red colour) is probably the most useful, but where the depths can be ascertained at which two or more of the above changes occur, it is possible to obtain the temperature gradient.

From the results produced by these studies, it was possible to examine walls and columns which had been subjected to standard fire tests (B.S. 476) at the Elstree Fire Testing Station and accurately determine the maximum temperatures which existed at various depths within the walls or columns as a result of exposure to the Standard Time-Temperature fire severity for various durations. From this point, it was then necessary to proceed one step further. Walls and columns of buildings which had been subjected to actual fires were then examined and compared with the results obtained from standard fire tests. This comparison along with a reconstruction of the fire load which had existed in the building prior to the fire made it possible to obtain the desired correlation between fire load and standard fire severity. The following example illustrates this method:

In applying the method to actual building fires the first procedure is to cut into the walls or columns of the building to determine the depths to which the change has penetrated in the mortar or concrete. A typical record of results obtained in two compartments of a storage building separated by 22½ in. brick division wall is given in Fig. 2. The record indicates that the heating in the parts adjoining this wall was, as might be expected, more severe than the heating of the walls near the windows, a feature attributable to loss of heat through the windows. The mean of these measurements on the division walls were used to plot the temperature gradient in Fig. 3. The surface temperature has been assumed to be the maximum temperature noted in the fire. This is probably higher than the actual surface temperature. The figure also shows the temperature gradients attained in a brick wall after exposure to 2 hours and 4 hours heating according to the standard time-temperature curve. It will be noted that the 2 hours test curve crosses the building fire curve, whilst the 4 hours test curve lies wholly above it. For present purposes it has been assumed that the severity of the building fire is equivalent to that period of exposure to the standard heating which causes the temperatures at all points in the thickness of the wall or column to be greater than those caused by the building fire. The equivalent severity of the fire in compartment A is therefore 4 hours. This basis of comparison gives results which are probably on the safe side, and more detailed analysis of the matter is necessary, taking into account criteria of failure, etc., before a more exact comparison can be made.

Corresponding curves for compartment B are shown in Fig. 4, whilst in Fig. 5 the results obtained in another storage building are shown. In this case the results are based on measurements of the depth to which the changes occurred in the reinforced concrete columns. The temperature gradient for the building columns and a 2 hours test on a reinforced concrete column are shown in Fig. 6, from which it will be noted, on the above assumption, that the fire was equivalent to about 2 hours exposure.

RELATION BETWEEN SEVERITY AND FIRE LOAD

From a knowledge of the fire load of any building or compartment it is now possible to determine the relation between the severity of the fire and the fire load. Estimates of the fire load in the examples quoted above gave values in the first case of 500,000 B.Th.U's./sq. ft. consisting chiefly of clothing for compartment A, and 400,000 B.Th.U's for compartment B, and 150,000 B.Th.U's./sq. ft. in the latter example. The method has been applied to various buildings ranging from office occupancies, having relatively low fire loads, to the storage building referred to in the first example.

Whilst the investigation has afforded much insight into the problem of fire severity, and has given results comparable with those obtained by Ingberg, analysis of the results has been concerned mainly with the immediate uses. Full analysis of the data has yet to be made.

Among the factors yet to be taken into account are the effects of rates of combustion and loss of heat on the equivalent severity and on the shape of the temperature gradient, as affecting failure.




FIG. 1. MAXIMUM TEMPERATURES ATTAINED IN CONCRETE HEATED ON ONE FACE FOR VARIOUS PERIODS IN ACCORDANCE WITH THE TIME-TEMPERATURE CURVE OF B.S. 476. *certain type of*




FIGURE 2 DEPTHS OF COLORATIONS
R = red G = gray




FIGURE 3 AVG. TEMP GRADIENTS




FIGURE 4 AVG. TEMP GRADIENTS




FIGURE 5 DEPTHS OF COLORATION
R = red G = gray




FIGURE 6 AVGE. TEMP. GRADIENTS
INSIDE COLUMNS



ILLINOIS INSTITUTE OF TECHNOLOGY

NAME DAVID LUCHT

SUBJECT FPE 309

CLASS _____ DATE DEC. 10, 1963

INSTRUCTOR PROF. MAATMAN

1		11	
2		12	
3		13	
4		14	
5		15	
6		16	
7		17	
8		18	
9		19	
10		20	

94

ave 69

1. Portland Cement is a mixture of Clay ($Al_2O_3 \cdot 2SiO_2 \cdot 2H_2O$) and limestone ($CaCO_3$). These components are mixed and heated to give clinkers composed of $CaO \cdot Al_2O_3$ and $CaO \cdot SiO_2$, which are ground to give the portland cement. When water is added, the CaO goes back to $CaCO_3$ a.e. $CaO + H_2O \rightarrow Ca(OH)_2$ and then upon drying, exposed to air (CO_2) $Ca(OH)_2 \xrightarrow{CO_2} CaCO_3$

2. a. ~~the~~ Perlite conc. is lightweight and \therefore ~~so~~ requires much less supporting steel - which is much more expensive than the perlite conc, esp. when used in lg. bldgs. Also Perlite conc has good FR properties

2. b. Gypsum plaster has very good fire resisting properties and heat insul properties (protects steel). It contains lg amt of H_2O ($CaSO_4 \cdot 2H_2O$) and acts as a good heat insulator as the H_2O keeps the temp at 212° for considerable period. Also the assembly as a whole is comparatively thin and takes up less floor space.

c. This assembly ~~is~~ takes up less vertical space, than ord. steel-conc. assembly with suspended ceiling. This is because utilities can be run thru the cellular steel. The

cellular steel also takes up most of the tensile stress of the assembly and after the conc requires no reinforcing rods.

d. ~~cell~~. a suspended ~~cell~~ ceil. is limited as to how many openings it may have & of what Δ it may be const., esp. when fire ~~res~~ resistance of ~~steel~~ steel bar joint - conc etc is desired. \therefore a sprayed on fireproofing on the unprotected steel will fulfill FR requirements and

The suspended cut only
must be decorative.

7

3.

1. An intumescent surface
coating may be applied
to the plastic after ~~or during~~
its manufacture, ~~which will~~
~~increase~~

2. A mechanical mixture
may be added to the
plastic during its mfr.
e.g. chlorinated wax, antimony oxide

3. A chemical mixture may be added to the resin when formulated to form chemical bonds with the high organic polymers. also ~~to~~ e.g. elminated wax, antimony oxide.

4. a. Composite: Made up of incomb core surfaced either with a material such as wood or plastic (IHR) or steel or aluminum (ZNA). These composites are good for ~~with~~ often used exits ~~as~~ as they aren't too difficult to operate and are fairly nice looking.

2. Tin Clad - these doors are B
made up of a 2ply ~~wood~~ ^{solid wood core} or a

A → 3ply solid wood core, and
surfaced with at least
30 ga. (?) steel. ~~the~~ ~~they~~

they provide good class A
protection for fire walls when
used on each ~~of~~ ^{side} of
the wall. They may be either
of the sliding or swinging
type.

→ Suggested use ?

✓ Kalamain - these are made
up of a wood frame surfaced
with 20 ga (?) steel. They
are lighter weight than
tin clad doors and ∴

easier to operate, however usually only give $\frac{1}{2}$ hr. B protection.


5. The NBS conducted ~~model~~ ^{full scale} bldg human fires with known fire loading and compared the ^(area) T-T curve of this test with ~~the area~~ ^{an equivalent area under} the ASTM std T-T curve and obtained a corresponding std. fire ~~severity~~ severity rating in hours. NBS rates fire load in lb/ft^2

The British made a more realistic attempt to correlate std fire severity with fire loading

They used a std T-T curve
vs to ours and applied
it to different bldg construction
and found that conc. etc
indicated different temp
gradients applied by changing
color. Then they went to
actual bldg fires and
compared the indicated
temp gradients in the
actual burned out bldg
construction to the std.
curve. Then they calculated
the actual fire load
which had been present
before the fire, in BTU/ft².
+ correlated it to the standard
~~observed with~~. Using actual
bldg fires enabled them
to better account for variations
in forms of the math in

the fire load, whereas a high rise of temp and a small area under the ASTM TT curve was unrealistic, since it would indicate a small fire severity and actually the high temp would do considerable damage.

6. The time temp curve may be divided into 3 parts




13

Area A ✓ More vent. makes time for
A less.

Area B ✓ ~~Area~~ 25% or more
window area vent. has
no marked effect on
time for Max Temp (excess air)
@ $\leq 15\%$ ✓ the time for
Max Temp is solely controlled
by vent. (oxygen starved)
✓ 15-25% partially controlled by vent.

Area C. More ventilation \Rightarrow Shorter
cooling time

→ effect on Temp. of vent.



7. Consider OER for entire area ①
~~total area~~ ~~to~~ ~~not~~ neglect stair
 windows + inset.

~~OER = 24 x 33~~

~~TWA = 10(3 x 9)~~

$$\begin{array}{r} 14021 \\ - 2900 \\ \hline \end{array}$$

$$\begin{array}{r} 220 \\ - 590 \\ \hline \end{array}$$

$$\begin{array}{r} 548 \\ - 3080 \\ \hline \end{array}$$

$\frac{1}{6} \sqrt{1.0}$

OER = 24 x 142 = 3408

TWA = 22(3 x 9) = 594

$\frac{594}{3410} = 17.4\%$

first boundary:

height	30	} BD = 18'
width	150	
	20%	

check for separate radiators

$$\frac{1 \times 4}{72}$$

$4(18') = 72'$

$72' > 60' \therefore$ not separate

OER for area (2)

$$\text{OER} = 96 \times 24 = 2304$$

$$\text{TWA} = 16(3 \times 9) + 2(9 \times 40) =$$

$$432 + 720 = 1152$$

$$\frac{1152}{2304} = 50.0\%$$

$$\frac{1152}{2304} = 50.2\%$$

$$\left. \begin{array}{l} \text{height } 30 \\ \text{width } 100 \end{array} \right\} 34'$$

seems logical to consider 50%

check for conc. of exposure of large windows

$$\text{OER} = 24 \times 40 = 960$$


$$\text{TWA} = 2(9 \times 40) = 720$$

$$\frac{720}{960} = 75\%$$

$$\left. \begin{array}{l} \text{height } 30' \\ \text{width } 40' \\ 100\% \end{array} \right\} 34'$$

$$\begin{array}{r} 1630 \\ 490 \\ \hline 4090 \\ 3620 \\ \hline 720 \end{array}$$

$$\begin{array}{r} 2440 \\ \hline 960 \end{array}$$



✓ DOUBLE THESE separation distances
for TOTAL SEPARATION between
bldgs.

● Check concentration of exposure for
one area in ①

$$\pi \text{ OER} = 42 \times 24 \left. \begin{array}{l} \\ \end{array} \right\} 1008$$


$$\text{TWA} = 12(3 \times 9) \left. \begin{array}{l} \\ \end{array} \right\} 324$$

$$\frac{324}{1008} = 32\%$$

$$\begin{array}{r} 42 \\ \times 24 \\ \hline 168 \\ 840 \\ \hline 1008 \end{array}$$

$$\begin{array}{l} \checkmark 40\% \\ \text{height } 30' \\ \text{width } 50' \end{array} \left. \begin{array}{l} \\ \\ \end{array} \right\} 23'$$

See new
book





ILLINOIS INSTITUTE OF TECHNOLOGY


NAME LUCH T

SUBJECT _____

CLASS _____ DATE _____

INSTRUCTOR _____

1		11	
2		12	
3		13	
4		14	
5		15	
6		16	
7		17	
8		18	
9		19	
10		20	



~~-2~~

another cone of RP.

$$OFR = 24 \times \overset{33}{\cancel{36}} = \overset{792}{\cancel{864}}$$

$$TWA = 10 \times (3 \times 9) = 270$$

$$\frac{270}{\cancel{864}} = \overset{34\%}{\cancel{31.25}}$$

$$\checkmark \quad 46\% \overset{792}{} \text{ ht } 30' = \underline{21'} \\ \text{width } 40'$$

05

Need for exits governed by:

- (1) Concentration of population
 - (2) Physical and/or mental condition of occupants.
 - (3) Height and Area of Bldg.
 - (4) Extent and adequacy of public F.D. facilities (mostly ladder equip)
 - (5) Comb. of Interior finish
- Psychological Problems.

1. People Do not Behave normally.
2. Fear is Prin. cause of Panic
3. Panic is contagious
4. People tend to leave bldg. in same manner they entered.

Basic Philosophy of Code:

- (1.) * Based on concept of providing 2 independent choices for exit from any part of bldg.
- Independent - any single fire shouldn't be able to block BOTH.
- (2) Based upon providing free + unobstructed path to this exit.
- (3) Exits and their routes must be clearly visible and marked.

- (4.) where size and arrangement of a bldg. is \Rightarrow the presence of a fire is not ~~usually~~ immediately apparent - to all occupants, then a fire alarm sys. must be provided. (mult. story + lg single story of cons. pop. density)
- (5.) Code built on concept that all vertical openings must be protected. (few exceptions)
- (6.) Code requires minimizing of Highly Comb. Interior trim, ~~esp~~ esp in corridors, exit ways, and lg. assembly rooms.
- (7.) Code does not ~~to~~ generally require but recognizes the desirability of automatic fire prot systems as adjunct to life safety design.

The Code Its self -

Primarily concerned with exits
Uses Population as yardstick.

1. Gross Area Method

e.g. 15 ft²/person - derived from extensive study. They are AVE figures - used primarily in proposed bldgs
~~Net Area~~ - figure based on outside dimensions of bldg.

2. Net Area - inside occupied area.
Neglect corridors, rest rooms, closets
etc.

3. Actual Count Method - after bldg is up
you can count them.

Desirable to use all three and use
~~one~~ one with highest safety
factor. - MAX

EXIT DETAILS

What is an exit? It is a
way of departure from interior
of bldg to open air, outside,
at ground level.

First floor - door to outside

Upper floor - corridor - stairs - etc
to outside.

If enclosed stairwell - exit
would be door into enclosed
stair well assuming it
leads directly to outside.

Some things meet Def but not accepted,
a.e. knotted rope, portable ladder etc.

Exit Measurement -

Unit of exit width 22" down a stair.

(One width of Person.)

Fractions ignored unless $> 1/2$ "

a.e. 28" = 1 unit

34" = $1\frac{1}{2}$ unit

also 43" = $1\frac{1}{2}$ unit

how to meas. stair width.

Ignore encroachment of rail
up to $3\frac{1}{2}$ " on ea. side.

(recognize value of rail)

if ≥ 88 " must have intermediate
hand rail.

For door - permit encroachment
of 0" ~~encroachment~~ for ea.
22". As a.e. permit total
4" jamb for 44" door.

When calculating # exits required,
round off to next higher whole
unless fraction $< 10\%$
of whole #, drop fraction.

Code based on 2 speeds of exit travel

45 people/min/unit exit width
assumed rate down stairs

60 people/min/unit
assumed rate thru level exit
(door)

Example: pg. 43

Educational Stairs - 60 persons/unit exit width

$\frac{60}{45} = 1.33 \text{ min}$ - (not complete ~~time~~ evac, but everyone should

Assembly.

pg 75 211 b.) 75 persons/unit

wh. is protected
he in stairwell

$\frac{75}{45} = 1.67 \text{ min}$

Both use same rate \therefore ea. occy requires diff time of evacuation

Distance to ~~exit~~ exits - meas.
along centerline of travel

is distance to stairwell door
if stairs is prot, opening to outside
If not prot, distance clear
to outside.

In general code requires in
open areas, meas distance from
most remote point (whse etc.)

where bldg is divided into
rooms, meas from door in
room (if room is not occupied
by > 6 persons + if not more
than 50' travel dist) (hotel, apt, etc)

Isles and Corridors leading to exit


1. must have ~~with~~ width
at least = to that of exit
2. must have width = 75%
of total width of ~~total width~~
of ~~exits~~ they feed.
stairs

Doors - min. door width of 30"
 except in private dwellings
 Max width of single swinging
 door is 48" (so they won't be too
 heavy)

2.

All exits doors must
 swing with direction of exit
 travel.

In general code permits only
 swinging door, sometimes one
 swinging & one sliding in fire wall.
 When a doorway is ÷ into smaller
 doorways, ea. indiv. door
 must be credited separately.



Code requires floor level to be
 same and horiz. on ea. side
 of door for width of door
 and width of door out on
 ea. side.

In general requires panic hardware for exit doors on all schools + theatres and any other place of assembly > 500 people.

Revolving doors or Turnstiles -

Only can be used as exit on street floor to outside + can't use them at foot of stairway, and credit ea.

turnstyle or revolving door as $\frac{1}{2}$ unit regardless of size, and can only use them for $\frac{1}{2}$ the required exit requirement for street level, and at any given location revolving door capacity can't be greater than swinging door capacity within 20'

If you use 4 units of revolving, you need 4 units of swinging within 20'.

Stairs - Pg 147-8

Code divides stairs into 3 classes

A. - Conc. of population

B. - all except A

C. - Permitted in Bldg built ~~in~~ ~~before~~ before code in 3 bldgs only.

Recall Max 66" betw rails
height of rail


Outside Stairs 157

OK if permanently fixed
not > 1 sty or appear to be > 1 sty.


Smokeproof Towers ~~158~~ 158

Considered most effective means of egress.

Called smokeproof tower
since smoke, gases, fire
etc will vent to
outside & can't get
in stairs



In ord. stairs, door may be left open + this is obviously not too cool - ~~is~~ in smoke proof tower, it doesn't matter since smoke won't enter stairwell.



RAMPS 159

A } see book
 B }
 C }

FIRE ESCAPE STAIR 162-5

Type stairway added after bldg built
 - only pre ordinance (existing) bldg.
 Can only be used for 50% exit req.


A.

straight run type

B

Return Platform

C



Don't recognize ropes, poles, etc.
portable ladders.

Some poor exits recognized to limited extent pg 169

Class D - unoccupied (e.g. ~~to~~ elevator) pent house

E - existing wood ladders fire escape
1 or 2 fam. dwgs or sm.
dwms.

F - wood ladders

Slide Escapes - 173

In educational bldg
only on existing bldgs
upto 25% req.

L

Except high hazard Industrial
allowed for full req.
=> fastest possible exit

one unit width @ 20/min
& must have drill program.

Escalators - 178

not on educ. bldgs, etc.

Now

max credit 2 units width
90/min

Many escalators may travel
> 90/min, but c/w may fail

Elevators - 181



not recognized - could have power failure

Possibly people couldn't get elevator
in time

Confusion - people push wrong
buttons → may be
set off on fire floor

Elevators may not move
because door held open
by more people trying to
get in.

Horizontal Exit 102



horiz

Advantage - don't have to provide as much stairs

Can be 50% horiz as req.

3rd person for total floor occy must be provided on ea side

Construction & Protection 187

One Basic.

P 4302 Req. all vert. egress prot.
except - low hazard + ord haz.
see pg 191

Interior Finish 200

Class

- A } areas of egress + assembly area.
- B }
- C
- D
- E

Alarm Systems 203

Educational Occy 35

A - 1st ty with any type egress
mult. sty with all ext. egress.

B - mult. sty with encl. stairs

C - sprinkler See pg 40

D - open plan schools - no perm. fixed partitions

E - existing schools

N.F.P.A. BUILDING EXITS CODE

1. Calculate total population for each floor level and/or section of a building by as many of the following methods as is feasible, and use the highest population figure obtained as the basis for calculating the required total quantity of unit exit widths for each floor level and/or section. (Section 11)
 - (a) gross floor area method
 - (b) net floor area method
 - (c) actual count method

2. Calculate total number of units of stairway and ground floor exit width required for the particular occupancy in question. (Sections 21 thru 29)

3. Arrange the required aisles, corridors, doors, stairways and street floor exits in such a manner as to satisfy the various requirements of the code. These include the following:
 - (a) two independent and remote exits from each floor level or large room.
 - (b) specified "distance to exit" limitations for a particular occupancy.
 - (c) protection of stairways used as exit facilities.
 - (d) directness and continuity of path of exit travel.
 - (e) balance as much as possible the total number and capacity of exits for a floor level as between the two or more independent directions of exit travel.
 - (f) adequate path of egress outside of building leading away from street floor exits.

4. Check the various possible construction and occupancy features involved:
 - (a) interior finish requirements.
 - (b) possible use limitations on specific construction types.
 - (c) protection of other vertical openings.
 - (d) requirements for segregation of hazardous uses.
 - (e) special occupancy use requirements.

5. Check the various possible protection features involved:
 - (a) fire alarm system requirements.
 - (b) exit signs and lighting requirements.
 - (c) automatic detection and/or extinguishing system requirements.

6. Check the various possible operating features involved:
 - (a) fire exit drills.
 - (b) maintenance features.

3 basic aspects of BC.

1. Sanitation
2. Structural Req.
3. F.P.

Mimto notes:

1. Provide life safety to occupants
2. " " " " premises
3. " " " " adjoining ~~property~~ property
4. preserve property

* must consider if given B.C. is ~~to~~ within limits of local constitution - can't be exercised - just may make min. req.

Important Aspects of NBFU BC.

1. life safety aspect.

- Exit Req. pg. 53 - patterned after Bldg. Exits code NFPA 101 but may be slightly different (diff times of revision)

- pg. 190 - article 17 - only chapter wh. applies to existing Bldgs.
~~life safety~~

local official usually given discretionary power.

- only place where F.E. allowed

- pg 56 608.2 N NFPA 101

- pg 98 - 808.2 use ASTM E84
+ F.S. ratings

Pg. 24

Spur Occup. Reg.

Sec. 312-b.-

313-a- one of few places where F.R. const. REQ.

314-319

(319 = NFPA 101)

320 = NFPA 101

~~Regulating Construction to limit spread.~~

vertical openings

article 6

Pg 68

article 7-

NFPA 220

Defines Const.

R 702.7 - gives harr. req.

703.7

704.4

705.4

for incl. panths etc.

for ea. type Const.

Pg 39 Restrictions on ht. + area

height Table 401

Area Table 402

R 402.3

a-g

Note: Don't require F.R. const. but sure do encourage it. (in high cost real estate areas, very high bldgs are very desirable ∴ must be F.R.)

Sprinkler Part:

Again Don't directly require it, but strongly encourage it.

~~the place~~

Pg. 101

810.1 "Define" Comb

Few places where Sprink is Req.

a, b, c, --- f certain area + fire load

g-h Parking gar.

i - upldr.

j - limit - a lot of cities use this TP

even if not this Code.

only places where Sprink Req.

LA School Tests

al

Test # 1

Worked with Vents

→ didn't work.

Not too practical for life
safety.

810.1
l.-

cont,

65

~~pg. 126~~ though basicly performance req. code, in this
can SPEC. req. code.

909.5.

pg. 89 - sect 801 parapets

limits
for
openings
problem.

pg. 91
sect 803 - external openings (recall British
Approach)

pg. 69
702.6 limits on areas of windows
to a small extent.

703.6 repeats 702.6

pg. 38 - concerned with conflagration hazard.

Fire Limits:

all man. & business districts
closely built up with 200 ft belt
around it.

pg. 90-91

802.
Also concerned with Conflagration Hazard.
Roof Covering Materials

pg. 275 - Appendix L.

Suggests, if wood shingles are to be permitted, how it should be done.

(In some areas it is ^{politically} impossible to outlaw it)

Mimeo notes

pgs. 9+10

Comparison of other model codes.

Basic difference is in req. wh. are judgement types.

(area, height, etc.) interior finish

(areas in wh. more research is needed)

pg. 10. - interior finish req. in Southern code - good example of effect local industry can have on B.C.

67

OUTLINE FOR APPLICATION OF NATIONAL BUILDING CODE

1. Determine construction classification - Article VII (pages 68-84)
(must meet all req. to be classified certain class) (701.)
2. Determine occupancy classification - Section 300 (pages 21-23)
3. Check applicable special occupancy requirements - Sections 310-22 (pages 23-37)
4. Check restrictions if located within the fire limits - Section 400 (pages 38-39)
5. Check height and area restrictions - *for its class count* Sections 401-02 (pages 39-43)
6. Check exit facilities - Article VI (pages 53-66) or Article XVII (pages 90-91)
if existing building.
7. Check thickness of exterior walls - Section 909-14 (pages 126-139) and for
any exposed walls, also check Article VII (pages 68-84) for
wall requirements within appropriate construction classification
specifications.
8. Check parapet requirements - Section 801 (pages 89-90)
9. Check requirements for protecting exterior wall openings - Section 803 (pages 91-92)
and also Article VII (pages 68-84) for window area limitations.
10. Check roof covering requirements - Section 802 (pages 90-91)
11. Check interior finish requirements - Section 808 (pages 97-99)
12. Check requirements for enclosure of vertical openings - Section 604.2 (pages 55-57)
and applicable partition requirements in Article VII (pages 68-84)
13. Check requirements for automatic sprinkler systems and standpipes - Sections 809-10
(pages 99-104)
14. Check requirements for various utility systems - Article X (pages 157-165),
Article XI (page 168), Article XIV (page 183) and Article XV
(pages 185-86)

Reference to Other Codes.

Engineering Economic Aspects of Bldg. Const.

~~F.P.E. Decision~~

F.P.E. Decision

Technical

Economic

Life Safety

Property preservation

fire ins
rating
aspect

orig.
fixed
cost

depreciation
&
service
life

annual
maint.
cost

potential
risk to
profits
and
production
continuity

Building
code

F.P.
stds.
(advisory)

functional
reqs.

aesthetic
req.

personal
desires

↑
may be
advisable
to go beyond
code.
NFPA stds
etc. (advisory)

SUMMARY AND ANALYSIS OF 1959-61 LOS ANGELES SCHOOL FIRE TESTS

by

Professor Gerald L. Maatman, Director
Department of Fire Protection and Safety Engineering
Illinois Institute of Technology

309
Cont.

77

The tragic fire at the Our Lady of Angels School in Chicago on December 1, 1958, which took the lives of 95 pupils and teachers, produced a great amount of interest throughout the country on the subject of school fire safety. In Los Angeles, the Fire Department obtained the use of the Stevenson Junior High School which was due to be demolished and funds were obtained from the Educational Facilities Laboratories of the Ford Foundation to conduct fire tests. Other sponsoring agencies included the Los Angeles Board of Education and the California State Fire Marshal's Office. Some 61 tests were conducted between April 16th and June 30, 1959.

After the results of the first test series had been evaluated, it was decided to conduct additional tests and 101 tests were run between June 30th and July 30, 1960 at the St. Agnes High School which had been donated by the Los Angeles Catholic Archdiocese. Subsequently, 16 additional tests were conducted at the Santa Fe High School between February 6-14, 1961.

The results of these three series of fire tests have been published by the N.F.P.A. in two volumes titled "Operation School Burning."

Each test series will be separately described and evaluated and the last section of this article will then sum up and analyze the conclusions drawn by the various sponsoring agencies.

TEST SERIES NO. 1

STEVENSON JUNIOR HIGH SCHOOL, APRIL 16-JUNE 30, 1959

The building was 3 stories with part basement with brick bearing walls, part concrete and wood floors and ordinary wood joist roof. Only a 90 foot long section of the building was used for the tests. This section of the building included two open stairwells and a center corridor with classrooms on either side. Interior partitions were 6" hollow tile in corridors and metal lath and plaster on wood studs between classrooms. Doors to classrooms were of 1-3/4" wood paneled type with clear glass in wood frame transoms above.

Six thermocouples were located in the corridor on each floor level. Three were placed 8" below the ceiling and the other three five feet above floor level.

Two photoelectric cells and light sources were installed near the opposite ends of the corridor at each floor level with the light beams projected across the corridor width five feet above floor level.

Criteria for untenable smoke and temperature conditions were pre-fixed as follows:

(1) Smoke

- (a) visibility - illuminated placard with 12" letter placed 45 feet from observer and five feet above floor level. Conditions considered to be untenable when placard no longer visible.


(b) irritability - used judgment of observers in corridors.

23

(2) Temperature - established limit of 150°F. at 5 foot level in corridor.

Test fires were run with wood pallets stacked in piles with most involving 1400 lbs. of wood. Fires were ignited with two cotton and gauze torches soaked in thinner.

Purpose of Test Series No. 1 - Investigate methods of protecting multi-story open stairwell school buildings to provide a safe environment for occupants under fire conditions.



TYPICAL UPPER FLOOR PLAN
SANTA FE HIGH SCHOOL

TEST RESULTS

Series A-Tests With No Protection to Provide Basic Comparison

Using a wood pallet fire located in the east stairwell basement landing, untenable smoke conditions were produced in 2 and 3 minutes respectively in the east and west sections of the first floor corridor, in 4 and 4½ minutes in the second floor corridor and 5½ and 6½ minutes on the third floor. Untenable temperature conditions were not present until 7½, 9 and 11 minutes respectively on the three floors.

*see instant
smoke detector
wouldn't allow
300. To
evacuate
a.c. &
1 min/floor
rate of
thumb*

When the same test was repeated with various doors and windows open (to simulate summer conditions), untenable smoke conditions were reached in about the same times except in the third floor corridor which became untenable in 4 and 4½ minutes respectively. Untenable temperature conditions were developed in 5½, 7½ and 9½ minutes on the three floors.

Using a wood pallet fire located in a second floor classroom (with windows and transom open), untenable smoke was developed in 6 minutes on the third floor and 10 minutes on the second floor. Repeating this same test under summer conditions, untenable smoke was developed in 4½ and 5 minutes respectively.

Series B-Natural Draft Vent With Fusible Link Operation

Using a 21 ft.² vent, it opened after nine minutes. However, untenable smoke conditions had occurred within 4 to 5½ minutes. Increasing the vent opening to 42 ft.² decreased its opening time to 7½ minutes but still occurred at least 2½ minutes after untenable smoke conditions prevailed.

Series C-Tests With Sprinkler Protection Only

These tests were conducted for the purpose of determining the effectiveness of sprinklers installed in corridors and stairways to keep smoke and temperature below untenable levels when a fire originates in a non-sprinklered area. Four tests were conducted with three involving a stairwell fire and the fourth a classroom fire. In almost every case, untenable smoke conditions were reached in most of the corridors prior to the operation of a sprinkler head and even when a head operated prior to this time, it did not prevent the subsequent rapid build-up of untenable smoke levels. Insofar as temperature build-up was concerned, the operation of sprinklers either greatly delayed or prevented the development of untenable temperature levels except in locations close to the fire.

Series D-Tests Combining Stairwell Roof Vents and Sprinkler Protection

These tests attempted to determine the effectiveness of vents in combination with sprinkler protection to control smoke and heat build-up in corridors when a fire originates in an unsprinklered area. Four tests were conducted, two involving stairwell fires and two classroom fires, the last of which involved a test with sprinkler protection provided within the room of origin.

The two stairwell fire tests and the first classroom fire test gave results similar to those of Series B and C. Untenable smoke conditions were reached before or soon after operation of the first sprinkler head and the subsequent operation of additional heads and the roof vent did not clear the building of smoke. Once again untenable temperature levels were either greatly delayed or prevented from developing.

27

In the second classroom test fire, sprinklers operated within the classrooms after $2\frac{1}{2}$ minutes but the wooden pallets shielded the fire from the sprinkler discharge so that the fire could only be held in check. The second and third floor corridors developed untenable smoke levels within one to two minutes later.

Series E-Tests Combining Curtain Boards and Roof Vents

Ten tests were conducted combining different sizes of stairwell roof vents with draft curtains (extending down to 7 feet above floor levels) located in various combinations. In addition, automatic door closers with fusible link hold-open devices were installed on certain corridor and classroom doors in two of the tests. Again, it was found that untenable smoke conditions developed almost as rapidly as in Series A. In addition, the hold-open devices on the various doors did not operate until several minutes after untenable smoke levels had been reached. The draft curtains did, however, slow down the development of untenable temperature levels in areas remote from the fire.

Series F-Same As Series E Except With Simulated Summer Conditions

Eight tests were conducted in this series in a manner similar to Series E. The additional venting effect produced by having various classroom windows, transoms and exit doors opened reduced the smoke build-up somewhat but untenable conditions were still reached in most cases although they did not last as long. As would be expected untenable temperature levels were reached in somewhat less time than under Series E.

Series G-Tests Combining Roof Vents and Curtain Boards With Classroom Fires

Four tests were conducted, two involving classrooms on the second floor and two on the first floor. In each case, transoms between the room and corridor were open and two classroom windows were open at the bottom. In general, untenable smoke levels developed as quickly as the comparable Series A test without protection. In addition, the draft curtains around the stairwell opening interfered somewhat with the venting action of the roof vents.

Series H-Tests Combining Roof Vents and Curtain Boards With Corridor Fires

Four tests were conducted with 700 lb. pallet fires started in the first floor corridor in each case.

Once again, the roof vents did not operate effectively enough to prevent the build-up of untenable smoke levels. When curtain boards were omitted from around the stairwell openings, the vents were able to clear the smoke conditions in the corridors in about 3 to 5 minutes after they opened. However, in such cases, untenable temperature levels were reached almost at the same time as the original untenable smoke conditions.

Series I-Tests Involving Curtain Boards and Roof Vents With Forced Draft

Three tests were conducted with fires started in a stairwell. Four 60° water spray nozzles were installed above one of the stairwell roof vent openings and discharged in a manner to produce a venturi effect. Curtain boards were installed in the corridors only. The operation of the water aspirator helped clear the smoke from the corridors more quickly than otherwise but smoke exceeded untenable levels for several minutes prior to this effect and untenable temperatures were reached in the meantime.

- 5 -

79

Series J-Tests Combining Roof Vents, Curtain Boards and Sprinkler Protection

Five tests were conducted with all of the fires started in a stairwell. In four of the tests, no sprinkler protection was provided over the fire and untenable smoke conditions occurred within 3 to 4 minutes which in each case was prior to the operation of any sprinkler head or the opening of the roof vent. In the fifth test, sprinkler protection was provided in the stairwell where the fire was originated. It was unable to completely extinguish the fire due to shielding by the uppermost wood pallets but controlled it and untenable smoke conditions resulted only in the portion of the first and second floor corridors located adjacent to the stairwell. Venting was rather poor due to the relatively small temperature differences which gave an insufficient stack effect.

Series K-Tests Supplementing Series J With Aspirator for Roof Vent

Three tests were run, one in a sprinklered second floor classroom, another in an unsprinklered first floor classroom and the third in a stairwell to determine the possibility of increasing the venting effectiveness by the use of an aspirator in connection with the stairwell roof vent.

In the case of the unsprinklered first floor classroom fire, the venting action was insufficient and the first floor corridor was untenable in 4 minutes with 6 and 9 minutes respectively for the second and third floors. However, temperatures were kept within the tenable range in the first floor corridor for 13 minutes.

The fire in the second floor sprinklered classroom was shielded from sprinkler discharge by two inches of newspapers on top of the stack of wood pallets and thus the fire could only be controlled. Consequently untenable smoke conditions were produced in the second floor corridor in 2 and 5 minutes in the east and west sections and in 6 minutes within the third floor corridor.

Series L-Tests to Study Performance of Combustible Acoustical Tile

Three tests were conducted, the first with ordinary combustible acoustical tile on the ceiling of the first floor corridor and the fire ignited on the basement landing of a stairwell, the second identical except that the east half of the corridor ceiling tile had been covered with a fire retardant paint and the third identical with the second except that the fire was started in the first floor corridor at the west end.

neglected to meas smoke & gases in CLASSROOMS

In the first test, the ceiling ignited after ten minutes and flashed the full length of the first floor corridor. However, it should be noted that both untenable smoke and temperature conditions existed in the first floor corridor after 1½ minutes and untenable smoke on the second and third floors after 2½ and 4 minutes respectively.

In the second test, the small blue flames were evident around the area where the exposure fire impinged on the ceiling tile but no propagation of flame occurred down the ceiling. However, once again untenable smoke and temperature levels were reached in the corridors at times almost identical to the first test.

In the corridor fire test (500 lbs. of wood pallets), the ceiling tile ignited after 18 minutes and flashed over the half of its length which was not protected by a fire retardant coating. Here again, untenable smoke conditions existed in the first floor corridor after 10 minutes and were developed in only 8 minutes in the second floor corridor.

Series M-Tests to Study Performance of Smoke Detection Units

Six tests were conducted to measure the effectiveness of ionization type smoke detectors. All of the test fires consisted of 1400 lbs. of wood pallets and were set in the west end of the first floor corridor. Two detectors were installed in both second and third floor corridors and one was provided near the east end of the first floor corridor.

In the six tests, smoke detection time varied from 1 to 2-1/3 minutes on the first floor and 1-1/3 to 2 and 2-1/3 to 3-1/4 minutes on the second and third floors respectively.

It should be also noted here that automatic fire detectors (rate-of-rise heat detection type) were installed within the building throughout most of the tests within Series B through L and that, in general, they detected the test fires at about the same time that untenable smoke conditions developed in each case.

Conclusions of Testing Agencies

1. With the type of fires used in these tests and no fuel added due to the construction of the building, smoke was the principal life safety hazard. Untenable smoke levels preceded untenable temperature levels in nearly every test. *usually true except if you have fast burning flames*
2. Natural draft roof vents of the sizes (21'-42'-63') tested and the manner opened did not keep corridors and stairways tenable for exit use. Where fusible link devices were used, untenable smoke conditions occurred in every case before the vents opened. Even when vents were opened prior to the start of the test, untenable smoke conditions followed in some cases. Also, in those cases where better venting action was achieved from a smoke standpoint, untenable temperatures were reached much more quickly.
3. The addition of draft curtain boards did not materially cut down the rate of smoke distribution within the building and, in some cases, made the situation worse by reducing the effectiveness of the roof vents. They did, however, prove to be effective in reducing the rate of temperature build-up.
4. The forced draft induced by the use of a water aspirator was of insufficient capacity to materially increase the effectiveness of the roof vents. It would appear that extremely high water discharge rates or the use of a relatively expensive motor driven fan would have to be used to be effective. In addition, the operation of such forced draft would have to be automatic and would have to be actuated early in the fire development.
5. Partial automatic sprinkler protection did not prevent smoke spread throughout the building even when installed to provide a water curtain between the test fire and the corridors.
6. Complete automatic sprinkler protection will maintain low temperatures and will prevent the build-up of smoke and irritating gases to untenable levels if the fire is not shielded from the sprinkler discharge.
7. A combination of roof vents and partial sprinkler protection will not prevent the rapid build-up of untenable smoke levels throughout the building.
8. A combination of roof vents, curtain boards and partial sprinkler protection will not prevent the rapid build-up of untenable smoke levels throughout the building.

9. The use of fusible link actuated devices on doors, vents, etc. are not satisfactory as untenable smoke levels are built-up before the devices will operate. *Bldg. exits code agrees.*

Fail safe electro magnet door holders have been developed wh. act on smoke detect. + sprink. + F.A. etc.

10. Enclosed stairways will not provide protection against the spread of heat and smoke unless the doors are kept closed or are closed immediately after an outbreak of fire.

11. Automatic heat detection devices operated so as to detect the fire at about the same time that untenable smoke conditions were reached in the building and therefore are not satisfactory for life safety purposes in this particular type of building.

12. Automatic smoke detection devices detected the presence of fire before untenable smoke conditions were reached but not always in sufficient time to allow complete evacuation of the test building and therefore it is questionable if they would prove satisfactory under all conditions.

13. The untreated cellulose fiberboard acoustical tile, when ignited, spread flame quite rapidly down the corridor. This performance was quite radically altered when tile which had been coated with a fire retardant paint was substituted.

ANALYSIS OF TEST SERIES NO. 1

It would appear that the use of a considerable weight of wood pallets (either 700 or 1400 lbs. in the various tests) to create the test fire was somewhat unrealistic insofar as simulating a normal school fire was concerned. This large amount of concentrated fuel produced a fairly fast developing fire of considerable magnitude which I do not feel was representative from a time or severity sequence of fires in school occupancies.

In addition, no attempt was made to monitor temperature and/or smoke levels in individual classrooms during any of the tests to determine how long occupants could safely remain in those rooms awaiting evacuation by fire department ladder equipment. Also, no attempt was made to monitor toxicity, CO, CO₂, content, etc. in the corridors during any of the tests.

Very little effort was made to determine the potential effectiveness of complete automatic sprinkler protection to restrict the development of untenable smoke levels.

Not enough classroom and corridor tests were performed to form any definite conclusions as to the particular characteristics of the life safety problems involved therein.

The problem of the life safety aspects of combustible acoustical tile was given only a cursory examination and the brief data obtained would make it appear that the flame spread characteristics of the tile were not too significant because of the development of both untenable smoke and temperature levels in the corridors several minutes prior to the ignition of the tile itself.

His Comments

45

TEST SERIES NO. 2

ST. AGNES CATHOLIC HIGH SCHOOL, JUNE 30-JULY 30, 1960

The building was three stories and full basement with brick bearing walls and wood joisted floors and roof. The building had three open stairwells all emptying into a center corridor (see diagram). Interior partitions consisted of both w.l. and p. and m.l. and p. on wood studs. Classroom doors were combination wood paneled with plain glass in top half with plain glass transoms above. The building was L shaped but only the 155 foot long main section was utilized for the tests.

Six thermocouples were symmetrically located in the corridor on each floor level. Three were placed 8" below the ceiling and the other three five feet above floor level.


Light sources and photoelectric cells were installed across the entrance to each stairway at each floor level with the light beam projected five feet above the floor level.

Criteria for untenable smoke and temperature were identical with those used in Test Series No. 1.

Subsequent to Test Series No. 1, the Los Angeles Fire Department had conducted numerous unannounced fire drills at various schools. Their results indicated that it takes approximately one minute per floor to evacuate a school building. On this basis, it was assumed that it would take three minutes to evacuate the St. Agnes School after the receipt of a fire alarm.

Approximately one-half of the test fires involved wood cribs, 2'x2'x2' with an approximate weight of 75 lbs. Three different types of cribs were used, varying in construction and arrangement of igniting combustibles beneath them. These were designated as slow, medium and fast depending upon rate of temperature rise.

The remaining half of the test fires were set up to simulate typical school fires and included waste basket, baled newspaper, ditto fluid, paper supplies, arson fires, etc.



PURPOSE OF TEST SERIES NO. 2 - To investigate the potential effectiveness of various types of automatic detection devices and sprinkler systems to provide life safety protection in multi-story open stairwell school buildings when subjected to a considerable number of different types of fires. In addition, the investigation of various types of ceiling finishes to determine their potential hazard to life safety.

TEST RESULTS

Series A-Basic Automatic Detection Device Tests

A total of 14 tests were conducted, 7 in classrooms, 4 in small storage rooms or closets and 3 at the base of stairwells. In all of the 11 room fires, doors and/or transoms and in several cases room windows were at least partially open to create some favorable draft conditions. The following eight basic types of fire detection devices were evaluated in each test:

- (1) fixed temperature type heat detector - operates on the principle of heat causing an unequal expansion of the laminated parts of a bi-metal disc causing an electrical contact to close the alarm circuit.
- (2) pneumatic, rate of rise type heat detector - operates on the principle of an abnormal rate of temperature increase causing air within small diameter tubing to expand and increase pressure on a diaphragm until an electrical contact closes the alarm circuit.
- (3) thermopile, rate of rise type heat detector - operates on the principle of radiant and/or convective heat energy falling upon an exposed thermocouple junction which is connected with another shielded thermocouple junction. Their difference in temperature produces a voltage difference and a subsequent flow of current which is used to trigger an alarm circuit.
- (4) combination rate of rise and fixed temperature type heat detector - combines both features using an air chamber and diaphragm for the rate of rise effect and a fusible element (136°F.) for the fixed temperature detection. Design is intended to detect both fires which increase rapidly in temperature and also the "smouldering" type which slowly build up temperatures.
- (5) rate anticipation, fixed temperature type heat detector - varies slightly in purpose from (4) above in that it not only combines the rate of rise and fixed maximum temperature detection functions but also automatically adjusts itself to compensate for changes in rate of temperature rise.
- (6) beam type smoke detector - operates on the photoelectric cell principle. Smoke from a fire obscures the amount of light being received by the cell from a light beam source directed toward it from across a room, etc. and therefore reduces the current being delivered from the cell which can be used to actuate an alarm circuit.
- (7) refraction type smoke detector - also operates on the photoelectric cell principle. However, in this instance, the cell and light source are both located within a small chamber open to the atmosphere and the light source is not directed at the cell. When smoke from a fire enters the small chamber, it reflects the light from the source into the cell thus changing its current output.

(8) ionization type smoke detector - operates on the principle of ionized air being able to conduct an electrical current. A radioactive source is located within a small chamber which ionizes the air within it allowing a minute electrical current to flow through a circuit thus created. When smoke particles enter the chamber, they interfere with the ionization process thus reducing the current flow. This current reduction is used to actuate an alarm circuit.

In four of the test fires (two first floor classrooms, first floor storage room and basement kindergarten room), untenable smoke conditions occurred in less than 3 minutes and therefore, although some of the detection devices operated within 30 seconds, it was concluded that the building could not have been safely evacuated due to the assumed 3 minute limitation. Two of these fires simulated arson conditions with accumulations of combustibles and the use of accelerants, one involved ignition with flammable paint thinner in a laboratory and the other involved a kindergarten room with fairly substantial amounts of combustibles.

In the other ten test fires, the various automatic heat and smoke detection devices provided an alarm in sufficient time to allow safe evacuation of the building. These included 3 classroom, 1 storage room and 3 stairwell fires. In five out of these ten, untenable smoke conditions were not created in corridors within the time limit of these tests. (It is possible that they would have created untenable smoke conditions if allowed to burn long enough but at the time which they were terminated, the detection devices had already given more than sufficient notification to safely evacuate the building).

? Were there fires of the type wh. would have EVER been serious as to life hazard

Series B-Detection Device Response Time As Affected By Location, Spacing and Other Physical Factors

A total of 33 tests were conducted in order to study the effectiveness of the eight basic types of detection devices under varying locations, spacing, room volume, ceiling height, ventilation and types of fires. 18 tests were conducted in classrooms, 6 in the basement cafeteria and 9 in the first floor auditorium. The following general conclusions were obtained from the test data:

They cut test off to finish

Depends on config. of Bldg

1. The smoke detectors operated faster than the heat detectors when both were located within the room of origin but did not respond significantly faster when both types were located outside the room of origin.
2. The rate of rise and rate anticipation type detectors operated faster than the fixed temperature detector.
3. The pneumatic rate of rise type detector operated considerably faster when installed in a "U" loop as compared to a straight tubing run.
4. All types of heat detectors operated equally as well when mounted on a side wall 4" or 12" below the ceiling as when mounted on the ceiling, 6" out from the wall.
5. When mounted on side walls 5 feet above the floor, none of the heat detectors were of any value in detecting the test fires.
6. Increasing ceiling height from 11½' to 19' and 26.5' resulted in considerably slower response time for all types of detectors.
7. Under good draft conditions, the heat detectors operated equally as well as in closed rooms. The smoke detectors operated slower under draft conditions but still faster than the heat detectors.
8. Reducing the detector spacing below the maximum recommended by U.L. gave a faster response time, but the improvement was not significant from a life safety standpoint.

Series C-Performance of Automatic Sprinkler Protection

A total of 30 fire tests were conducted to evaluate the effectiveness of automatic sprinkler protection from a life safety standpoint. These included 17 tests in classrooms, 3 in storage rooms, 4 in stairwells, 4 in an auditorium and one each in a cafeteria kitchen and a corridor. 10 of the fires were set in wood cribs and the remaining consisted of various combinations of combustibles commonly found in schools.

In 27 of the tests, the fires reached sufficient magnitude to operate sprinklers and in all but one instance the sprinklers extinguished the fire before untenable smoke conditions were created. In the remaining three tests, the fires neither operated sprinklers nor were dangerous from a life safety standpoint.

In the single test where untenable smoke levels were produced, the test fire was set in a 55 gallon drum located at the base of the west stairwell. The fuel consisted of oil soaked cloth tubular filters and a sheet of metal was placed over the drum to prevent sprinklers from discharging directly on the fire. Untenable smoke conditions occurred in the west end of the second floor corridor in 5 minutes, west end of the third floor corridor in 6 minutes, center and east end of the third floor corridor in 17 minutes and in the center and east end of the second floor corridor in 24 minutes. The first sprinkler operated after 25 1/2 minutes.

In the other 26 tests where sprinklers operated, this occurred within 1 minute in 6 tests, within 3 minutes in a total of 14 tests, within 4 minutes in 18 tests, within 6 minutes in 23 tests and within 8 minutes in 25 tests. The remaining test, consisting of a waste paper basket fire in a music room storage area, gave operation of the first sprinkler in 12 1/2 minutes.

Series D-Performance of Ceiling Finish Materials

A total of 11 tests were conducted in this series, 10 involving corridor fires and one in a classroom. In both types, a "fast" 75 lb. wood crib fire was used and in each of three of the corridor tests, three "fast" wood cribs were used. All of the tests involved acoustical tile ceiling finish varying in flame spread rating (A.S.T.M. E-84) from 3 to 85. The results of the tests indicated that acoustical ceiling tile within the given range of flame spread ratings does not produce a rapid flame spread down a corridor under the specific fire exposure conditions used. In addition, the various test results appeared to generally follow the relative flame spread rating scale (see table on next page).

recall in previous tests untenable smoke was in 3-6 min.

they were under too much pressure & influence by people who donated equip. Automatic (FA) & spark.


they don't know if these fires were comparable to automatic fire detection sys. test fires.

- Should have:*
- 1. run ~~the~~ fire with no protection.*
 - 2. " same " " detection*
 - 3. " " " " sprinkler.*
- COMPARE*

over

Sprinkler has disadvantage
 that it takes longer to
 operate, but when it
 does operate it does
 something.

With (FA) it acts faster,
 but then you have to get the
 rely on people to get the
 Hell out of there.



The comparison has to be
 made on all identical
 kinds of fires slow burn to fast burn.
 Seems smoke det would be
 best on end of spectrum wh
 is slow burn - ni smoke + sprink
 best on fast burn - but careful
 testing them after line
 in spectrum

PERFORMANCE OF CEILING FINISH MATERIALS

<u>Test No.</u>	<u>Description</u>	<u>A.S.T.M. E-84 Flame Spread Rating</u>	<u>Test Fire Crib</u>	<u>Initial Flame Exposure</u>	<u>Ignition of Ceiling Finish</u>	<u>Time of Max. Flame Prop.</u>	<u>Max. Flame Prop.</u>	<u>Untenable Smoke</u>	<u>General Remarks</u>
D-1	Mineral Base Tile	3	115 lb.	2:20	None	-	0	5:00	-
D-2	Cellulose Treated Tile	51	75 lb.	2:30	None	2:30	2'	None	4' diameter charred
D-3	Cellulose Treated Tile	10	" "	2:15	None	-	1'	None	2' diameter charred
D-4	" "	85	" "	2:00	2:40	3:00	4'	5:00	7½' diameter charred
D-5	" "	49	" "	1:45	2:40	2:40	4'	5:00	8' diameter
D-6	" "	49	3 arranged in "T"	1:15	2:10	3:45	12'	?	relatively slow flame spread
* D-7	Existing Class D Tile	77	75 lb.	2:20	3:00	3:30	4'	?	flames receded and died out in room
D-8	Cellulose Treated Tile	85	75 lb.	1:45	3:00	3:30	2.5'	None	-
D-9	" "	85	3 arranged in "T"	1:00	1:50	3:10	9'	7:00	relatively slow flame spread
D-10	" "	49	75 lb.	2:00	2:30	4:00	2.5'	Less than 10 min.	relatively slow flame spread
D-11	" "	49	3 arranged in "T"	1:35	2:10	4:30	12'	?	slow flame spread

* Test conducted in classroom.

Series E-Performance of Plastic Light Diffusers and Windows

Six tests were conducted; two in a corridor, one in the auditorium and three in a classroom. The two corridor tests involved exposure of acrylic (methyl methacrylate) plastic light diffusers set in fluorescent light fixtures to a "fast" wood crib fire. One test was made using a fire retardant type and the other with an untreated type. In the former, the four diffusers dropped out in from 3 to 8 minutes with no ignition and in the latter test, the diffusers dropped out in from $3\frac{1}{2}$ to 6 minutes with brief ignition but self-extinguishment after drop-out.

The auditorium test involved exposure of a 17'x6 $\frac{1}{4}$ ' polyester fiberglass reinforced window to a fire in two "fast" wood cribs. Direct flame impingement began at 2-1/3 minutes and rapid burning of the window began 15 seconds later with the release of large quantities of black smoke.

The three classroom tests consisted of polyester fiberglass reinforced plastic window glazing (22 ft.²) exposed to "fast" wood crib fires. No ignition of the plastic was obtained in two of the tests where only a single crib fire was used. However, when two wood cribs were used in the remaining test, the plastic glazing was ignited within 2 minutes. However, it was felt that the amount of smoke produced was not objectionable.

why did they test this? Seems UL would be better.

The general conclusions which were drawn from this series were: (1) plastic materials of the type tested should be used in classrooms only with definite limitations on total area of plastic used within a given room, (2) limitations should be placed on permissible vertical dimensions of plastic materials and (3) proper separation should be required between adjacent plastic panels.

Series F-Comparative Smoke and Heat Patterns

Five tests were conducted, three with large wood pallet fires (1000 lbs.) and two with considerable accumulations of ordinary combustibles, to determine whether the build-up of smoke and heat in the St. Agnes School were comparable to that experienced in the 1959 tests in the Stevenson School. It was concluded that the pattern of smoke and heat development was indeed comparable. Four of the tests involved classroom fires and the remaining one a stairwell fire.


Series G-Evaluation of Partial Sprinkler Protection

Two tests were run to verify the performance of partial sprinkler protection which was evident during the 1959 Test Series. Both tests involved 1000 lb. wood pallet fires started in a non-sprinklered classroom with sprinkler protection provided in adjacent corridors. In both tests, untenable smoke conditions occurred within $4\frac{1}{2}$ to 6 minutes throughout the corridors with several corridor sprinklers having operated in from $4\frac{1}{2}$ to 10 minutes. However, the operation of corridor sprinklers did prevent the development of untenable temperature levels in areas remote from the fire.

TEST SERIES NO. 3

SANTA FE HIGH SCHOOL, FEBRUARY 6-11, 1961

The building was two stories with part basement with reinforced concrete walls and wood joisted floors and roof. Interior corridor partitions and ceilings were also reinforced concrete. Only the second floor corridor was used in this series of tests. Thermocouples were placed 8" below the ceiling as shown in the following diagram:



A total of 16 tests were conducted, 15 involving corridor ceiling finishes and one to investigate the performance of two types of automatic door closures. All of the tests were conducted in the second floor corridor using wood cribs of various sizes (see table on next page). It was found that the use of 330-360 lb. cribs could produce significant flame spreads on various interior finish materials which were generally grouped in accord with their "tunnel test" ratings but that it was necessary to use a 500 lb. crib in order to produce a flame spread on "standard" red oak which propagated the entire 50 foot corridor length. The only exception occurred in the case of 1/4" plywood which produced a 50 foot flame spread when exposed by a 367 lb. crib fire.

A single test was conducted with a 352 lb. crib to compare operating times of smoke and heat actuating door-closing devices and to determine if any significant improvement could be obtained in either case from the unsatisfactory performance which was experienced with fusible link (135°F.) closers in the 1959 Test Series. Devices were installed on a door located 32' down the corridor from the test fire and both the smoke and rate-of-rise heat actuated devices operated in 2 minutes while a 135°F. fusible link closer took 7-1/3 minutes to actuate.

PERFORMANCE OF CEILING FINISH MATERIALS

<u>Test No.</u>	<u>Description</u>	<u>A.S.T.M. E-84 Fl. Sprd. Rating</u>	<u>Test Fire Crib</u>	<u>Initial Fl. Expos.</u>	<u>Ignition of Ceiling Finish</u>	<u>Time of Max. Flame Propagation</u>	<u>Max. Flame Propagation</u>	<u>Remarks</u>
D-12	3/8" gypsum wallboard	10-15	242 lb.	1:30	?	?	4'	
D-13	5/8" gypsum wallboard	10-15	235 lb.	1:45	?	?	4'	
D-14	13/16" T. & g. red oak	100	249 lb.	1:00	2:30	3:30	30'	
D-15	3/8" gypsum wallboard	10-15	328 lb.	1:00	?	?	6'	
D-16	13/16" T & g. red oak	100	328 lb.	1:00	2:00	3:30	35'	flame receded and then spread back 25' at 10:00
D-17	3/4" treated cellulose tile	77	331 lb.	1:00	1:55	2:50	40'	
D-18	3/4" mineral tile	5	337 lb.	0:40	1:00	?	?	recording instruments inoperative
D-19	3/4" treated cellulose tile	92	331 lb.	1:00	1:35	3:40	37'	
D-20	5/8" treated cellulose tile	21	337 lb.	1:00	?	3:00	18'	
D-21	3/4" treated cellulose tile	87	360 lb.	1:00	?	4:00	30'	
D-22	5/8" mineral tile	8	333 lb.	1:00	?	3:10	10'	flame spread only from exposure fire
D-23	13/16" T. & G. red oak	100	*500 lb.	0:30	1:50	3:00	50' (total)	
D-24	3/4" mineral tile	15	508 lb.	0:55	1:30	2:40	25'	
D-25	3/4" pecky cedar plywood	?	367 lb.	1:00	1:30	3:10	40'	flame receded and then spread back to 45' at 13:30
D-26	1/4" Douglas Fir plywood	125-145	367 lb.	0:55	1:30	4:15	50' (total)	plywood delaminated over test fire after 5 1/2 minutes

*Crib placed on floor, all others 3 feet above floor.

ANALYSIS OF TEST SERIES NOS. 2 AND 3Heat and Smoke Detectors

The tests seemed to indicate that automatic heat or smoke detection protection (except for fixed temperature thermostats) provides a satisfactory solution to the life safety problem in multi-story open stairwell school buildings with a single exception. In certain instances, where a fire develops very rapidly and produces heavy quantities of smoke so as to produce untenable smoke conditions within the time interval necessary for safe evacuation, an almost immediate detection of the fire obviously still cannot give sufficient warning time. This occurred in four instances, two involving "set" arson type fires using trailers and accelerants, one involving a flammable liquid fire in a laboratory and the other a fire started in piled combustibles. However, it should be pointed out that in each instance, doors, windows and transoms were arranged to give good ventilation and to promote smoke distribution.

Automatic Sprinkler Protection

The tests appeared to indicate that total automatic sprinkler protection provides a completely satisfactory solution to the life safety problem in multi-story open stairwell school buildings with a singular reservation. Storage of combustible materials must be controlled to the extent necessary to prevent the existence of conditions where a fire would be shielded from sprinkler discharge.

A sufficient number of tests were made under varied conditions to give substantial support to the above stated position. However, I think that it is unfortunate that the four tests conducted in Series A, which showed automatic heat and smoke detectors to be inadequate, were not exactly repeated during the automatic sprinkler test series for comparison purposes. Four somewhat similar tests were made but these were not identical either varying in the room used, draft conditions and/or combustibles and therefore a completely valid comparison between automatic heat and smoke detection protection and automatic sprinkler protection cannot be made.

It would appear from the tests, except as noted above, that automatic sprinkler protection has one potential clear cut life safety advantage over automatic heat and smoke detection. In those types of fires which develop large quantities of smoke in their early stages and thus create untenable smoke conditions in less time than would be necessary to safely evacuate the building even assuming immediate detection of the fire, the automatic sprinkler operates a number of seconds after the heat or smoke detector but nevertheless immediately thereafter begins to control the fire and consequently reduces the smoke production and either significantly delays or prevents the build-up of untenable smoke levels.

Performance of Ceiling Finish Materials

A total of 26 tests were made, 10 in the third floor corridor of the St. Agnes High School, 15 in the second floor corridor of the Santa Fe School and one in a second floor classroom of the St. Agnes School. I do not feel that these test results were too significant from the standpoint of increasing our knowledge of the relative life hazard properties of interior finish materials. The wide variance in flame spreads which were obtained with the various sized cribs merely reflected the basic heat balance problem which existed in the particular volume of corridor and draft conditions found in the two schools used for the tests. With 75 lb. wood crib fires, the rate of heat output was insufficient to cause much flame propagation down the ceiling. When the size of the cribs was increased during subsequent tests at the Santa Fe School, the length and rate of flame spread was correspondingly increased.

It would appear that the tests showed only that if corridor ceiling finish of the types tested is subjected to a severe enough direct fire exposure, it will ignite and propagate flame down the corridor in general agreement with its relative performance and rating under the A.S.T.M. E-84 Test Method (Tunnel Test).

Some of the questions which were certainly not answered in these two test series concerned the build-up of smoke and temperature levels throughout the building prior to propagation of flame down the corridor ceiling, the subsequent increase in these two factors during and after flame propagation and the effects of significant variations in draft on this performance.

The difference in flame spread behavior obtained in these two test series as opposed to the 1959 Test Series appears to have been due to the fact that the 700 to 1400 lb. wood pallet fires used in the latter were set at the base of a stairwell and provided a situation where there was a considerable indirect pre-heating of the ceiling finish so that when ignition occurred, it resulted in a much faster flame spread down the ceiling. Therefore, we have two basic situations to evaluate: (1) indirect heating with longer ignition time but more rapid flame spread after ignition occurs and (2) direct flame impingement with shorter ignition time but somewhat slower rate of flame spread. In this country, the U.L. Tunnel Test Method (A.S.T.M. E-84) which simulates the latter situation is most widely accepted while in Great Britain and most of Europe, their test methods more closely approximate the former situation.

The important basic question of what contribution combustible interior finish materials make to the life hazard problems in a multi-story open stairwell school building under various fire conditions simply was not answered in these Test Series.

Performance of Plastic Light Diffusers and Windows

The number and arrangement of tests conducted in this series was much too meager to draw any definite guidelines with reference to the use of plastic products in school buildings. In addition, practically no definitive information was published on the smoke contribution from the samples in the tests which constitutes one of the main points of interest with plastics nor were any observations made of the toxicity of the products and their effects on the room environment which is also of paramount interest with plastics.

Performance of Heat and Smoke Actuated Door Closers

The single test which was made on these devices was encouraging enough to warrant a substantial amount of additional testing. The day to day problem of maintaining self-closing stairwell doors in the closed position in multi-story school buildings is of paramount importance and deserves considerable emphasis in any school fire research studies.

105

GENERAL CONCLUSIONS

The three series of school fire tests conducted in Los Angeles in 1959-61 represent a significant contribution to our knowledge of the life safety problems associated with school fires. However, in interpreting their test data and examining the various conclusions which were reached by the testing agencies, it would be well to keep in mind that from a scientific standpoint, it is absolutely necessary to control all of the many fire variables if it is desired to accurately reproduce fire exposure conditions in order to compare the performance of various alternative materials, devices, equipment, etc.

It would appear that such an approach was not faithfully followed in these test series. Factors such as draft conditions, fuel load and arrangement, location of test fire, igniting source, etc. were varied so often that it is difficult to find more than a few tests which can be accurately compared with one another. Therefore, the various test results produce a scattering of data which, in my opinion, should rightly be evaluated only in a general qualitative manner.

The fuel loads and types of fires used in Test Series No. 2 appeared to be generally more representative of actual conditions than in Test Series No. 1 but, especially in the case of the 30 automatic sprinkler tests, the absence of duplicate tests conducted without protection to determine the time sequence of untenable smoke and temperature development make it difficult to determine in many cases whether the sprinklers controlled fires which indeed would have ever been dangerous to life safety within a reasonable period of time.

By

Professor Gerald L. Maatman, Director
Department of Fire Protection and Safety Engineering
Illinois Institute of Technology

INTRODUCTION

Since almost the beginning of time, society has been concerned with the problem of safety in building construction. Archeologists have unearthed relics which indicate that as far back as 2100 B.C., laws existed in Babylon which provided that "in the case of collapse of a defective building, the architect is to be put to death if the owner is killed by the accident; and the architect's son if the son of the owner is killed." During the Roman era, it became necessary to pass laws restricting the heights of buildings to 70 feet because of the frequency of collapse of taller buildings.

Later in history, numerous regulations began to appear which were concerned with preventing and restricting fire spread. The City of London as far back as the 14th Century required that chimneys be built of stone, tile or plaster. It was not uncommon in the larger closely built-up towns of the early American colonies to require that roof coverings be of slate or tile.

From these meager beginnings, slowly evolved groups of regulations which we know today as building codes. Most of the early building codes were written on a so-called "specification" basis. That is, they spelled out in considerable detail what specific materials could be used to construct buildings. This regulatory method provided no particular problems at that time because the architect had only a limited choice of materials to choose from in any case.

However, in the past two or three decades, the building materials industry has undergone a rapid technological change and, as a result, it has become necessary to rewrite codes on a "performance" or functional basis, wherein the code spells out only the desired functional end requirement and leaves the architect free to choose from a variety of materials.

BASIC PURPOSE OF A BUILDING CODE

Stripped of its legal and technical phraseology, a building code is simply a set of laws intended to keep people from getting hurt. A man may be physically hurt from being struck by a collapsing structure, by falling through unguarded openings, by being burned, through sickness resulting from improper sanitation, or from any number of other causes. The same occurrences may cause him financial loss, whether he be owner, occupant or merely a passerby.

Not only does a building code concern itself with individuals, but, in addition, it must of necessity be concerned with the welfare of the community in general. The basic objectives of a code can be divided into three broad classifications:

- X (1) structural integrity
- X (2) health and sanitation
- X (3) fire protection

109

① Structural integrity is dealt with by specifying various engineering design criteria which must be adhered to by the building designer to insure that the structure will carry its intended dead, live and wind loads with a liberal safety factor.

② Health and sanitation regulations cover the factors of plumbing, sewage, ventilation and light as they bear on the problem of providing a healthy atmosphere for the building's human occupants.

③ However, it is in the ^{90%} field of fire protection where the building code probably is most concerned with the welfare of the community as a whole. Mr. B. L. Wood in his book, "Fire Protection Through Modern Building Codes" states that, insofar as fire protection is concerned, a code has the following four objectives in order of importance:

- * (1) To provide for the safety of occupants of buildings and to make provision for their exit without loss of life during a fire.
- * (2) To provide for the safety of firemen fighting fire.
- * (3) To provide for the safety of adjoining property and to prevent the spread of fire.
- * (4) To provide for the preservation of the property itself.

In writing a building code to achieve its three basic purposes, it must be kept clearly in mind that the governmental agency, be it a municipality, township, county or state, has authority under its general police powers only to regulate to the extent necessary to achieve minimum reasonable safety for the public. In addition, under our democratic form of government and relatively free economic system, it would be against the public good to unduly restrict the construction of buildings through the use of excessive regulations. Thus, the basic difficulty, especially in the rather intangible area of fire protection, is to determine what regulations will provide minimum reasonable safety without being unduly restrictive.

Building code regulations pertaining to fire protection are still, to a large extent, based upon past fire experience and the judgment of mature fire protection engineers. For this reason and because of the great increases in new building materials and methods, which do not always lend themselves to analysis by past experience alone, there has developed a strong need for a more sophisticated scientific analysis of fire protection factors. However, until the last decade or two, there has been little emphasis placed on this area of study by the scientific community and therefore, for the present at least, modernization of building codes from a fire protection standpoint must continue to be made largely based on experience and judgment.

Mr. Wood, in his previously mentioned book, discusses the basic problem of defining "minimum reasonable safety" as it applies to fire protection needs and presents a case in favor of eliminating the element of "safety factor" from fire protection determinations. Although it is customary for building codes to include a safety factor in all of its structural design criteria, Mr. Wood argues that the same analogy cannot be applied to fire protection requirements because, while a building must constantly sustain its designed load and frequently be subjected to overloads, the chance of a fire occurring in a particular building is about one in 1,000 years. One might compare this argument with the endless controversy over whether the capacity of a municipal storm sewer system should be designed to carry off a rainfall which occurs once each twenty years, fifty years, 100 years, etc. Within the last four years, for example, the Greater Chicago Area has endured two of the so-called fifty year rainfalls. Therefore, although the frequency of fire occurring in any one

111

particular building is admittedly remote, no one can fortell which buildings will suffer fires and it cannot be denied that a tremendously large number of building fires occur each year. It follows then that the degree to which codes regulate fire protection factors must, in the end, be a compromise between judgment and the capacity of the public to bear the cost of such protection.

ANALYSIS OF BASIC FIRE PROTECTION OBJECTIVES

The various structural factors which have a bearing on the development and spread of a building fire are well known from past experience and a brief list of these factors and how they are inter-related to the four basic fire protection objectives previously enumerated follows:

1. Safety to Building Occupants

- a. adequate and reliable exit facilities.
- b. protection of all vertical openings.
- c. limitation of use of combustibile interior finish.
- d. limitation of basic construction type to some extent.
- e. limitation of allowable height and area of buildings to some extent.
- f. segregation of hazardous portions of an occupancy.

2. Safety to Firemen Fighting Fire

- a. protection of stairwells and other vertical openings so as to provide interior access for fire fighting purposes.
- b. limitation of allowable height and area of buildings.
- c. minimum requirements for masonry wall thickness.
- d. fire resistance requirements for structural elements.
- e. requirements for automatic sprinkler systems and other protective equipment.

3. Safety of Adjoining Property

- a. limitation of allowable heights and areas of buildings.
- b. limitation of allowable roof coverings.
- c. protection of exterior wall openings and/or building separation requirements.
- d. parapet requirements.
- e. restrictions on construction within the "fire limits."
- f. requirements for automatic sprinkler systems and other protective equipment.
- g. fire resistance requirements for exterior walls and various load bearing members.

4. Preservation of Property Itself

- a. limitation of allowable heights and areas.
- b. protection of vertical openings.
- c. requirements for vertical separation between openings in exterior walls.
- d. fire resistance requirements for structural elements.
- e. minimum requirements for masonry wall thickness.
- f. segregation of hazardous portions of an occupancy.
- g. requirements for automatic sprinkler systems and other protective equipment.
- h. requirements dealing with chimneys, flues, vents, heat producing appliances, heating, ventilating and air conditioning systems, gas piping and electrical power and lighting systems.

ACHIEVING - FIRE PROTECTION OBJECTIVES IN BUILDING CODES

The intelligent promulgation of building code requirements to achieve the four basic fire protection objectives by regulating the numerous factors outlined above is a complex problem and one upon which there has never been an unanimity of opinion. There are still many examples of widely varying requirements between building codes in use in various cities. In many cases, this is due to honest differences of opinion or to erroneous ideas on what factors have a bearing on the fire problem. However, unfortunately, some of these divergences are due to improper pressure having been brought to bear upon code writing authorities by special interest groups in the building materials industry who seek to obtain an unfair advantage over their competitors.

At the present time in the United States, approximately 80% of the existing building codes are based entirely, or in part, on one or more of four regionally or nationally recognized model codes. These are:

- ✓ 1. National Building Code of the National Board of Fire Underwriters
- ✓ 2. Basic Building Code of the Building Officials Conference of America
- ✓ 3. Uniform Building Code of the International Conference of Building Officials
- ✓ 4. Southern Standard Building Code of the Southern Building Code Congress

Although these codes differ in some important respects, their increased acceptance has produced an overall beneficial effect in the promotion of safe building construction in this country.

The various specific standards of the National Building Code will be reviewed in some detail as this is the only model code which is promulgated exclusively by fire protection engineering interests and the three remaining codes will then be compared with the N.B.F.U. code where they differ in important aspects.

NATIONAL BUILDING CODE

CLASSIFICATION OF CONSTRUCTION

- There are seven basic types of construction recognized by the code and these are defined in detail on a performance basis. The construction elements considered are (1) columns and piers, (2) floors (3) roofs (4) beams, girders and trusses, (5) walls, (6) partitions, (7) ceilings and (8) firestopping. A.S.T.M. E-84 fire resistance test standard (N.F.P.A. No. 251) is used as a measure of performance.

- 1. Type A - Fire Resistive (3 hour construction)
- 2. Type B - Fire Resistive (2 " ")
- 3. Protected Non-Combustible (1 " ")
- 4. Unprotected Non-Combustible
- 5. Heavy Timber (Mill or slow-burning construction)
- 6. Ordinary (masonry-wood joist construction)
- 7. Wood Frame

The code for the most part does not directly require that a particular building be built to meet the standards of any particular class of construction but strongly encourages the use of fire resistive buildings by limiting the allowable heights and areas of non-fire resistive structures. However, in a few cases, the code does directly restrict construction type for certain occupancies. For instance, institutional buildings such as hospitals, asylums, jails, infirmaries, etc. must be of fire resistive construction. In addition, theaters must be fire resistive except

if not over one story or 45 feet in height in which case the roof may be only of one hour fire resistance. Also, schools over two stories in height must be of at least protected non-combustible construction. Another notable exception to the general rule involves the prohibiting of wood frame or unprotected non-combustible construction from within the fire limits of the city. This will be discussed in greater detail in the next section.

RESTRICTIONS WITHIN THE FIRE LIMITS - Except for a few minor exceptions, the code prohibits the erection of or moving of wood-frame or unprotected non-combustible buildings or additions into or within the city's fire limits. In addition, the code regulates the permissible areas and heights of all except Type A fire resistive buildings erected within the fire limits. The boundaries of the fire limits are normally specified in a separate ordinance, usually the Zoning Code, and are intended to cover all areas within the city which are or could be subject to a concentrated build-up of mercantile buildings plus a belt of exposing area around such mercantile concentrations. The object of these regulations is, of course, to minimize the fire conflagration potential of the city's closely built-up mercantile areas.

LIMITATIONS OF ALLOWABLE HEIGHTS AND AREAS - The code limits the permissible heights of all buildings except Type A-fire resistive and residential or business occupancies in Type B-fire resistive. The height limitations are graduated from 35 feet for wood frame and unprotected construction to 85 feet for Type B-fire resistive (except as noted above.) In addition, there are several specific height limitations for high hazard and certain institutional occupancies when located in non-fire resistive buildings. Thus, the code recognizes the inherent problems involved in meeting all of the four basic fire protection objectives in the case of multi-story non-fire resistive buildings.

The code limits the permissible ground floor areas of all buildings except Types A and B fire resistive. The area limitations are broken down into two groups, one story buildings and multi-story buildings, with the limitations being more restrictive for the latter group. The maximum permissible areas are graduated from 6,000 ft.² for a one story wood frame building (4,000 ft.² for multi-story) to 18,000 ft.² for one story protected noncombustible construction (12,000 ft.² for multi-story.) The basic reasons for limiting building areas are, of course, to reduce the conflagration potential, to restrict the maximum amount subject to any one fire, and more important, to avoid an impossible fire fighting problem due to the practical limitations on the reach of fire department hose streams. In accord with this same reasoning, the code permits a 200% area increase when any building is sprinklered, increases varying from 20% to 50% when a building is located outside of the fire limits and structural load bearing members have a specified fire resistance, and increases ranging up to 100% for buildings which have one-fourth or more of their perimeter fronting on a public street or public way at least 21 feet in width. This latter factor, of course, governs to a great extent the number, arrangement and effectiveness of fire department hose stream operations.

Conversely, the code requires in certain cases where the combustible fire load of an occupancy is quite high, that buildings exceeding specified height and area limitations must be provided with an automatic sprinkler system. This requirement will be discussed in greater detail in another section.

EXIT REQUIREMENTS - The code regulates exit standards in a manner which closely follows the provisions of the N.F.P.A. Building Exits Code (N.F.P.A. No. 101) and to some extent the recommendations of the National Bureau of Standards (Report No. M-151 "Design and Construction of Building Exits.") The more important basic provisions include adequate exit capacity and arrangement, enclosure of stairwells and free and unobstructed access. The various structural factors having a bearing on life safety

u7

such as enclosure of other vertical openings and the regulation of interior finish are covered in separate sections of the code.

The code also makes an important necessary distinction regarding safety to life requirements as between "existing" buildings and buildings built after the code is enacted into law. In general, provisions of a new building code cannot be made retroactive to apply to buildings already in existence. However, in the area of life safety, legal authorities have consistently held that retroactive laws may be enforced which are necessary to maintain minimum standards of life safety. Therefore, the code contains a separate section applicable only to existing buildings which regulates to some extent exit facilities, interior finish, protection of vertical openings, chimneys and vents and heat producing appliances.

PARAPETS - The code requires parapets on all fire walls and exterior walls required to have 2 hours or more fire resistance except (1) in the case of a fire resistive roof, (2) when roof of adjacent building or any opening in adjacent wall is at least 3 feet higher, (3) when building is at least 30 feet distance from nearest line to which other buildings can be or are built and (4) when the roof has a 20 degree or more slope with the horizontal. Parapets are required to have the same fire resistance as the wall and must be at least 24 inches high on a 2 hour wall and 36" high on walls required to have greater fire resistance.

ROOF COVERINGS - The code uses the roof covering classification system set forth in N.F.P.A. Standard No. 203 which is based upon a fire test method developed by Underwriters Laboratories (U.L. Standard No. 790.) This method provides for three types of approved roof coverings:

- Class A - effective against severe fire exposure and possess no flying brand
- Class B - " " moderate " " " " " " " " hazard
- Class C - " " mild " " " " " " " "

The code requires either Class A or B roof coverings to be provided on all buildings except (1) dwellings, (2) wood frame buildings and (3) all buildings located outside of the fire limits whose height and area do not exceed the code limitations for wood frame buildings. These latter three classes are permitted to have Class C roof coverings.

The code does not permit wood shingle roof coverings as this type can not pass the Class C fire test. However, in recognition of the fact that some code enforcing agencies nevertheless want to permit such types of roof coverings, the appendix of the code suggests that if this is desired, the use of such shingles should be restricted to a good grade (U.S. Dept. of Commerce Std. CS 31-52) and should be applied in a manner to provide maximum thickness, close spacing and firm anchorage. In addition, the code recommends that such roof coverings be permitted only on dwellings, private garages and barns separated at least 12 feet from other buildings and only when located outside of the fire limits.

PROTECTION OF EXTERIOR WALL OPENINGS - The code requires that all exterior wall openings be protected by either wired glass, fire doors or fire shutters when the wall in question lies within 30 feet of (1) an adjacent wood frame building, (2) an adjacent lower combustible roof, (3) an opening in an adjacent wall. Also, protection is required when the wall lies within 15 feet of an adjacent lot line or when the wall opening lies within 10 feet of an exterior fire escape stair. The only exceptions to these requirements are openings in exterior walls of (1) dwellings, (2) churches, (3) wood frame or unprotected noncombustible buildings, and (4) open air parking garages. The code also specifies certain fire resistance requirements for all exterior bearing walls (except for unprotected non-combustible and wood frame buildings.) In addition, where an exterior building wall is exposed within 30 feet, non-bearing portions also must have a specified fire resistance and the total window area in the wall is limited to 60% of the total wall area (40% of total area if exposure distance is less than 20 feet.)

119

VERTICAL SEPARATION BETWEEN OPENINGS IN EXTERIOR WALLS - The code requires that there shall be not less than three feet separation between vertically adjacent exterior wall openings provided by a non-combustible material having a fire resistance of at least two hours, or in lieu thereof, the vertical openings shall be separated by a similar assembly extending horizontally outward from the wall at least three feet. The only exceptions to this requirement intended to prevent vertical spread of fire are: (1) ordinary construction located outside of the fire limits, (2) unprotected non-combustible and wood frame construction, (3) when the lower of any two successive wall openings opens into an occupancy of light fire load, i.e. business, educational, residential, etc. and (4) when the exterior openings are protected by wired glass or fire doors.

INTERIOR FINISH - The code classifies interior finish materials on the basis of A.S.T.M. Standard E-84 (N.F.P.A. No. 255-Tunnel Test) as to their flame spread hazard. Interior finish may not have a flame spread greater than 75 in (1) exit stairwells and exit hallways (2) portions of buildings greater than 75 feet in height (except in rooms of 1500 ft.² or less), and (3) in all portions of institutional occupancies. If in any of the above cases, the building is sprinklered, the requirement is reduced to a 200 flame spread. In all other cases except dwellings, the flame spread limitation is 200 (one other exception is allowable 500 flame spread in rooms of 1500 ft.² or less in business, high hazard, industrial and storage occupancies.)

The flame spread limitations also apply to the back face of interior finish materials used in exitways located more than 75 feet above grade, in all rooms or spaces of institutional occupancies and assembly occupancies, or theaters more than 45 feet in height.

MASONRY WALL THICKNESS REQUIREMENTS - The code specifies certain minimum thickness for masonry walls of various types. This represents somewhat of a departure from a performance to a specification type basis. However, the N.B.F.U. justifies this action on the grounds that the standard fire resistance test (ASTM E-119) which is conducted on a 100 ft.² wall sample is not of sufficient magnitude to reproduce the actual stress and expansion effects which occur in larger building walls during a fire. In general, the code requires a minimum of 12" thickness for masonry bearing walls (6" for reinforced concrete) except that 8" is permissible for dwellings and a minimum of 8" thickness for non-bearing exterior masonry walls. Buildings greater than 35 feet in height of course require correspondingly thicker bearing walls (4" for each 35 feet in a downward direction.)

Where walls are utilized to separate portions of a building to conform with the code's area limitations (i.e. fire walls), they must (1) be independently supported so as to allow collapse of construction on either side, (2) have a fire resistance of at least 4 hours, (3) extend through the roof and at least 36" above except for fire resistive roofs, and (4) in the case of hollow masonry walls must be of at least 16" thickness and with reinforced concrete walls, must be at least 9" thick. Openings in fire walls are restricted to 120 ft.² area (with maximum 12' dimension) and the aggregate width of all such openings shall not exceed 25% of the length of the wall. Also, all such openings must be protected on both sides of the wall by approved Class A fire doors.

PROTECTION OF VERTICAL OPENINGS - In general, the code requires that interior stairways, elevator shafts and all other vertical openings be protected. In buildings less than 4 stories in height, the enclosure must be of at least one hour fire resistance and in taller buildings, the requirement is for a fire resistance of at least two hours. In the latter case, only non-combustible materials can be used to construct the enclosure, while with buildings less than four stories high, this requirement applies only to the fire resistive and non-combustible classifications. All openings into stairway enclosures must be protected by approved Class B fire doors except that where one hour

fire resistance is required, solid flush type wooden doors of 1-3/4" minimum thickness can be used.

The only exceptions to the general requirement for enclosing all interior stairwells are the following:

- (1) where a stairway serves only two floors, is not part of the required exit facilities and is cut-off at one of the two floor levels by a one hour partition.
- (2) where stairway serves three floors, is not part of the required exit facilities and is cut-off at both the upper and lower floors by a one hour partition.
- (3) stairs leading from a mezzanine or balcony to a floor below where the mezzanine or balcony area doesn't exceed 1/3 of the area of the floor below.

AUTOMATIC SPRINKLER SYSTEMS AND STANDPIPES - The code strongly encourages the use of automatic sprinkler systems by allowing greatly increased permissible areas, more combustible interior finish, wider spacing of exits, etc. when a building is so protected. However, in general, the code recognizes that automatic sprinkler protection goes beyond what could be defined as reasonable minimum safety and therefore does not require sprinkler protection. The only exception to this position is taken in the case of occupancies which manufacture, sell or store large amounts of combustible goods or merchandise. Because of the high combustible fire load involved in such instances, the code requires that when such buildings exceed certain combinations of, heights and areas, both the fire fighting and fire conflagration problems become acute and it is then necessary to provide more positive fire protection. Some of the more important height and area limitations are:

fire resistive - 2 stories and 10,000 ft.²
protected non-combustible - 2 stories and 8,000 ft.²
other construction types - 2 stories and 6,000 ft.²

In addition, sprinkler protection is required in certain cases when the building heights exceed specified limits, irregardless of area, and the building is used for the storage of large amounts of combustible materials.

Also, sprinkler protection is required for parking or repair garages and storage basements of mercantile buildings when certain area and/or height limits are exceeded. The latter requirement arises from the extremely difficult fire fighting problem involved in gaining interior access to basements of mercantile buildings.

The code requires standpipes to be installed only in buildings that are required to be sprinklered under the code (with the exception of open air parking garages.)

SEGREGATION OF HAZARDOUS OCCUPANCIES - The code in certain instances requires that hazardous portions of an occupancy be cut-off by fire resistive partitions, floors, etc. from remaining portions of the occupancy or one adjacent thereto. For instance, bowling alley areas must be separated from other portions of a building by a one hour cut-off. Parking and/or repair garage operations must be cut-off as must mercantile areas from adjoining residential occupancies in the same building. These requirements are principally aimed at reducing the life hazard factor and, to some extent, at reducing possible areas subject to any one fire.

HEATING, VENTILATING, AIR CONDITIONING, ELECTRICAL, ETC. - In the various areas of utilities systems and equipment, the code suggests that other applicable nationally recognized standards be adopted. For instance, the National Electrical Code, the N.B.F.U. Standard on Heat Producing Appliances, Heating, Ventilating, Air Conditioning, Blower and Exhaust Systems, etc.

COMPARISON WITH OTHER THREE NATIONALLY RECOGNIZED CODES

BASIC BUILDING CODE - B.O.C.A. (1955 Edition)

Heights and Areas - Allows greater heights for Type B fire resistive and protected non-combustible buildings in some instances. Also, allows larger areas in both the single and multi-story classifications for the relatively poorer types of construction.

Protection of Exterior Wall Openings - Requires protection only for 4 story or higher buildings.

Fire Walls - Requires only 1½ hour fire door to be installed on each side of wall opening. Also, fire wall requirements are on a performance basis, and in some cases, only 3 or 2 hours fire resistance is required. In addition, requirements for separate ground supports for fire walls are less rigid.

Restrictions Within the Fire Limits - Doesn't restrict the use of unprotected non-combustible construction within the fire limits.

Parapets - Requires only a maximum of 24" parapet height.

Automatic Sprinkler Systems - Require sprinkler protection in certain instances only for 4 story or higher buildings containing a high fire load.

Interior Finish - Uses both A.S.T.M. E-84 (tunnel test) and Federal Specifications Test SS-A-118b to evaluate flame spread hazard. The applicant has the option in this matter.

UNIFORM BUILDING CODE - I.C.B.O. (1955 EDITION)

Heights and Areas - Allows somewhat greater heights for the 3 poorest classes of construction and permits unlimited heights for all Type B fire resistive buildings. Allows somewhat greater areas for all types of construction and for almost all types of occupancies.

Protection of Exterior Wall Openings - Allows closer exposures outside of the fire limits and is generally less restrictive in requiring protection for various types of exposure situation.

Fire Walls - Requirements expressed on performance basis and only two hours fire resistance specified in some cases. In addition, only single 1½ hour fire doors required to protect openings in fire wall which separates unprotected non-combustible or wood frame construction.

Parapets - Requires only 12" height and no parapets are required (1) when roof is non-combustible, (2) when the building is 20 feet or less in height or (3) on fire walls.

Automatic Sprinkler Systems - Doesn't require sprinkler protection for repair or parking garages nor mercantile occupancies over 2 stories in height (unless of very large area.)

Interior Finish - Uses both A.S.T.M. E-84 and Federal Specifications Test SS-A-118b as basis for flame spread hazard.

SOUTHERN STANDARD BUILDING CODE - S.S.B.C.C. (1954 EDITION)

Heights and Areas - Allows greater areas for all one story buildings and also multi-story buildings of heavy timber or poorer types of construction.

Protection of Exterior Wall Openings - Requires protection for buildings less than 3 stories in height only when 8 feet or less from property line.

Fire Walls - Requirements expressed only on performance basis with 4 hours fire resistance specified.

Restrictions Within the Fire Limits - Allows somewhat more liberal use of unprotected non-combustible construction within the fire limits.

Automatic Sprinkler Systems - Allows much larger areas of high occupancy fire load in various construction classes before requiring the provision of an automatic sprinkler system.

Interior Finish - Allows any interior finish material which "will not have a rate of flame spread in excess of that of wood or fiberboard when exposed to heat or flame." The only restriction on the above is that in fire resistive buildings over three stories in height, all fiberboard finish must be installed over a non-combustible base.

FUTURE TRENDS IN BUILDING CODES

It is apparent from analyzing the four nationally recognized building codes that there exists some considerable differences of opinion as to what constitutes reasonable minimum safety requirements. Furthermore, this divergence of opinion is quite naturally more pronounced in those areas in which judgment plays a large part in deriving code standards. Therefore, it follows that any substantial future improvement in writing realistic but adequate building code requirements will necessarily have to be preceded by greatly expanded fundamental research within the area of fire development and behavior within buildings.

The recent work done by the British Joint Fire Research Committee in the area of building separation and ignition by radiation which was supplemented by radiation ignition studies made by Canadian authorities during the "St. Lawrence Seaway Burnout Test Series" offers excellent future promise in developing scientifically realistic standards for protection of exterior wall openings and building separation criteria.

Studies made by the National Bureau of Standards in the early 1940's, which have since been greatly expanded and refined by the British Joint Fire Research Committees' work, in the area of correlating standard fire resistance test ratings (A.S.T.M. E-119) with fire severity as measured by combustible fire loads (i.e. lbs. combustibles/ft.² floor area or B.T.U./ft.² floor area), also offers great promise for a more rational approach to fire resistance code requirements. However, there remains much work to be accomplished before this method can be used in other than the crude indirect fashion presently recognized by the various model codes.

In his publication, "Fire Protection through Modern Building Codes," B. L. Wood advanced the suggestion that building area code limitations be developed by a somewhat complicated scaling method whereby the maximum permissible area of any particular building is dependent upon (1) its occupancy insofar as it reflects on contents fire loading and life hazard and (2) its construction as it reflects on the additional contributed fire load and on the degree of fire resistance offered. By comparing each basic type of occupancy and construction (as used in the model code classification system) on each of these counts from data available in the National Bureau of Standards fire loading study and exit standards of the N.F.P.A., he developed a series of relative scaling factors for each class of occupancy using a value of unity for wood frame construction. Thus, once a determination is made of the actual maximum permissible area which can be allowed for wood frame construction within each occupancy classification (this would have to be set by the code writing body,) the remaining permissible areas fall into place and the end result is an area table which he claims reflects equivalent fire risks for each case. For instance, the maximum allowable area for a Type A fire resistive building with an institutional occupancy would present the same total fire risk as the maximum allowable area specified for a wood frame building with a business occupancy. As previously noted, he defines the total fire risk as representing the sum of the conflagration risk plus the life hazard risk.

Other areas in which it appears that fruitful research could be undertaken include (1) realistic study of life hazard factors, (2) comprehensive study of conflagration factors and (3) correlation study between the behavior of walls in standard fire tests and in actual building fires.

The recent series of tests conducted on three school buildings in Los Angeles brought out quite forcefully the fact that the present test methods used for evaluating the life hazard characteristics of interior finish materials (i.e. tunnel test, radiant panel test, etc. ...) do not directly provide meaningful quantitative information on their hazard to human occupancy. This is especially true with regard to the development of smoke and toxic gases. In addition, there is some doubt as to whether any of these test methods even places materials in their correct relative hazard position in all cases. There is a definite need to first quantitatively determine the various factors bearing on the life safety problem and then to develop a correlation between these factors and existing test methods or to develop more meaningful tests for interior finish materials.

The present method utilized in codes to retain the potential conflagration hazard within reasonable limits is to prohibit combustible buildings and roof coverings from within the fire limits and to regulate heights, areas and exposed wall openings with regard to all other buildings erected within the congested mercantile districts. This approach, which is based on past experience, directly attacks some of the more important factors bearing on this problem, but again, it represents at its best only a crude attempt to measure and control this problem. An entirely new approach is vitally needed if building codes are to eventually reach a true realistic status.

Both the British and Japanese governments are presently supporting basic research intended to develop the use of small scale model buildings to study the behavior of fire development and mass fires. The initial problem, of course, consists of developing proper "scaling factors" which can take results obtained in model fires and provide meaningful information as to the probable behavior of fires in full scale buildings. If these studies can be carried to a successful conclusion, it will then be possible to apply a mathematical analysis to conflagration hazard on both a block and area basis which can be translated into rational code requirements.

The present shortcoming of specifying minimum thicknesses for masonry exterior and fire walls, irregardless of standard fire resistance test ratings, should be eliminated and a performance approach used. This will necessitate further study into the various structural stress and stability factors present in different sizes and types of walls subjected to actual building fires and the development of a meaningful correlation between these factors and the standard wall fire resistance test. The results will likely result in a revision of the present test method insofar as the application of structural load and test observations are concerned. The end result will be a test which develops a fire resistance rating which is meaningful from a structural stability standpoint.

As new building materials and methods continue to be developed and the rejuvenation and expansion of our cities reaches its full impetus in the next decade or two, the need for a realistic analytical approach to the problem of achieving adequate but not excessive fire protection in building construction will provide one of the great challenges to our profession.

National Board of Fire Underwriters

(A National Organization of Capital Stock Fire Insurance Companies Established in 1866)

COMMITTEE ON FIRE PREVENTION AND ENGINEERING STANDARDS

LEWIS A. VINCENT,
General Manager

85 John Street, New York 38, N. Y.

JOHN A. NEALE,
Chief Engineer

Revised January 23, 1956

Special Interest Bulletin No. 167

BUILDING CODES—THE NATIONAL BUILDING CODE OF THE NBFU

Communities looking for a good way to modernize their building codes will do well to consider the National Building Code, recommended by the National Board of Fire Underwriters.

The National Building Code is well suited for adoption by reference, and a suggested ordinance for use in adopting the Code by reference is published as Appendix P. Many cities have so adopted it. For communities which feel that their needs can be cared for by a briefer code, the National Board of Fire Underwriters has published an abbreviated edition of the Code.

In its efforts to influence and encourage the introduction of improved and safe methods of building construction, the National Board of Fire Underwriters has published a recommended building code continuously since 1905 when the first edition appeared. The 1955 Code is the seventh major revision, and in commemoration of 50 years since the publication of the country's first model building code by the National Board of Fire Underwriters, it is called the 1955 Golden Anniversary Edition.

The Code has been prepared with the definite objective of meeting the public interest, providing safety to life as well as property, and giving due regard to provisions affecting health and sanitation. The fire insurance companies carry on this activity because that which serves the public interest in these matters also serves their interest.

The Code is a performance code and insofar as practicable, within the limits of public safety, allows the use of any material, type of assembly, method of construction, or style of architecture that meets the required standards of strength, stability and fire resistance.

The Code has been drafted by engineers of the National Board of Fire Underwriters with help and assistance from many sources. Approved American Standards and nationally recognized standards of trade associations have been widely used in the Code.

Safety to life from fire of the kind which a building code should provide, requires more than ample exit capacity. It requires exit ways that will be safe to use under fire conditions, and restrictions on the spread of fire such as limitation of areas, proper enclosure of stairs and elevators, fire walls (and in some cases exterior walls) having stability under fire conditions as well as fire resistance, restrictions on flame spread rating of materials used as interior finish, protection of window openings against fire exposure, and installation of automatic sprinkler systems in certain situations including large area buildings of readily combustible construction or occupancy.

Lack of one or more of the above features has frequently been an important factor in the injury or death

of persons from fires in buildings. The requirements of the National Building Code take into account the accumulation of years of study of these factors by men familiar with the phenomena of fires and their spread in buildings.

The National Building Code contains the latest nationally recognized working stresses for steel and lumber, and permits the use of glued laminated lumber provided its use is in accordance with nationally recognized good practice. It recognizes the place of plastics in building construction and covers their use. It recognizes the use of newly developed thin panel wall sections and permits them under certain conditions.

Buildings of unlimited area are covered by stipulating the conditions under which such buildings are permitted.

High hazard occupancies are covered by requiring compliance with nationally recognized good practice where such exists and giving certain requirements for other high hazard occupancies.

Installation of heating appliances, incinerators, and air duct systems, are covered in the Code by a brief section which cites the "Code for the Installation of Heat Producing Appliances, Heating, Ventilating, Air Conditioning, Blower and Exhaust Systems" recommended by the National Board of Fire Underwriters. This is published in one of the appendixes and is also available in separate pamphlet form.

The Code contains 16 appendixes which give supplementary information. In addition, information on the fire-resistance ratings of walls and partitions, column, beam, girder and truss protections, and floor and roof constructions is given at the end of the Code.

One appendix gives supplementary code provisions for resistance to severe wind conditions. Other appendixes give special provisions covering resistance to earthquakes and protection against termites.

This Code should be a valuable reference book for every building official, architect, structural engineer, and fire chief as well as many others. Any person concerned with building construction may obtain a copy without charge.

Any community considering adoption of the National Building Code, or the Abbreviated Edition thereof, will be furnished on request without charge a sufficient number of copies for study, and on the adoption of either edition will be furnished with up to 50 additional free copies of the edition that is adopted, and as many additional copies as may be desired for a nominal charge that partially covers cost of publication.

Any city or town which adopts either code will, on request, be furnished 1 to 3 sets of the Standards of the National Board of Fire Underwriters and the appropriate official of such town or city will be placed on a mailing list to receive future issues of the standards.

National Board of Fire Underwriters

(A National Organization of Capital Stock Fire Insurance Companies Established in 1866)

COMMITTEE ON FIRE PREVENTION AND ENGINEERING STANDARDS

LEWIS A. VINCENT,
General Manager

85 John Street, New York 38, N. Y.

JOHN A. NEALE,
Chief Engineer

January 23, 1956

Special Interest Bulletin No. 11*

BUILDING OFFICIALS, IMPORTANCE OF—ALSO, SUGGESTED ORDER FOR CHECKING PLANS AGAINST BUILDING CODE

The building official's job in any political subdivision is very important and yet, unfortunately, its importance is too often overlooked by local governing bodies and the citizenry.

We are all aware of the important part played by the firemen and policemen in safeguarding our lives and property from fire and theft because we see and hear about their work daily. Yet we either take for granted or are unaware of the official responsible for seeing to it that the homes we live in and the buildings in which we work, play or worship are designed and constructed to be structurally stable, have adequate means of egress and light and ventilation and provide reasonable protection to life and property from fire. The fact that the building official plays an important part in providing reasonable safety to life and property from fire in buildings and structures is probably surprising to many people.

That such a fact is surprising is probably due to the layman's lack of ability to recognize fire protection features that are built into buildings and to understand their purpose. For instance, many people think of doors leading to stairways as being unnecessary obstacles in their path of travel in stores, offices and other buildings and therefore have a tendency to block the doors open. Yet the importance of properly enclosed stairways, including closed doors, has been demonstrated time and again to be of utmost value in preventing the vertical spread of fire up stairways and in providing a means whereby occupants are able to escape from a burning building with reasonable safety. Properly enclosed stairways further provide a means for the fire department to get to upper floors to fight fires.

Proper enclosure of stairways and other vertical openings through floors of buildings is a fundamental fire protection requirement covered in modern building codes. Some of the other fire protection features included in up-to-date codes are limitations of height and area, sprinklers or standpipes required because of area, height or occupancy of a building, fire walls to subdivide large areas, firestopping of walls, floors and suspended ceilings, protection of exterior openings against exposure fires, restrictions on types of construction in the fire limits and construction of chimneys, flues and vents.

In addition to fire protection requirements in building codes, there are many other requirements that are designed to provide safety, health and sanitation for the public. Some of these are provisions for adequate means of egress, light and ventilation, structural stability, plumbing facilities and for the installation of heating equipment.

All of the above matters included in building codes affect each of us and contribute to the general welfare of the community in which we live.

Responsibility for enforcing building codes rests with the building officials. This is indeed an important re-

sponsibility as the building official must see to it that the protection contemplated under the code is provided and yet he must be reasonable in applying the code provisions to the multitudinous variations in building design and materials so as not to be accused of being arbitrary. In addition he must have intimate knowledge of building design and construction practices. Such a job certainly requires many skills.

The National Board of Fire Underwriters has long been aware of the importance of building officials and has maintained a policy of providing helpful assistance to them whenever possible. In accordance with this policy there is given below a recommended order to be followed in checking the code in use to determine items which would be applicable to a proposed building. This procedure is designed to facilitate processing plans for building permits.

1. Determine the occupancy classification and then check all special occupancy requirements such as type of construction required, separation from other occupancies, permissible height or area modifications, etc.

2. Determine type of construction proposed.

3. Determine whether proposed building is to be erected within the fire limits and if so check the requirements within such limits.

4. Determine height and area allowed for the type of construction and occupancy proposed taking into account all permitted modifications.

5. Check location of proposed building on the lot to determine requirements for fire-resistance rating of exterior walls and protection of openings in exterior walls.

6. Check means of egress provided—number of exit ways, location, width and other details.

7. Check light and ventilation provided—size of rooms, window area, courts, yards, etc.

8. Check fire protection requirements such as fire walls, parapets, protection of vertical openings, roof covering, sprinklers, standpipes, interior finish, etc.

9. Check structural design details such as design for proper loads, allowable working stresses of materials, miscellaneous requirements for kind of materials to be used, etc.

10. Check design of chimneys, flues, vents and fireplaces and framing around them.

11. Check sanitary features such as water supply, toilet facilities, etc.

12. Check mechanical and electrical installations such as elevators, moving stairways, air conditioning, ventilating and heating systems, electric wiring, plumbing, gas piping, etc.

* This Bulletin replaces Bulletin No. 11 dated September 9, 1935 entitled "The Need for Gas Masks in Fighting Fires, Their Value and Limitations" which should be discarded.

National Board of Fire Underwriters

(A National Organization of Capital Stock Fire Insurance Companies Established in 1866)

COMMITTEE ON FIRE PREVENTION AND ENGINEERING STANDARDS

LEWIS A. VINCENT,
General Manager

85 John Street, New York 38, N. Y.

JOHN A. NEALE,
Chief Engineer

Revised September, 1956

Special Interest Bulletin No. 219

BUILDING CODES, IMPORTANCE OF PROPER

Almost any fire chief or building official could point out in his community buildings which he would class as fire traps and which he regards as having defects both as to construction and occupancy which would tax the fire department to the utmost with serious danger to life, and which, under unfavorable conditions, might result in a spreading fire involving other buildings.

For many years the National Board of Fire Underwriters and other organizations maintained by the capital stock fire insurance companies have studied these conditions and offered various recommendations for remedying unsatisfactory conditions and thus aid in reducing the enormous destruction of life and property which has taken place over the past years. The increased cost of construction and the attendant increase in taxable values emphasize the importance of reducing these fire losses. The loss in taxable values alone may have a serious impact, and failure of a burned out industry to rebuild may seriously affect a community in a number of ways.

Fire experience has clearly indicated that a large percentage of the serious losses of life and property are due to faults in building construction. The installation of dividing walls to reduce areas, the enclosure of stairways and other vertical openings from floor to floor, the firestopping of walls, and other features necessary to restrict the spread of fire, safeguard life and aid firemen in extinguishing a fire have often been omitted either because of their cost or because of ignorance on the part of the owner or builder as to the need of such safeguards. Even some so-called fire-proof or fire-resistive buildings are seriously deficient in some of these important points.

Many years ago the National Board of Fire Underwriters learned that the preparation of a model building code which would protect life and property against fire, permit the use of new materials as they were developed, and provide for freedom of action in the design of buildings by architects, was a matter requiring a large amount of study and the cooperation not only of building officials but also of trade associations representing manufacturers of the materials used as well as other interested parties.

Because of the importance of such work, men of outstanding ability have been employed by the National Board of Fire Underwriters to prepare and edit a model code. Modifications and revisions have been carried on from year to year by men specializing in building construction and fire protection. The result has been a carefully edited, well arranged, concise and complete code. Since the first edition of this code in 1905 up to the present, a large percentage of the

cities of America have used it as a guide and many have adopted it as a whole.

If proper codes are not adopted in municipalities of the United States, much future construction will result in buildings little better than those of the past, and a continued high rate of destruction may be expected of the assets of America as represented by buildings and their contents, as well as a continued high loss of life from fire.

Every city and town in the United States should be prepared for future building programs by having a modern up-to-date building code, with provisions for strict enforcement. Where there is need for the adoption of a new code the first step usually is to appoint a building code committee. Such a committee can well expedite its work by using the National Building Code or the National Building Code, Abbreviated Edition, recommended by the National Board of Fire Underwriters. The committee can make comparisons with the existing regulations in the city, and with codes of other cities, and see what changes, if any, are needed to make the code fit local conditions. However, experience has shown that modification of the arrangement or of the provisions of the National Building Code is seldom necessary. To aid in this work the National Board of Fire Underwriters will provide any city or town with free copies of the codes to be used as the basis of study by any committee appointed to prepare a suitable code for the community. In addition, the National Board has on its staff engineers who are available for consultation work, without cost to the community, both in reviewing any code prepared and in explaining the provisions in its National Building Code.

Inasmuch as the cost of preparing and printing a building code is high, a number of cities have adopted the National Building Code or the Abbreviated Edition by title, with such amendments as seemed necessary. A suggested ordinance for use in adopting the National Building Code, or the Abbreviated Edition, is given in an appendix of each code. Where either code is thus adopted it is the policy of the National Board of Fire Underwriters to provide the city with up to fifty free copies of the edition that is adopted without cost, and as many additional copies of the codes as may be desired at a nominal price per copy, which is less than cost of publication. The National Board of Fire Underwriters will also be pleased to furnish any town or city which adopts either code with one to three sets of the Standards of the National Board of Fire Underwriters and to place the appropriate official of such town or city on a mailing list to receive future issues of the Standards.

National Board of Fire Underwriters

(A National Organization of Capital Stock Fire Insurance Companies Established in 1866)

COMMITTEE ON FIRE PREVENTION AND ENGINEERING STANDARDS

85 John Street, New York, N. Y.

W. E. MALLALIEU,
General Manager

SPECIAL INTEREST BULLETINS

GEO. W. BOOTH,
Chief Engineer

(For Those Interested in Preventing Loss of Life and Property from Fire)

August 1, 1945

Bulletin No. 220

RESTRICTION OF AREAS OF BUILDINGS

The tendency in constructing any building is to provide for operations by the user such as to entail the least amount of waste movement. For most conditions this means having everything on one floor. This is especially true for stores, machine shops, planing mills and many other industries.

It is therefore natural to expect frontier communities to consist largely of one- or, at most, two-story buildings, and when these become overcrowded, additions are made to them. Only where land values increased rapidly did increase in the height of buildings become a factor in providing enough operating space.

In the process of growth every city has gone through the same stages of building construction. Walls have had openings cut through them, turning several buildings into one fire area, and large structures, originally in semi-isolation, have become centers of congested sections.

The result has been that large-area and excess-area buildings exist, of various occupancies and all of a type of construction having little resistance to destruction by fire. In the final analysis it makes little difference whether structural parts of a building are of wood, unprotected steel, cast-iron, glass or many kinds of stone, plaster or tile; a complete burn-out of the contents results in seventy-five to one hundred per cent destruction of the building. Even in a fireproof building the damage to trim, partitions, decorations, etc., has amounted to eighty per cent or more of the total value, where these buildings have been completely involved.

Studies of fires have been the business of the fire insurance engineers and of the fire chiefs of this country. One fact which experience has shown, and on which theory agrees, is that material well involved in a fire cannot be extinguished unless water can be applied directly upon the incandescent mass. Another recognized fact is that there is a limit to the "reach" of a stream from hose lines, and therefore if all parts of a floor area cannot be reached by the water, when applied from doorways and windows, there is little chance of putting out the fire; in fact, if the burning of the contents is sufficient to prevent the firemen from advancing the nozzle, the fire usually causes the roof or floors to collapse and the firemen will have to retire. Even open areas, such as large platforms at a cotton compress, a lumber yard, or a railroad storage yard, may be so big and develop such heat as to practically prevent successful fire fighting.

This matter of combatting a fire involving a large area has been the bane of firemen of all times, and it has proven many times to be beyond the ability of control by hose line and manpower. So long as these conditions exist in a community the demands for large fire departments, with their high cost to the taxpayer, will exist.

Those buildings which were built before the days of building code requirements controlling areas will always remain as a menace. Where located in congested areas they become conflagration breeders. Even where isolated their destruction seriously injures the economic structure of the community. Besides reducing the taxable assets, the loss of such a structure reduces the income of those thrown out of work, and if not rebuilt it may result in an exodus of workers from the community.

It is the business of the legislative body to enact suitable safeguards, and one of the most vital of these is in the restriction of areas of buildings. No one individual should expect treatment favoring his economics at the expense of the community. Too much of this has existed in the past. Recent serious fires have shown that even the expediency of war has not justified the construction of buildings of great area and holding commodities of large value or great scarcity.

The restriction of fire areas in buildings does not impose a serious obstacle to the use of many buildings. It can be separated into sections by fire walls, or by fire partitions in fireproof and semi-fireproof construction, and by providing fire doors on openings, the building's fire areas will be within the requirements and the building serve its purpose without interfering with operations and at no great cost.

Even though the nature of the use may make it disadvantageous to so restrict the area, there are other safeguards. The potential hazard introduced by excess areas can be somewhat reduced by separating or isolating combustible materials and hazardous processes through the erection of suitable partitions. However, there is no assurance of these conditions being maintained; in fact, the varied changes in occupancy and in process in the past few years have resulted in million-dollar fires occurring in magnesium, rubber, on piers, and even in the open.

There can be no panacea for large and excess areas. The nearest approach is to provide some means of getting water onto a fire irrespective of its location within the building.

The problem of large areas was solved in the years following 1880 by the development of automatic sprinklers. These provided means for the discovery of a fire in its early stages and furnished a discharge of water. Thus it became possible to apply water mechanically where manual application would not be possible. Today automatic sprinkler systems are of such reliability and have proven of such adequacy that all modern building codes recognize them as offsetting the hazard produced by excess areas, except that certain limitations must be made where construction is of a type which would introduce considerable danger of injury of the sprinkler system by collapse or the amount of combustible material might be too great for effective sprinkler control.

It must be recognized that hose lines will be most effective on ground floor areas, and as buildings go upward the ability of hitting all portions becomes less. This may appear to justify greater ground floor areas than on upper floors, but here the economics of design comes in, as stepped-in walls are not well adapted to economic construction. And further, the basement area is the most inaccessible part of a building and it will equal the ground-floor area.

Various factors have been introduced in formulas devised to mathematically determine a true permissible area. The complication of these, and especially if the formula attempts to include heat units of contents and resistance value of the construction in terms of minutes and hours of fire, leads those who have tried to evaluate the various factors back where they were before. That is, that there can never be a scientific determination of area limitation, but that reasonable figures, based upon experience, should be set for all new construction, and where it is desired to exceed these figures that conditions shall be corrected through fire wall and fire partition separation and by requiring automatic sprinkler protection. Any building code which does not rigidly restrict unsprinklered building areas, irrespective of the location and type of construction for most occupancies, fails in one of its important functions.

It will be found that the most logical limit to areas is that which best fits in with the usual size of lot. Where the plat map shows the lots as being 20 to 30 feet wide and 100 to 120 feet in depth, a limitation of two lots in width might well be considered as the basis beyond which the building would be considered as so large as to require special consideration. With the common provision of blank party walls between buildings of other than frame construction, and a separation distance of three feet to the lot line for frame buildings, conditions on this basis would not be too bad, and will be found in close harmony with the limitations in the Recommended Building Code of the National Board of Fire Underwriters.

National Board of Fire Underwriters

(A National Organization of Capital Stock Fire Insurance Companies Established in 1866)

COMMITTEE ON FIRE PREVENTION AND ENGINEERING STANDARDS

W. E. MALLALIEU,
General Manager

85 John Street, New York 7, N. Y.

JOHN A. NEALE,
Chief Engineer

November 1, 1945

Bulletin No. 224

BUILDING HEIGHTS

The crash recently of an airplane into the tall tower of the Empire State Building in New York City forcibly emphasizes the fact that the public has an interest in the often debated subject as to the desirability of limiting the height of structures.

This newest hazard, which produced a death list of fourteen, makes it advisable for all cities to review the subject of structure heights and evaluate the matter from all standpoints.

The arguments for high buildings are: Greater use of land of high value; an advertising item of considerable worth; better light and air on upper floors. Against these are several pertinent arguments which are discussed below.

Consider first the item of land value. This is a purely artificial item, which is becoming of less moment with the changes in transportation, especially in places of less than metropolitan size. Where the principal means of travel was by walking or the use of fixed route transportation, the value of land near these arteries of travel reached astounding figures. These conditions are rapidly changing with the advent of the automobile, and may change even more with the greater use of the airplane.

As a final analysis this claim of the need of great height to overcome high land values does not stand up; close to these high buildings are many of less height and often nearby open lots are used for parking.

Obviously existing Building Codes and Zoning Ordinances will have to take cognizance of the danger of high buildings to airplane travel. They must be prohibited in the immediate vicinity of airfields, and should preferably be limited along the principal approaches for a considerable distance.

Adequate light and air can well be assured for all buildings, whether low or high, by requirements for separation, for courts, areaways and yards, and for setbacks. It is true that these were not provided for in many building codes of the past century, but they have now been incorporated in zoning ordinances. It is no longer necessary to go to excessive heights for breezes and sunshine, especially in these days of air conditioning.

The outstanding factors in height of buildings will always be those endangering life by fire. In this connection there are several items which must be considered. It is not only the few excessively tall structures, which the first part of this article may have seemed to apply to, but the broader aspect of relation of height to types of construction. Certain sections of this country, in the days before the automobile, had

many multiple-family frame buildings erected three- and sometimes four-stories high, with little separation between individual buildings. Height is always a material factor in life hazard, and height, combined with close grouping, greatly increases the potential danger of conflagrations. The result of this permission for the erection of such structures has been to increase the requirements as to men and apparatus needed in the fire department. In like manner because there were no suitable restrictions in the building code, factory, store, office, hotel and apartment buildings of brick-joisted construction were erected in many cities to heights of six to eight stories; these also are conflagration breeders, but of even greater moment, they are proving to be death traps for their occupants. Not only does the height of these buildings limit life saving and fire extinguishment by the fire department, but it increases the flue action of the commonly found open stairway. Even where such stairways and other vertical openings through floors are protected, the absence of good fire resistance to the floors makes occupancy of higher stories dangerous.

The National Board of Fire Underwriters in its Recommended Building Code has not limited the height of fireproof buildings. This type has a high degree of stability and of resistance to fire spread from floor to floor. However, even this type might well be restricted by the individual city, on the basis of preventing congestion. This congestion may prove very costly to a city. It will require additions to water, sewers, gas and electricity; it overtaxes transportation during certain hours of the day; it provides complications in the parking and garaging of automobiles, and it necessitates vital changes in schools, playgrounds and in delivery of goods.

Many existing buildings, particularly those without elevator service, cannot find tenants for either residence or business occupancy for floors above the third. In every city are areas in which buildings of even three stories have only ground floor occupancy. Under normal conditions the erection of a new and more modern building will always cause vacancies, especially in upper floors, of older buildings, even though the older, as well as the newer, building may be fireproof.

It is very evident that it is one of the obligations of a law-making body of every community to restrict the height of buildings. An engineering study of this subject covering half a century, indicates that limitation covered by Article 403 of the Building Code Recommended by the National Board of Fire Underwriters properly applies to the various occupancies and classes of construction.

129

National Board of Fire Underwriters

(A National Organization of Capital Stock Fire Insurance Companies Established in 1866)

LEWIS A. VINCENT,
General Manager

85 John Street, New York 38, N. Y.

JOHN A. NEALE,
Chief Engineer

Revised April, 1957

Special Interest Bulletin No. 227

FIRE LIMITS

One of the most important objectives of a building code is to minimize the possibility of fire involving a series of buildings in the closely built commercial districts. Where suitable laws are not enforced and adequate precautions are not taken to prevent spreading fires in closely built commercial districts, experience has shown that there is an ever-present possibility of a sweeping conflagration. Such a conflagration might be ruinous not only to the individual establishments concerned but to the entire community.

That there is a need for some means to lessen the possibility of a major conflagration has long been recognized. In years past the memory of conflagrations and their consequences in such cities as Chicago, Boston, Seattle, Milwaukee, Jacksonville, Baltimore and San Francisco, served as constant reminders of this need. As the memory of these conflagrations has dimmed, there has come a tendency in recent years on the part of some building code writers to relax the controls that are so vital to the prevention of such catastrophes. However, the lessons of these serious fires must not be forgotten for we are not without examples of serious conflagrations in recent years.

The most effective means by which a building code minimizes the possibility of conflagration is in the fixing of limits known as fire limits together with restrictions on the types of building construction permitted within such limits. With minor exceptions buildings of wood frame and unprotected noncombustible construction should be prohibited within these limits. The types of buildings that are permitted within such limits should be those with exterior walls possessing substantial fire-resistive qualities.

For many years building codes required masonry walls for buildings erected within the fire limits. This was based on years of experience showing that of the materials available at the time for constructing exterior walls, brick and stone of sufficient thickness furnished the most dependable barrier to the spread of fire. However, with the development of new materials and methods of construction, modern building codes no longer specify the materials that must be used for exterior walls of buildings within the fire limits, but require the exterior walls to be of noncombustible material and have a fire resistance rating of not less than 2 hours.

Great care must be taken in the delineation of fire limits and the restrictions placed upon construction therein. The idea of including all of the area zoned for mercantile or for industrial use is unwise in most cases as often these include areas in which there are

scattered buildings of mercantile occupancy found along certain street fronts or small, somewhat isolated, industrial buildings; such groups do not in general produce conditions which a moderate sized fire department could not readily handle and usually the growth of such areas will be slow. Neither is there need of setting up special fire limits in which buildings are restricted to fire-resistive construction. The adoption of two or more kinds of fire limits, or as is done in some codes as A, B, C or 1st, 2nd and 3rd limits, is an unnecessary degree of refinement.

It is not believed that fire limits should be of an extent such that they would unduly restrict construction, especially of dwellings, and which will not permit good leeway in design. Fire limits are largely to reduce the spread of fire from building to building.

Fire limits should include all closely built districts of predominantly business or commercial occupancy, together with such blocks or portions of blocks surrounding these districts on all sides as constitute an exposure to these districts, including areas where a definite trend toward business or commercial development is manifested. The outer belt of blocks or part blocks surrounding the closely built districts ordinarily should be not less than 200 feet wide.

Where a land use or zoning ordinance has been adopted, it may be desirable to correlate the fire limits with the provision of the zoning ordinance regarding location of commercial occupancies. Some extension of the fire limits to include areas zoned for commercial occupancies may be appropriate; however, as indicated previously, it is seldom necessary or desirable to include all such areas within the fire limits.

The problem of properly delineating fire limits has confronted municipal authorities and others interested in the subject for years. In an effort to meet the need for information on this matter the National Board of Fire Underwriters has published a Recommended Method for Laying Out Fire Limits in booklet form. This booklet gives a procedure for analyzing built-up areas of communities and criteria for determining whether they should be included within the fire limits.

Copies of the Recommended Method for Laying Out Fire Limits may be obtained free by persons having an interest in it. Copies will be supplied on request to the National Board of Fire Underwriters at 85 John Street, New York 38. If you are located in the Middle West write to 222 West Adams Street, Chicago 6, Ill., and if west of the Rockies, write to 465 California Street, San Francisco 4, Calif.

National Board of Fire Underwriters

(A National Organization of Capital Stock Fire Insurance Companies Established in 1866)

COMMITTEE ON FIRE PREVENTION AND ENGINEERING STANDARDS

85 John Street, New York 7, N. Y.

SPECIAL INTEREST BULLETINS

(For Those Interested in Preventing Loss of Life and Property from Fire)

W. E. MALLALIEU,
General Manager

GEO. W. BOOTH,
Chief Engineer

August 2, 1943

Bulletin No. 173

OCCUPANCY HAZARDS

Too often a manufacturing concern will introduce a material into its process without looking into the question as to whether this new material is hazardous. This condition may become more prevalent at the present time because of the need of using substitutes for those commonly used materials which are now scarce.

Film Fire.—As an example of a hazard introduced without proper steps being taken to safeguard the material is a fire which occurred in a large plant which originally made photographic dry plates, using glass. For over forty years this relatively low hazard process was carried on, but about ten years ago, the use of nitrocellulose film was introduced and used in the place of glass. The hazard was recognized by the insurance inspector and a recommendation made for a sprinkler system and for safe storage of the large amount of nitrocellulose film on hand.

Apparently there was no adequate fire prevention ordinance in this city, and therefore the fire department could not force the proper safeguards. Also, apparently, the owner of the plant did not appreciate the danger involved, both to life and property, and took no action. That a fire in this material did not occur for a period of ten years was probably due to luck. The fire which made itself known by two explosions, about eleven o'clock at night, was soon out of control with a loss of about \$200,000.

Excess Area Building and High Occupancy Hazard.—This fire would be just another case of the inability of any fire department to successfully fight a fire in a building of excess area, where the fire gets under good headway before it is discovered. were it not that it involved today's all important product—rubber.

Any rubber fire is bad enough from the standpoint of fire fighting—the fumes and smoke are a serious handicap—but when to this is added many gallons of rubber cement and a delay in discovery of possibly 4 hours, there is little a fire department can do.

The building was 320 feet by 160 feet, which meant that streams from windows and doors could not reach all parts of the interior.

Here again, it is evident that the community did not have a fire prevention bureau. In fact, it was a small town outside of a large city, and it is probable that this outside location was chosen partly because the owner could not "build as he chose" within the city where there was a building code and a fire prevention code.

Within most cities structures of this area would have to be sprinklered, and there would be periodic inspections to see that common hazards, particularly those of poor housekeeping, were eliminated.

Delay in Discovery.—Preventing the total destruction of a building, with consequent loss of thousands of

dollars, is true fire prevention. Repeated examples, occurring in all communities, emphasize that delay in discovery of a fire is one of the outstanding causes of serious fires.

The story of a recent fire in a 3-story and basement building is typical of these delayed-discovery fires. A city patrolman smelled smoke at 11:00 p. m., but was unable to locate it then or later; at 3:45 a. m. flames were coming through the basement windows. Although an alarm was sent in immediately, and a general alarm within six minutes, the fire could not be brought under control until noon.

Fire prevention, if it is to eliminate such fires, must include the education of owners and operators of the need of guarding against a condition where a fire may burn and smolder for hours, filling the building with heated gases, which in turn heat up woodwork and other burnable material to a point where only the introduction of additional air is needed to make the interior of the building a seething mass of flame.

There are cures for such conditions. Enclosing stairways and elevator shafts will be of great value, and should be done in any multi-storied building. To prevent the delay in discovery a watchman will be of value, but preferably an automatic fire detecting system, which will transmit an alarm to the fire department, should be installed, or the building equipped with sprinklers.

Pyroxylin Plastic Fires.—As an indication of the value of knowledge as an aid in fire fighting, the following story is of interest:

It looked like only an ordinary fire, this blaze in a store handling supply for students in one of the State colleges. Four of the firemen fighting the fire on the inside wore gas masks, but others were without them. Those without masks were dropping like flies. It was recognized then that the fumes were those from T squares, triangles, protractors and other engineering drawing materials made of pyroxylin plastic. All the men affected were immediately put to bed. One fireman completely collapsed; forty-five minutes' application of a resuscitator was necessary before normal breathing was obtained. Others were kept in bed, regardless of protests, until danger of collapse had past.

Fumes from pyroxylin plastic, which is known by the various trade names of celluloid, pyralin, fiberloid, xylonite, niscloid and nixonoid, can sometimes be recognized by the smell of camphor; the smoke is dense, often of a brownish color; men who are gassed generally resent help with physical force. The fumes are very toxic and men without masks should not be allowed inside the building. Water spray tends to wash out some of the toxic properties, therefore automatic sprinkler protection is very desirable.

UL 10.6.136

D. Standard Tests for Fire Door Assemblies S8, Ch. I-parag. C

- 1. purpose
- 2. specific performance requirements
- 3. significance and application of test ratings

E. Standard Fire Tests for Roof Covering Materials S8, Ch. VI

- 1. purpose
- 2. specific performance requirements
- 3. significance and application of test ratings

IV. BASIC STRUCTURAL COMPONENTS AND CONSTRUCTION TYPES

Read Section 8, Chapters II, III, IV and IX. This material will only be briefly covered in lecture.

EXAM T ↑

V. BASIC STRUCTURAL MATERIALS

- A. Rocks and their decomposition products
- B. Portland Cement
- C. Concrete
- D. Gypsum

VI. SURVEY OF NEW BUILDING MATERIALS AND ASSEMBLIES-Sweet's Catalog Bulletins

- A. Lightweight aggregate plasters
- B. Contact sprayed fireproofing
- C. Concrete assemblies
 - 1. block floor systems
 - 2. lightweight concrete
 - 3. precast concrete slabs and joists
 - 4. prestressed concrete
- D. Gypsum roof decks
- E. Composite roof decks
- F. Cellular steel floors
- G. Lightweight partitions
- H. Plastics-mimeo. lecture notes

VII. PROTECTION OF INTERIOR STRUCTURAL OPENINGS-S8, Ch. I

- A. Basic objectives
- B. Horizontal openings
- C. Vertical openings
- D. Special methods
- E. Smoke and heat venting - S8, Ch. XII

VIII. PROTECTION OF EXTERIOR STRUCTURAL OPENINGS-S8, Ch. XIII

- A. Scope of problem
- B. Types of protection
- C. Theoretical calculations of space separation - mimeo. lecture notes
 - 1. basic theory
 - 2. derivation of formulas and tables
 - 3. application of method to specific building problems

137

IX. PRINCIPLES AND APPLICATION OF FIRE LOADING THEORY-S8, Ch. I-parag. D
and mimeo. lecture notes

- A. Objectives
- B. National Bureau of Standards approach
- C. British approach
- D. Applications and limitations of method

X. STRUCTURAL DESIGN FOR LIFE SAFETY-S8, Ch. XI and Building Exits Code

- A. Basic philosophy
- B. Exit types and details
- C. Influence of construction features
- D. Influence of occupancy features
- E. Analysis of Los Angeles school fire test program - mimeo. lecture notes
- F. Analysis of other life safety testing programs:

- 1. Los Angeles Fire Department dwelling fire tests
- 2. British dwelling fire tests
- 3. Canadian dwelling fire tests

- G. Application to specific building problems

XI. FIRE PROTECTION THROUGH BUILDING CODES - S8, pp. 22-24, National Building Code
and mimeo. lecture notes

- A. Basic objectives

- 1. life safety
- 2. limitation of interior fire spread
- 3. limitation of conflagration potential
- 4. regulate causative hazards

- B. Analysis of National Building Code

- C. Comparison with other nationally recognized codes

- 1. Basic Building Code (B.O.C.A.)
- 2. Southern Standard Building Code (S.B.C.C.)
- 3. Uniform Building Code (I.C.B.O.)

- D. Application to specific building problems

XII. ENGINEERING ECONOMICS OF STRUCTURAL FIRE PROTECTION - mimeo. lecture notes

School GROUP A
39000 # GROSS

$$\frac{39000}{40} \Rightarrow 975 \text{ people}$$

9.75 units needed

have 8 units

= 10 since its a requirement
and not a credit.
.75 < 10% of 9

need door @ (2)

not > 125' to exit

need exit @ 3 or 4

Need smoke barrier in hall since > 300' long
halls.

Should have w.g. windows in part's
or none.

Should have MANUAL (FA) & adequate
illuminated exits

At least 1 window in ea. classroom
should open. # 2277

Heating plant o.k. - 1 HR. Cut off.

would advise door (5) swing other way
or put exit @ (6)

GROSS AREA

PLACE OF ASSEMBLY (INC (LOBBY))

$$120 \times 150 = 18000 \text{ GROSS CLASS A}$$

1400 SEATS

$$\frac{18000}{15 \text{ #/r.}} \Rightarrow 1200 \text{ people}$$

$$\text{NET FLR. AREA} = \frac{12876}{6} \Rightarrow 2146 \text{ people}$$

REMAINDER

$$(150)(60) + (80)(300) + 60(100) = 39000 \text{ #}$$

* should NOT have > 14 SEATS betw. aisles.
end aisles shouldn't have > 7 seats./row.

should have exit @ pt. # ① PD 2112 a.

should have exit @ ② (.not > 20' allowed)

CLASS B interior finish in assembly hall OK
However, in lobby (exit) not < CLASS A PD 2125 a

$$\frac{2146}{100} \Rightarrow \text{AT LEAST 21.5 UNITS}$$

They have 11 units

need 10.5 more to outside
should have type 1 emergency illumination
exit lights

Need MANUAL (FA)

Calculating Reg.

$$3.2 = 3.0 \quad (.2 < .3)$$

$$8.3 = 8.0 \quad (.3 < .8)$$

$$8.6 = 8.5 \quad (.1 < .8)$$

$$\frac{180}{720}$$

$$\frac{16}{1280}$$

$$\frac{720}{1280} + \frac{500}{2500}$$

VAS

Actual Count:

1st: $(20 \times 9)(4) + (20 \times 16)(4) + \text{Lobby}$
 $[(\frac{1}{2} \times 30 \times 100) / 3]$

$$720 + 1280 + 500$$

$$\Rightarrow 2500$$

Balcony $(18 \times 9)(2) + (18 \times 16)(2)$

$$324 + 576$$

$$\Rightarrow 900$$

$$\frac{324}{576} = 900$$

NET AREA

1st. \rightarrow

$$\frac{115 \times 100}{6} + \frac{15 \times 100}{3}$$

$$1917 + 500$$

$$\Rightarrow 2417$$

Balcony

$$\frac{50 \times 100}{6}$$

$$\Rightarrow 833$$

$$\frac{16.6}{3} = 5.5$$

∴ use Actual count

2500 people main flr

900 people balcony

CLASS A place of assembly

20 UNITS AUDIT
 + 5 UNITS lobby.

$$\frac{2500}{100} \Rightarrow 25 \text{ UNITS of exit for main flr.}$$

→ NOT MORE THAN $\frac{2}{3}(25) = 16.5$ may be thru lobby

$$\frac{900}{75} \Rightarrow 12 \text{ UNITS of stairs for balcony}$$

→ MAX 6 UNITS CAN BE F.E.

$$\frac{2}{3} \times 12 \Rightarrow 9 \text{ UNITS exit cap. from stairs.}$$

→ Not $> 9 \times \frac{2}{3} = 6$ may go thru lobby
 or $6 \times \frac{2}{3} = 8$ stairs than lobby.

$$\frac{180}{162} = 324$$

$$\frac{180}{36} = 576$$

$$\frac{1917}{6} = 319.5$$

$$\frac{1917}{6} = 319.5$$

$$\frac{833}{6} = 138.8$$

$$\frac{900}{75} = 12$$

How many existing

147

Main Floor

$$1\left(\frac{44}{22}\right) = 2$$

$$2\left(\frac{36}{22}\right) = 2(1.5) = 3$$

Lobby

$$5\left(\frac{88}{22}\right) = 20$$

$$2\left(\frac{30}{22}\right) = 2(1) = 2$$

} 33

$$\frac{2}{3} \times 11 = 7.33$$

$$\frac{2}{3} \times 22 = 14.66$$

$$\frac{30}{22} = 1.36$$

$$\frac{22}{22} = 1$$

Balcony:

STAIRS

$$F.E. \quad 2\left(\frac{44}{22}\right) = 4$$

$$2\left(\frac{66}{22}\right) = 6$$

Note: $9 - \frac{2}{3}(4) = 6$ units exit cap. now req. in bldg. from stairs

NOT O.K.

look at it another way, audit has 11 units
 \therefore lobby needs $(20 - 11) = 9$
 + 5 for lobby + 6 from balcony $\Rightarrow 20$ O.K. (has 22)

Summary:

MAIN Floor: Need total 25 units + 6 = 31

Have $8 + 3 = 11$
 + MAX (16.5) = 27.5 **INADEQUATE**

Balcony: $\frac{2}{3} \times 25 = 16.67$ $\frac{31.0 - 27.5}{3.5}$ needed in auditorium

Need 12 units stairs, MAX 6 of wh. may be F.E.

Have 10 units stairs, 4 of wh. are F.E.

since 6 of these go thru lobby, and $9 \times \frac{2}{3} \times \frac{1}{2} = 3$ stairs is max allowable, Need another 2 unit F.E. or 2 unit stair thru lobby.

$6 \times \frac{3}{4} = 4.5$ units exit req. in lobby for stairs, O.K.

Note: If only had enough for main floor, could they be used for this 4.5?

$$4 \sqrt[4]{18} = 4.5$$

149
has. 4 exits remote from ea. other.
not > 100' travel. dist.

Type 1 emergency illumination o.k.

Open stairs to balcony o.k.

Acoustical tile in lobby and other places
of exit should be treated \rightarrow F.S. \approx 25.

Rows of seats betw. aisles shouldn't have
> 14 seats

end rows shouldn't have > 7 seats

spacing 32" back to back o.k.

width of aisles ok (36" min.) \rightarrow 2135

80 rows of seats o.k.

Cross aisle width o.k. (min 44")

Should have partitions or 4" railings in
lobby to keep standing people from
obstructing exit.

115
 210
 1150
 230
 424150
 6550

16

BUILDING EXITS PROBLEM (GROUP B TYPE)

1 PERSON / 40 # GROSS FLOOR AREA

2ND. FLOOR ; N. Wing 329 people on 6400 # gross
 S. Wing 289 people on 5600 # gross.
 618
 N. Wing 329 " " 1800 # net
 S. Wing 289 " " 1200 # net
 3000

GROSS $\frac{12000 \#}{1} \times \frac{1 \text{ People}}{40 \#} \Rightarrow \underline{300}$ people on second flr according to gross method.

ACTUAL N. WING: 329
 S. WING: 289 618 people actual

Net $\frac{3000 \#}{1} \times \frac{1 \text{ person}}{6 \#} = \underline{500}$ people net.

1ST FLOOR.

GROSS $\Rightarrow \underline{300}$ people

ACTUAL $\begin{array}{r} 569 \\ -329 \\ \hline 240 \end{array}$ $\begin{array}{r} 631 \\ -289 \\ \hline 342 \end{array}$ $\begin{array}{r} 342 \\ 240 \\ \hline 582 \end{array}$ N. WING: 240
 S. WING: 342

Net $\frac{1400}{1200} = \frac{2600}{1} \times \frac{\text{People}}{6 \#} \Rightarrow \underline{133}$

433
 6 2600
 21 20

~~Stairs Needed to ...~~

~~$\frac{618 \text{ people}}{1} \times \frac{1 \text{ unit}}{60 \text{ people}} = 10.3 \text{ UNITS STAIRS REQ'D.}$~~

FIRST FLR. DOORS: $\frac{582}{100} = 6 \text{ units}$

2ND. FLR. DOORS: $\frac{618}{100} \Rightarrow 6 \text{ units}$

BUILDING EXITS PROBLEM.

153

EXIT REQ.

N. WING. ~~UNIT / STAIR~~

1ST:

$$\frac{240}{100} = 2.4 \text{ UNITS}$$

$$\Rightarrow \underline{2.5 \text{ UNITS. DOORS}}$$

FROM 2ND. $\frac{5.5}{1} \times \frac{3}{4} = 4.1 \Rightarrow \underline{4 \text{ UNITS DOOR.}}$

2ND. $\frac{329}{60} = 5.5 \text{ UNITS. STAIRS.}$

S. WING

2ND: $\frac{289}{60} = 4.8 \text{ UNITS} \Rightarrow \underline{5 \text{ UNITS STAIRS}}$

1ST: $\frac{342}{100} = 3.42 \Rightarrow 3.5 \text{ UNITS DOORS}$

From 2ND $3.5 \times \frac{3}{4} = 2.6 = \underline{3 \text{ UNITS DOORS}}$

$\frac{.75}{3.75}$

EXITS AT HAND

N	east stairway $\frac{59}{22} = 2.36 = 2 \text{ UNITS STAIR}$					
	west stairways $2 \times \frac{54}{22} = 5.1 = 5 \text{ " "}$				}	7
S	east stair $\frac{39}{22} = 1.36 = 1 \text{ UNIT STAIR}$				}	3.5
	middle stair $\frac{39}{22} = 1.36 = 1 \text{ " "}$					
	F.E. $\frac{34}{22} = 1.64 = 1.5 \text{ " "}$					
N	W. 4-44" doors _____	8	UNITS	DOOR	}	10
	E. 1-44" " _____	2	"	"		
S	E. 1-44" door _____	2	UNITS	DOOR	}	3
	middle 1-28" door _____	1	"	"		


153

Evaluate the following proposed one story without basement school building with reference to the various applicable requirements of the Building Exits Code. Include in your answer each instance when this building does or does not meet the Code. Use only the Gross Area Method except for the Assembly Hall.

Building consists of 8" brick bearing walls with concrete floor on ground and with tectum roof slabs on steel bar joists. Ceiling consists of 3/4" gypsum-perlite plaster on metal lath attached directly to the bottom of the bar joists throughout the building. Ceiling of assembly hall and of corridors throughout remaining portion of the building have acoustical tile attached directly to the underside of the plaster. This tile has been listed by U.L. as having a flame spread rating of 40.

The stage in the assembly hall has an approved fire resistive curtain and no scenery of any type. Assume that the assembly hall will be used on occasion by outside groups after school hours. Also, assume that the lobby will not be utilized for standing room during performances. Both longitudinal aisles are 8 feet wide and the cross aisles are 4 feet wide except at the rear of the hall which has a 6 foot aisle. There are 10 seats in each side aisle and 15 seats in the center aisle. There are 20 rows of seats between cross aisles. There is 28 inches spacing back to back between rows.

In the classroom sections of the building, corridors are 8 feet wide. Classroom doors are solid wood flush type. A large ordinary glass panel is to be provided in the corridor wall adjacent to each classroom door. The classroom section of the building is to be air-conditioned and therefore the windows of the classrooms will not be movable. The heating plant for the entire building is to be cut off from the remainder of the building by a one-hour cutoff. No emergency exit lighting or fire alarm system is contemplated.



Net Area -
- assembly hall
- stage
- lobby

these must be Class A doors for exit from assembly hall.

Population Calculation

Classroom Section: Area - $150' \times 60' = 9,000 \text{ ft.}^2$
 $100' \times 70' = 7,000 \text{ ft.}^2$
 $300' \times 80' = 24,000 \text{ ft.}^2$
 $40,000 \text{ ft.}^2$

$40,000 \text{ ft.}^2 \times \frac{P}{40 \text{ ft.}^2} = 1000 P$

Assembly Hall: Area - $150' \times 120' = 18,000 \text{ ft.}^2$
 $18,000 \text{ ft.}^2 \times \frac{P}{15 \text{ ft.}^2} = 1200 P$

Actual Count - $2 \times 20 \times (15 + 10 + 10) = 1400 P$

Exit Requirements

Classroom Section
 $1000 P \times \frac{\text{Unit}}{100 P} = 10 \text{ units}$

Assembly Hall
 $1400 P \times \frac{\text{Unit}}{100 P} = 14 \text{ units}$

Available Exits

2-44" doors (south) $2 \times 2 = 4 \text{ units}$
 1-44" doors (west) $1 \times 2 = 2 \text{ units}$
 1-44" door (north) $1 \times 2 = 2 \text{ units}$
8 units

4-44" doors (south) $4 \times 2 = 8 \text{ units}$
 3-30" doors (east) $3 \times 1 = 3 \text{ units}$
11 units

2-36" doors (division wall) $2 \times 1\frac{1}{2} = 3 \text{ units}$

(1) Exit Capacity

Classroom Section - require 10 units of street door capacity and have 8 units. However, because assembly hall would not have simultaneous occupancy, the two doors in the division wall can be utilized for a total of $8 + 3 = 11$ units of exit capacity - satisfactory.

Assembly Hall - require 14 units of street door capacity and have 11 units. However, as stated above, total exit capacity is $11 + 3 = 14$ units of exit capacity - satisfactory. Aisle capacity - satisfactory.

(2) Exit Arrangement

(a) independent exits - require 2 in classroom section and 4 in assembly hall - satisfactory.

(b) maximum distance to exits - require $\leq 125'$ in classroom section and $\leq 150'$ in assembly hall. In east portion of classroom section, maximum travel distance would be at least $36' + \frac{1}{2}(360) = 216 \text{ feet}$ - inadequate. Assembly hall - satisfactory. In addition, classroom section has a 36' blind corridor at the west end (limit of 20' permiss.) - inadequate.

(c) balanced exit capacity - classroom section - satisfactory. Assembly hall has 8 units through public lobby and $2 + 3 = 5$ units elsewhere - satisfactory (not greater than 2/3 capacity through public lobby.)

157

(d) seating arrangement

- (1) ≤ 14 seats between aisles - have 15 seats - inadequate.
- (2) ≤ 7 seats between aisles and walls - have 10 seats - inadequate.
- (3) ≤ 20 rows between aisles - have 20 rows - satisfactory.
- (4) $\geq 30"$ between rows, back to back - have 28" - inadequate.
- (5) $\geq 3'$ aisle width - satisfactory.

(3) Construction Features

- (a) Interior Finish - require Class B in corridors and assembly hall, Class A in lobby, and Class C elsewhere - satisfactory except for lobby where proposed Class B acoustical tile can not be used.
- (b) 300' corridor length - have approximately 646' of open corridor - inadequate. Therefore, must provide two smoke barriers to reduce open corridor length below 300'.
- (c) classroom-corridor partitions-require wired glass windows - have ordinary glass wall panels adjacent to classroom doors - inadequate.
- (d) minimum 6' corridor width - have 8' wide corridors - satisfactory.
- (e) minimum 1 hour boiler room cut-off - satisfactory.
- (f) window access from classrooms - none provided account ^{of} air conditioning system, inadequate - provide one movable window per classroom of adequate size and not more than $2\frac{1}{2}$ ft. above the floor.
- (g) stage in assembly hall - fire resistive curtain - satisfactory.

(4) Protection Features

- (a) emergency exit illumination - account of possibility of night-time occupancy, a type 1 or 2 emergency lighting system is required - none provided - inadequate.
- (b) manual fire alarm system - required but not provided - inadequate.

Two story with basement brick ordinary joist school. (Evaluate as Group B Type.)

161

Actual school population

north wing-569 (329 on 2nd floor)
annex and south wing-631 (289 on 2nd floor)

Floor areas

north wing-6400 ft.² (net classroom areas; 1800 ft.² on 2nd floor and 4600 ft.² on 1st floor)
annex and south wing-5600 ft.² (net classroom areas; 1200 ft.² on each floor)

area available for seating


Exit facilities in north wing include a stairwell enclosure at west end with 2-56" stairways from 1st to 2nd floors and with 4-44" doors at street level. Doors into corridors at both floors are wood and plain glass. Stairway at east end is 52" wide and extends from basement to 2nd floor. Door protection into corridor is as follows; Basement-wood door, first floor-Class B fire door, second floor-open. Door at street level to outside is 44" wide.

Exit facilities in annex and south wing include two-30" open stairways from first to second floors (44" street level door on east stair and 28" street level door on middle stair) and a 36" outside Class B fire escape stair at the east end.

Doors separating the two sections of the building are of unapproved wooden type.

Interior finish consists of wood lath and plaster with combustible acoustical tile (estimated flame spread rating in excess of 200) fastened to ceilings of all classrooms and to the ceilings of the first and second floor corridors of the north and annex sections. Doors to classrooms are wooden with ordinary glass transoms above. Windows of classrooms are located with bottom sill 3 1/2 feet above floor level. All outside street level doors are equipped with panic hardware. All interior corridors are 10 feet wide.

Our Lady of Angels School



all 95 killed on 2nd. No F.D. but class "B" F.D. 1ST.

Should have 1 hr prot. stairs.

had plenty of exits in N. Section but NO PROT.

Question # 2202-3

163

Solution

Population Calculation

Gross Area Method

	<u>North Wing</u>	<u>Annex and South Wing</u>
Second Floor:	6400 ft. ² x $\frac{P}{40 \text{ ft.}^2} = 160 P$	5600 ft. ² x $\frac{P}{40 \text{ ft.}^2} = 140 P$
First Floor:	same = 160 P	same = 140 P

Net Area Method

Second Floor:	1800 ft. ² x $\frac{P}{6 \text{ ft.}^2} = 300 P$	1200 ft. ² x $\frac{P}{6 \text{ ft.}^2} = 200 P$
First Floor:	1400 ft. ² x $\frac{P}{6 \text{ ft.}^2} = 233 P$	same = 200 P

Actual Count Method

Second Floor:	= 329 P	= 289 P
First Floor:	= 240 P	= 342 P
	<u>569 P</u>	<u>631 P</u>

why 6?

Exit Requirements

2nd floor-North Wing

$\frac{329 \text{ P Unit}}{60P} = 5.5 \text{ units}$

2nd floor-Annex and South Wing

$\frac{289 \text{ P Unit}}{60P} = 4.8 = 5 \text{ units}$

1st floor-North Wing

$\frac{240 \text{ P Unit}}{100P} = 2.4 = 2.5 \text{ units}$

plus street door capacity
for 2nd flr. stair capacity

$\frac{3}{4} (5.5) = 4.1 = 4.0 \text{ units}$
6.5 units

1st floor-Annex and South Wing

$\frac{342P \text{ Unit}}{100P} = 3.4 = 3.5 \text{ units}$

plus street door capacity
for 2nd floor stair capacity

$\frac{3}{4} (3.5) = 2.6 = 3 \text{ units}$
 $(5.0 - 1.5 = 3.5)$ 6.5 units

Available Exits

east stairway $52''/22'' = 2.3 \text{ units} = 2 \text{ units}$
west stairways $2 \times 56''/22'' = 2 \times 2.5 = 5 \text{ units}$
7 units

east stairway $30''/22'' = 1.2 = 1 \text{ unit}$
middle stairway $30''/22'' = 1.2 = 1 \text{ unit}$
outside fire escape $-36''/22'' = 1.5 = 1.5 \text{ units}$
3.5 units

west end $4-44''$ doors $4 \times 2 = 8 \text{ units}$
east end $1-44''$ door $1 \times 2 = 2 \text{ units}$
10 units

east end $1-44''$ door $1 \times 2 = 2 \text{ units}$
middle stair $1-28''$ door $1 \times 1 = 1 \text{ unit}$
3 units

165

(1) Exit Capacity

North Wing - require 5.5 units of stairway capacity and have 7 units available - satisfactory. Require 6.5 units of street door capacity and have 10 units available - satisfactory.

Annex and South Wing - require 5 units of stairway capacity and have 3.5 units available - inadequate. Require 6.5 units of street door capacity and have 3 units available - inadequate.

Bldg. considered as a whole - require 10.5 units of stairway capacity and have 10.5 units available. Require 13 units of street door capacity and have 13 units available. Total exit capacity is satisfactory but it is poorly balanced as between the two sections of the building.

(2) Exit Arrangement

- (a) two independent exits - two exits are available from each floor of each section of the building. However account of open stairways, these exits are not independent.
- (b) maximum 125' travel distance to exits - satisfactory.
- (c) protection of stairwells - west stairwells have unapproved doors and the remaining stairwells are open except for a Class B fire door at the first level in the east stairwell in the North Wing. This is inadequate for Type B school. Either the stairwells must all be properly enclosed, or in lieu thereof, the building must be sprinklered and a separate outside access provided from the basement (Type C-Section 2230.)
- (d) balanced exit capacity-An additional 1.5 units of stairway capacity and 3.5 units of street door capacity should be provided in the Annex and South Wing. This can be achieved most economically by providing a 44" exterior fire escape and by widening the doorway opposite the middle stairway to 66" width.

(3) Construction Features

- (a) Interior Finish - require at least Class B in corridors and exitways and Class C elsewhere. Combustible acoustical tile must therefore be treated in classrooms to reduce flame spread below 200 and in corridors to below 75. (Assuming an existing building.)
- (b) Classroom doors - require wired glass in any windows. Have ordinary glass transoms - inadequate.
- (c) Other features - panic hardware - satisfactory; minimum 6 foot corridor width - satisfactory. Maximum height to window sill - inadequate.

F.P.E. 307 - BUILDING EXITS PROBLEM

169


Problem: Evaluate the adequacy of the exit facilities and associated features provided in the following existing 1 = 2 story movie theater with balcony which is of fire resistive construction. Use the Net Area and Actual Count Methods.

Main floor - provided with 4-44" doors and 2-36" doors (nominal width) on the side walls opening directly to the outside. All doors are equipped with panic hardware. Longitudinal aisles consist of a 132" center aisle and 2-88" side aisles and 3-66" transverse aisles (as shown on sketch). There are 16 seats between the center and side aisles and 9 seats between the side aisles and the walls. There are 20 rows between cross aisles and spacing between rows is 32" back to back.


Balcony - provided with 2-44" Class A exterior fire escapes. There are also 2-66" interior open stairways leading from the back of the balcony down to the first floor lobby. Arrangement of aisles is the same except single 132" transverse aisle at rear. Seating arrangement is identical with first floor except that there are 18 rows of seats.

Lobby - Assume 1/2 of area is available for standing room. Street doors consist of 5-88" double door openings (2-40" clear openings each) and 2-30" single doors (nominal width).

In General - Entire auditorium is equipped with a Type I emergency illuminating system. Interior finish on auditorium and lobby ceilings is acoustical tile (U.L. rating of 40).



Main Floor



Balcony 44" class A F.E.

Solution

169

Population Calculation

Net Area Method

main floor - $115' \times 100' = 11,500 \text{ ft.}^2 \times \frac{P}{6 \text{ ft.}^2} = 1917 \text{ P}$

balcony - $50' \times 100' = 5,000 \text{ ft.}^2 \times \frac{P}{6 \text{ ft.}^2} = 833 \text{ P}$

lobby - $1/2 (30' \times 100') = 1,500 \text{ ft.}^2 \times \frac{P}{3 \text{ ft.}^2} = 500 \text{ P}$

Actual Count Method

main floor - $2 \times 20 \times (16 + 16 + 9 + 9) = 40 \times 50 = 2000 \text{ P}$

balcony - $18 (16 + 16 + 9 + 9) = 18 \times 50 = 900 \text{ P}$

Total 3400 P

Exit Requirements

Balcony

$900 \text{ P} \times \frac{\text{unit}}{75 \text{ P}} = 12 \text{ units}$

Main Floor

Audit. - $2000 \text{ P} \times \frac{\text{Unit}}{100 \text{ P}} = 20 \text{ units}$

Lobby - $500 \text{ P} \times \frac{\text{Unit}}{100 \text{ P}} = \frac{5}{25} \text{ units}$

Available Exits

2-44" Class A ext. fire escapes $2 \times 2 = 4 \text{ units}$
 2-66" stairways $2 \times 3 = 6 \text{ units}$
 10 units

4 - 44" doors $4 \times 2 = 8 \text{ units}$
 2 - 36" doors $2 \times 1\frac{1}{2} = 3 \text{ units}$
 5 - 88" (2-40" clear opn'gs.) $5 \times 2 \times 2 = 20 \text{ units}$
 2 - 30" doors (nom. width) $2 \times 1 = 2 \text{ units}$
33 units


street door capacity
for balcony stairs $3/4(12-4) = \frac{6 \text{ units}}{31 \text{ units}}$

(1) Exit Capacity

Balcony - require 12 units; have only 10 units - inadequate

Main Floor - require 31 units; have 33 units - satisfactory. However, auditorium provides 11 units directly; therefore, 9 units must be provided in form of lobby doors plus 5 units for lobby standing area plus $3/4 (12-4) = 6 \text{ units}$ to evacuate occupants coming from balcony or a total of 20 units - also satisfactory.

2, (2) Aisle Capacity - $132"/22 + 2(88"/22) = 11\frac{1}{2} \text{ units}$. Although main floor requires 20 units, consider as adequate because of egress in various directions to the several auditorium exits.



(3) Exit Arrangement

- (a) 4 independent exits for Class A assembly hall - satisfactory.
- (b) maximum of 2/3 required exit capacity thru public lobby - have 22 units - satisfactory.
 $20 + 5 + 3/4(12) = 34$ total required; $2/3 \times 34 = 22.7$ units allowable.
- (c) maximum 150' travel distance to exit - satisfactory.
- (d) protection of interior stairways - waived as per section 2123.
- (e) seating arrangement

- (1) max. of 14 seats between aisles - have 16 seats - inadequate.
- (2) " " 7 seats " " and wall - have 9 seats - inadequate.
- (3) " " 20 rows between cross aisles - satisfactory.
- (4) minimum of 30" between rows, back to back - satisfactory.
- (5) minimum width of aisles - satisfactory in all cases.

(4) Interior Finish - require Class A interior finish in exitways and Class A or B interior finish in general assembly areas. Have Class B acoustical tile in both auditorium and lobby ceilings - inadequate in lobby.

(5) Emergency Illuminating System - require Type I system for Class A assembly hall - have Type I system installed - satisfactory.



ILLINOIS INSTITUTE OF TECHNOLOGY

NAME DAVID LUCHT

SUBJECT _____

CLASS _____ DATE _____

INSTRUCTOR _____

1		11	
2		12	
3		13	
4		14	
5		15	
6		16	
7		17	
8		18	
9		19	
10		20	

83

1. a. These hold-over devices found inadequate since untenable smoke conditions usually precede temperatures which are high enough to actuate device.
- b. effective in reducing temperatures to small degree, but had no effect on smoke cond.
- c. adequate in certain cases, but it is unknown as to if ^{some} the test fires would ever have been dangerous.
- d. weren't found to actuate fast enough to do any good as far as ~~a~~ giving occupants time to evacuate.

2. 1. giving building structural integrity
2. Providing adequate exits ← allows firemen to enter bldg with safety
3. Venting reqmts. vents and smoke + dangerous gasses
4. Sprinkler Reqmts. (esp. bsmts)
5. Fire Escapes existing bldgs. - provides good access, firemen don't have to take as many chances as fighting bsm't fires

3. ✓ 1. More research on performance characteristics of fire walls.

✓ 2. More research on exposure problems.

5. ✓ 3. More research on possibility of correlating model building performance with actual.

4. ✓ 1. Concentration of Population

- more people requires more exit capacity

✓ 2. Adequacy of Fire Dept. (Esp. ladder equipment) - how well exits can

be replaced or aided by ladder work

✓ 3. Mental & Physical condition

of occupants - how able are occupants to use the exits provided?

✓ 4. Combustibility of Interior Finish materials - must keep fire out of exit

✓ 5. Height and area of bldg.

this governs how far people must travel to reach safety

$$\begin{array}{r} 560 \\ 4 \overline{) 2240} \\ \underline{20} \\ 24 \end{array}$$

$$\begin{array}{r} 230 \\ 80 \\ \hline 18400 \end{array}$$

$$\begin{array}{r} 800 \\ 4000 \end{array}$$

$$5, \text{ TFA - GROSS } 80 \times 50 + 80 \times (150 + 80)$$

$$80 \times 50 \quad 80 \times 230$$

$$\begin{array}{r} 18400 \\ 4000 \\ \hline 22400 = \text{GROSS Area.} \end{array}$$

$$\frac{22400 \text{ #}}{40 \text{ #}} = 560 \text{ people/floor.}$$

REQ.

$$9.33 \text{ 1ST floor: } \frac{560}{100} = 5.6 \Rightarrow 5.5 \text{ units exit doors}$$

$$9.33 \text{ 2ND } \frac{560}{60} = 9.33 = 9 \text{ UNITS, STAIRS.}$$

$$\frac{3}{4} \times 9.33 = 6.75 \sim 6.5 \text{ STREET EXITS REQ FOR STAIRS}$$

∴ need TOTAL ~~12.5~~^{12.0} EXIT UNITS 1ST.
AND. 9 UNITS STAIRS.

AVAILABLE EXITS:

$$\left. \begin{array}{l} 3 \times \frac{28}{22} = 3 \\ 3 \times \frac{28}{22} = 3 \\ 3 \times \frac{21}{22} = 3 \\ 1 \times \frac{10}{22} = 1.5 \end{array} \right\} \begin{array}{l} 11.0 \\ 10.5 \\ 2.0 \end{array}$$

STAIRS!

$$\left. \begin{array}{l} 1 \times \frac{66}{22} = 3 \\ 1 \times \frac{66}{22} = 3 \\ 1 \times \frac{48}{22} = 2 \end{array} \right\} 8$$

∴ need 2 more door exit units
and one stair unit.

Probably should install stair
in N. end to balance exits
and eliminate dead end.

Group B school arrange so that

ea. stairwell has door cap at least = $\frac{3}{4}$ stair cap,

Stairs should have 1 hr. enclosure
and adequate means to keep doors
closed.

Basmt. should have access only
^{from} outside,

It doesn't appear that anyone should
have to travel > 125' ∴ o.k.

→ north end of 2nd
fl. (incl. 50' travel
dist. inside of
classrm.)

Cent. Acoustic tile should be
replaced with tile with
F.S. at least < 75 in corridors
& exits. and < 200 elsewhere.
except basmt should be replaced with

ceiling which would yield a 1 HR.
fire resistance to the floor assembly
above it. (storage area)

✓ Transoms should have w.g.

✓ Exterior doors and doors in any
room with >100 persons
should be equipped with panic
hardware.

✓ Corridor width o.k.


✓ height to bottom of windows
shouldn't be > 2'6" and at least
one should be able to be
opened from inside.

✓ Boiler Room cut off o.k.

Since bend is for storage, it must be 140c too.
✓ Should have adequate exit illumination.

✓ Should have manual F.A. and
plan fire drills.

✗ Vertical spng. proted. S/B 1 hr.



Important F.P. & Related Organizations

1. NFPA a-f
2. NBFU a-d
3. FIA
4. F.M.

Codes, Laws, & legislation:

Advisory Standards: 1-6

Federal Laws: 1-4 Dpts.

State

County

Municipal Govern: 1-2

F.P.E. v. ARCHITECT.

Hazards of Interior Finish Matls.

Reasons for death in Coconut Grove, School etc.

- 1.
- 2.
- 3.

Coconut Grove → U.L. WORK → TUNNEL

UL 723, NFPA 255
ASTM E-84

Stricter Tunnel measures 1.

2.

3.

Variable to be controlled

1.

2.

3.

3 FORMULAE ?

Calculation of Smoke & Fuel Cont ?

OTHER TEST METHODS

1. Federal Specifications Test SS-A-118(b)
2. RADIANT PANEL TEST. NBS
3. Small Tunnel Test FPL
4. Schlyter Test - Sweden
5. F.M. Calorimeter test
6. Spread of Flame Test BS. 476
7. New British Aldg. hd. test
8. Pilot Ignition Test - Australia

TESTING IMPREGNATED MATL:

1. UL 723
2. ASTM E-160

TESTING FOR COMB OR NONCOMB.

1. NFPA Def'n.
2. ASTM E-136-T
3. F.M. CALORIMETER
4. N.B.S. OXYGEN CALORIMETER BOMB TEST
- 5 BRITISH

TESTING METAL DECK.

1. F.M.
2. U.L.

Methods of Reducing Comb.

- 1.
- 2.
- 3.
- 4.

Types of Surface Coatings

- 1.
- 2.
- 3.
- 4.

Impregnation - how?

How does wood burn?

- decomp. products?

- make up. - give off?

Theories of how impreg. works:

1. Coating theory -

2. Thermal ~~theory~~ theory.

A.

B.

C.

3. Gas theories

A.
B.

4. Chemical theories

Advantages & disadvantages of Impreg. lbr.

Metal Roof Decks.

Standard Fire Severity Tests

ASTM E-119 }
NFPA 251 } fire endurance test.
UL 263 }

Measures 1. - A.

Natural Aggregates:

1.

2.

3.

4.

Artificial Aggregates:

1.

2.

3.

Two Types Pre-stressed Conc.

1.

2.

British Results: concerning RFC

1.

2.

3.

4.

N.B.S. Methods of Estimating F-R periods

$$R = (CV)^n$$

$V = \text{N.B. solid mat/amt over spread with surface}$

$$R = (e_1 v_1 + e_2 v_2 + \dots)$$

$$R = (R_1^{.59} + R_2^{.59} + \dots)^{1.7}$$

$$R = (R_1^{.59} + R_2^{.59} + \dots + K)^{1.7}$$

Mingolo's formula
Musk's formula
Hammatt's formula

Good

TESTING FIRE DOORS. U.L. 106, NFR252, ASTM E152

to extend range of fire ASTM T-T curve

LABELED: A, B, C, D, E, F

& if $\leftarrow 250^\circ \text{ or } \leftarrow 650^\circ \text{ F label}$

Good

Testing Roof Covering Mats 3 types test 1, 2, 3
U.L. 790, NFR4 256

Construction of Earth Surfaces

Clay =

Brick =

W.T. =

Portland Cement =

limestone =

Gypsum = ^{coloured} gypsum

lime plaster =

how does it set?

hydrated lime?

3 coats now used - made of what?

Pelite & Vermiculite?

CONTRACT SPRAYED FIRE ROOFING

made of?

advantages?

disadvantages?

Concrete Assemblies

Two types? 1.

2.

Advantages of L.W. conc. ? three L.W. agg.

"CELLULOSE"?

Advantages of Composite Roof. e.g. tekum.

- 1.
- 2.
- 3.

PARTITIONS

advantages of gyp F.R. partns.

PLASTICS - Def.

thermoplastic?

Thermosetting?

General qualities of plastics

1-8.

PROBLEM with Plastics W.R.T. F.P.?

Types fillers OR Aggregate commonly used:

- 1.
- 2.
- 3.
- 4.
- 5.

Tests available?

How can we reduce fire hazard of Plastic?

- 1.
- 2.
- 3.

- Fire walls _____ reg? 12" upper 35' + min 4" ea. 35'

Basic requirements of Fire Wall.

- 1.
- 2.
- 3.
- 4.

CONSTRUCTION TYPES OF FIRE DOORS.

- 1. COMPOSITE TYPE
- 2. HOLLOW METAL
- 3. KALAMEIN
- 4. TIN CLAD
- 5. SHEET METAL
- 6. ROLLING STEEL

CONST. & QUALITIES

Selection of F.D. depends on:

- 1.
- 2.
- 3.

PROTECTION OF EXTERIOR OPENINGS

Factors which have bearing on intensity of exp.
1-11.

BRITISH JOINT FIRE RESEARCH ENG. METHOD.

3 methods of transfer of heat

- 1.
- 2.
- 3.

British concerned with

$$I = \phi e T^4$$

$$\phi = \frac{sd^2}{ml^4} \quad \text{11 Bldgs.}$$

Exposed surface reaches max value when:

IGNORE: Setbacks < 5'

Openings < 20" is none within 5'
Encl. stairs

Separate ~~exposed~~ radiators is > 4 (B.D) apart
check concentration of exposure.

189

Compare NBS & BRITISH METHODS FOR
CORRELATING FIRE LOAD W. FIRE SEVERITY.
STD.

effect of venting?

How do they do it?

Need for exits governed by:
1-5

Psychological Problems
1-4

Basic Philosophy of Code 1-7.

What is an exit?

Two Speeds exit travel?

MAX-MIN Door Width?

Revolving Doors:

Building Code:

3 Basic Provisions

Providing safety to 1-4

Book # 1



ILLINOIS INSTITUTE OF TECHNOLOGY

NAME D. LUCHT
SUBJECT F.P.E. 309 FINAL
CLASS _____ DATE _____
INSTRUCTOR _____

1		11	
2		12	
3		13	
4		14	
5		15	
6		16	
7		17	
8		18	
9		19	
10		20	

81

→ Discussion of direct vs. indirect fire exposure

1. Today, the major evaluation of interior finish materials is based on flame spread, as in the ASTM E-84 tunnel test etc. However, the major cause of death due to fire is the smoke, toxic vapor, and diffident or developed during a fire. This flame spread evaluation has been accepted by building code authorities etc. as a basis for their requirements. It seems that the potential use of smoke + toxic vapor ratings would be most valuable in life safety design problems. Though ASTM E 84 measures this, the "science" requires more research.

- (02)
2. a. Plastics have ~~been~~ been increasingly used in building const. because:
1. good strength to weight ratio.
 2. high corrosion resistance
 3. good light diffusion properties
 4. Can be formed into good insulation mats.
 5. good possibilities in aesthetic uses.

from an FPE standpoint, the problems arise when manf's, etc. add such things as fillers, pigments, hardeners, plasticizers,

catalysts etc, which change
the ~~the~~ burning qualities
greatly from the original
properties, thus making contemplation
of burning characteristics difficult.
Also plastics usually give off
a lot of smoke.

b. The artificial aggregates, popularly
perlite, vermiculite, foamed slag,
have very low densities and
require less structural steel.
This saves money. These
aggregates yield very good
F. R. qualities.

c. Prestressed Conc. has ~~the~~
become popular since it
requires less vertical columns
etc to give assemblies
~~the~~ structural integrity.

When subjected to fire,
the assemblies are very
good, since the steel
makes up for the weakness
of ~~a~~ ord. conc. as far
as tensile stress is
concerned. (all provided
the steel is properly prot.)

4. these are very good
as it takes much less
time & \therefore less money
to construct bldgs. However
the stresses and reactions
in the joints etc. of
these assemblies is difficult
to predict from a fire
resistance standpoint.

3. 1. there is the possibility that the field const. will not duplicate the sample tested, and \therefore will give different results.

2. A 2 HR. etc. rating will not necessarily guarantee the field assembly will maintain the requirements, due to difference in fire load etc.

3. The rating was based on a relatively severe test, and ~~was~~ the field assembly may be in such an area which would never have this severe of a fire.

(3) ??

4. a. fire wall req. (specifications)
relative heights / + areas of bldgs,
protection of exterior openings, epts,
roof covering req., exterior
finish, separation distance

b. ~~fire~~ fire limit requirements,
roof covering req., ept. req.,
exterior ept. prot. req.,
separation distance.

c. Requiring standard hourly
fire resistance reqs for
building walls and
structural elements, prot.
vertical openings, venting
req, sprinkler requirements



5. The technical factors would be with reference to life safety and property preservation they would include application of various required codes such as the building code, exits code, and advisory standards, fire protection codes etc.

The economic factors would be such things as maintenance costs to installed devices, depreciation, insurance values. Questions such as ~~then~~ is a certain type protection worth the cost? etc.

6. According to the Chemical theory, flaming combustion is retarded in three ways:

1. The temperature at which decomposition of the material begins is reduced.
2. The temperature at which the reaction becomes exothermic is raised.
3. The reaction is directed towards formation of Charcoal and water rather than combustible tars & vapors.

The glowing combustion is retarded due to the fact that the reaction is directed from formation of CO_2 to formation of CO ; this CO formation reaction is 80% less exothermic.



$$\begin{array}{r} 364 \\ -134 \\ \hline \end{array}$$

$$R_{\text{brick}} = [(0.36)(4)]^{1.7} = \frac{1.44^{1.7}}{1.34} = \frac{1.86}{1.34}$$

$$6.55 = \left[\frac{1.86}{1.34} + R_{\text{HT}} \right]^{1.7}$$

$$(6.55)^{.59} = \frac{1.36}{1.34} + R_{\text{HT}}^{.59}$$

$$(6.55)^{.59} = (1.64)^{.59} + R_{HT}^{.59}$$

take .59 root

$$6.55 = 1.644 = R_{HT}$$

$$\begin{array}{r} 6.550 \\ -1.644 \\ \hline 4.906 \end{array}$$

$$\begin{array}{r} 4.906 \\ 4.906 \\ \hline 9.812 \end{array}$$

$$R_{HT} = 4.906$$

$$R_{\text{new wall}} = [R_{HT_{8''}}^{.59} + R_{HT_{8''}}^{.59} + K]^{1.7}$$

$$R = [(9.812)^{.59} + .3]^{1.7}$$

$$R = [3.48 + .3]^{1.7}$$

$$R = (3.78)^{1.7}$$

$$R = 9.62 \text{ HR.}$$

math

5

9/21


~~math~~

$(A+B) = [A] + [B]$
 $(A+B)^2 = [A+B]^2 = 22.2$
 $(A+B) + (A+B) = 22.2$

420

$$d = 28'$$

8. $BD = 14'$



all windows 10x5

Each floor will be a separate radiator.

~~distance between floors will be~~

~~$$\frac{100 - (2 + 3)}{8} = \frac{95}{8} = 11.875$$~~

~~$$\frac{100}{8} = 12.5$$~~

~~$$\text{OER of one floor} = 15 \times 100 = 1500$$~~

OER for one floor \Rightarrow height - 10'


width - 90'

$$BD = 14'$$

-4

frame table \Rightarrow % opening
not to exceed 50%
on any floor.

\rightarrow this would give
15' bdy. dist or 30' sep. dist.



Book #2.



ILLINOIS INSTITUTE OF TECHNOLOGY

NAME D. LUCHT

SUBJECT F.P.E. 309 FINAL

CLASS _____ DATE _____

INSTRUCTOR _____

1	11
2	12
3	13
4	14
5	15
6	16
7	17
8	18
9	19
10	20

$$\begin{array}{r} 26 \\ 12000 \\ \hline 450 \\ 192 \end{array}$$

$$\begin{array}{r} 26 \\ 1000 \\ \hline 30 \\ 192 \end{array}$$

$$\begin{array}{r} 150 \\ 80 \\ \hline 12000 \end{array}$$

$$\begin{array}{r} 8050 \\ 4000 \end{array}$$

9. TFA = GYM: $150 \times 80 = 12000$ #
✓ CLASSROOM: $280 \times 100 = 28000$ #
✓ CAFETERIA: $80 \times 50 = 4000$ #

$$4 \sqrt{800}$$

Gym - Place of Assembly ✓ $\frac{12000}{15} \Rightarrow 800$ people
classrooms $\frac{28000}{40} = 700$ people

Cafeteria: Place of Assembly ✓ $\frac{4000}{15} \Rightarrow 267$

FIRST FLOOR: REQ.

~~Assume Gym & classrooms won't be used simultaneously.~~

✓ Gym - $\frac{800}{100} \Rightarrow 8$ units exit width.

✓ Cafeteria - $\frac{267}{100} \approx 2.67 = 2.5$ units

✓ Classroom $\frac{700}{100} \Rightarrow 7$ units

SECOND: Classrooms: ~~700~~ $\frac{700}{60} = 11.6\bar{3} = 12$ stairs

$\frac{3}{4} \times 12 = 9$ exit units of street

$$\begin{array}{r} 11.6 \\ 6 \overline{) 70.00} \\ \underline{66} \\ 40 \\ \underline{36} \\ 40 \\ \underline{36} \\ 40 \end{array}$$

need ¹⁵¹ { Gym - 8
 Caf. - 2.5
 Classrooms - ~~7~~
 Street units ~~9~~
 stairs ~~12~~

1.5g

have! Gym! ^{O.K. 6} ~~1~~ $\times \left(\frac{36}{22}\right) = \del{6}^9$ (front)
 ~~$2 \times \left(\frac{36}{22}\right) = 3$~~

Cafeteria! $\checkmark A \left(\frac{36}{22}\right) = 6$

$\frac{1.5}{9.0}$ Classrooms! $\checkmark \left. \begin{array}{l} 2 \left(\frac{36}{22}\right) \\ 2 \left(\frac{36}{22}\right) \\ 2 \left(\frac{36}{22}\right) \end{array} \right\} 9$

Street units $2 \left(\frac{36}{22}\right) = 3$

Stairs - $2 \left(\frac{66}{22}\right) = 6$

the stairs are insufficient.
They would need a total
of 5 stairs in order to
prevent the existence of
dead end hallways. ^{720'} Since
they need 12 units, each
stair could be 3 units
wide, or ^{could} have ~~3~~ ~~3~~ ~~3~~
~~stairs~~ and combination of
different sized stairs such
that total units = 12
with $\frac{3}{4}$ stair unit capacity
at top and bottom of stairs,
with "B" fire doors (kept
closed) at top of stairs,
and bottom of those
which do not empty
out side. All panic hardware.
The additional stairs emptying
into first floor would create
a situation where ~~as~~ a

minimum of 4.5 more
units of sit would be
required, or if they all
emptied into classroom
section a new total
of $4.5 + 7 = 11.5$ new
req. we only have 9,
so would have to
put in 2.5 more sit
units from classroom sect.

✓ Could use smth barrier,
as an "L" shape of
hall \Rightarrow 300'

~~Cost~~

✓ Interior finish should be Class
A or B in assembly hall +
hallways and Class C
elsewhere.

✓ Should have w.g. in doors.

✗ ? Not > 125' exit travel O.K.

At least 2 exits required
in ~~the~~ Gym + Cafeteria
as remote from ea. other as
possible

✓ Gym ^{exits} could be relocated
somewhat + Cafeteria ~~to~~ needs
one in W. wall

✓ Corridors 10' wide O.K.

✓ Each room should have at
least 1 window 2'6" off
floor + operable.

✓ Heating equip. cut off O.K.


All cooking equipment ~~should~~

✓ air cond. etc. should accord
to Sect 47.

✓ If Gym. used at night
→ type 1 or 2 emergency
illumination.

✓ Should have ~~at least~~ manual
(F.A.) ~~system~~ system

After re-examining the dead
end ~~the~~ halls, it appears
that some of them will
be exactly 20' long, and
the allocation of a total
of 5 stairs may be
a judgement factor rather
than a requirement.






9-21-64

FPE 420

HARDY CROSS METHOD

Hazen Williams Formula



$$H_f = (2.31)(452.4) \left(\frac{Q^{1.85}}{C^{1.85} D^{4.87}} \right)$$


Q = gpm.
 $h_f = \text{ft. } H_{20} / 100' \text{ pipe}$

↓
 * Correct in data Manual

$$* h_{f A-B} = \frac{L}{100} h_f \frac{\text{ft } H_{20}}{100 \text{ pipe}} = \frac{L}{100} \times \frac{2.31}{1} \times \frac{452.4}{1} \frac{Q^{1.85}}{C^{1.85} D^{4.87}}$$

used in calculations
 in hydraulic data manual
 @ C=100 of Old CIP

Memograph in manual for converting
 to 8" pipe and different C values



LEG 1. FLOWS CLOCKWISE (+)

LEG 2. FLOWS COUNTERCLOCKWISE (-)

Eq. #8
$$q = \frac{\Sigma h}{\Sigma 1.85 \frac{L}{D}}$$

Read Article up to middle of 24

WORK SHEET FOR ANALYSIS OF FLOW IN WATER DISTRIBUTION SYSTEMS

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
LINE NUM- BER	L FT.	PIPE SIZE IN.	Eq.L. 8" FT.	Q G.P.M.	h FT. OF WTR.	$\frac{\eta h}{Q}$	CORREC- TION	Q G.P.M.	h FT. OF WTR.	$\frac{\eta h}{Q}$	CORREC- TION	Q G.P.M.	h FT. OF WTR.	$\frac{\eta h}{Q}$	CORREC- TION	Q G.P.M.	h FT. OF WTR.
1																	
2																	
3																	
4																	
5																	
6																	
7																	
8																	
9																	
10																	
11																	
12																	
13																	
14																	
15																	
16																	
17																	
18																	
19																	
20																	
21																	
22																	
23																	
24																	
25																	
26																	
27																	
28																	
29																	
30																	
31																	
32																	




FIGURE 1 by T. FRANCIS O'CONNOR
 Nomograph for the Rapid Calculation of Loss of Head in Pipes.

9-21-64

PRIVATE FIRE MAIN SYSTEMS AND WATER SUPPLIES

I. UNDERGROUND FIRE MAIN SYSTEMS

A. Hydraulic Characteristics of Various System Layouts

1. Single and Compound Pipe Systems
2. Single and Multiple Looped Systems
 - a. Hardy Cross Method

B. Analysis of Performance of An Entire Private Fire Protection Water Supply and Distribution System

1. Supplies Flowing Individually
2. All Supplies in Service and Flowing

Note: Solutions obtained by use of hydraulic slide rule, nomographs, charts and graphs and special graph paper ruled with Head versus Flow Rate 1.85 .

9-23-64

FPE 420

Assume req. F.F. of 1500 gpm. @ B
considering the indicated domestic flows;
CI pipe, $C=100$; neglecting valve + fitting
losses; Calculate water flow dist. in
the grid system. Calculate resid. pressure
req. at C to produce a min. resid.
pressure of 20 psi @ A.

Work on \uparrow

9-25-64

Read CH 17 \diamond FM
For

9-28-64

9-30-64


159.36
6.70

152.66



HEAD LOSS 38'
 FINAL FLOW 530
 FIRST TRIAL 200

How to calculate equivalent pipe?



KEY
 + VALVE
 ○ HYDRANT

$h_f = 151 \text{ C to A}$
 $+ 20 \text{ psi} \rightarrow \frac{46}{197 \text{ req. at C}}$

WATER FLOW TEST
 STATIC PRESSURE AT A
 FLOW MEASURED AT B
 ASSUMED CONSTANT PRESSURE AT C

REQUIRED FIRE FLOW
 PUBLIC WATER SYSTEM
 SCALE: 1" = 300'

12-7-58 W. G. L.

WORK SHEET FOR ANALYSIS OF FLOW IN WATER DISTRIBUTION SYSTEMS

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	
LINE NUM- BER	L FT.	PIPE SIZE IN.	Eq.L. 8" FT.	Q G.P.M.	h FT. OF WTR.	n/h Q	CORREC TION	Q G.P.M.	h FT. OF WTR.	n/h Q	CORREC TION	Q G.P.M.	h FT. OF WTR.	n/h Q	CORREC TION	Q G.P.M.	h FT. OF WTR.	h/h Q	
1	400	8	400	+2000	43	.04	-70 0	+1930	40.0	.038	-130 0	1800	35.0	.035	50	1850	37	.037	
2	1200	6	4900	+100	2	.04	-70 +520 +550	46.0	.160	-130 -160	260	13.0	.100	50 +50	360	21	.110		
3	400	6	1620	-200	-2.4	.023	-70 0	-270	-4.2	.030	-130 -0	-400	-8.3	.040	50	-350	-7	.037	
4	1200	6	4900	-400	-26	.120	-70 0	-470	-35.0	.140	-130 0	-600	-54.0	.170	50	-550	-46	.160	
					16.6	.223	= 74.4		46.8	.368	= 127		-14.3	.345	= -41.5		5	.344	
																		= 14	
8	2	400	8	400	+1900	+40.0	.038	-520 0	+1380	21.0	.028	160	1540	26.0	.031	-50	1490	25.0	.030
9	130	1200	8	1200	+1200	+48.0	.075	-520 -130	+550	11.0	.040	160 +30	740	20.0	.040	-50 -50	640	15.0	.040
10	9	400	6	1620	-300	-5.0	.031	-520 0	-820	-35.0	.078	160	-660	-22.0	.062	-50	-710	-26.0	.068
11	120	1200	6	4900	-100	-2.0	.040	-520 0	-620	-46.0	.160	160	-13.0	.100	-50	-210	-21.0	.110	
					95.0	.184	= 516		-49	.306	= -160		11.0	.233	= +47.2		-7	.248	
																		= -28	
17	3	400	6	1620	+700	26.0	.068	130 0	+830	35.0	.090	-30	800	32.0	.075	50	850	35.0	.080
18	140	1200	6	4900	+300	15.0	.090	130 -330	+100	2.0	.040	-30 +0	70	1.0	.030	50	120	2.8	.040
19	8	400	8	400	-1500	-25.0	.030	130 0	-1370	-20.0	.028	-30	-1400	-22.0	.030	50	-1350	-20.0	.028
20	130	1200	8	1200	-1200	-48.0	.075	130 0	-1070	-11.0	.040	-30	-20.0	.040	50	-15.0	.040		
						-32	.263	= -122		6	.198	= 30.3		-9	.175	= -51.3		2.8	.188
																		= 14.9	
25	4	400	6	1620	+400	+8.5	.040	330	+730	27.0	.070	-0	730	27.0			530	0	
26	5	1050	6	4260	+200	+6.0	.060	330	+530	38.0	.130	-0	530	38.0			-970	0	
27	6	350	6	1420	-1300	-69.0	.100	330	-970	-40.0	.090	0	-970	-40.0			-1470	0	
28	7	400	8	400	-1800	-35.0	.035	330	-1470	-24.0	.030	0	-1470	-24.0				-2.8	
29	140	1200	6	4900	-300	-15.0	.090	330	+30	-2.0	.040	0							
						-104.5	.325	= -322		-1	.350	= -2.86							

WORK SHEET FOR ANALYSIS OF FLOW IN WATER DISTRIBUTION SYSTEMS

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
LINE	PIPE	EQ. L.	h	h	h	CORREC	h	h	CORREC	h	CORREC	h	h	CORREC	h	h	h
NUM-	SIZE	8"	Q	FT. OF	n/h	TION	Q	FT. OF	n/h	TION	Q	FT. OF	n/h	TION	Q	FT. OF	h
BER	FT.	IN.	FT.	G. P. M.	WTR.	Q	G. P. M.	WTR.	Q	G. P. M.	WTR.	Q	G. P. M.	WTR.	Q	G. P. M.	WTR.
1			400	1840	36	.038	0	1840	36	.038	0	1840	36	.038	0	1840	36
2	12"		4900	340	19	.110	0 -20	320	17	.100	0 +10	330	18	.100	0	330	18
3	10		1620	-360	-7	.038	0	-360	-7	.038	0	-360	-7	.038	0	-360	-7
4	11		4900	-560	-47	.165	0	-560	-47	.165	0	-560	-47	.165	0	-560	-47
5						$1/.351 = 2.85$					$-1/.341 = -2.93$				$0/.341 = 0$		
6																	
7																	
8																	
9	2		400	1500	25	.030	20	1520	27	.032	-10	1510	26	.031	0	1510	26
10	13"		1200	620	14	.040	20+40	680	17	.040	-10+0	670	17	.040	0	670	17
11	9		1620	-700	-25	.065	20	-680	-24	.065	-10	-690	-24	.065	0	-690	-24
12	12"		4900		-19	.110	20		-17	.100	-10		-18	.100	0		
13						$-5/.245 = -20.4$					$3/.237 = -12.7$				$1/.236 = 4.24$		
14																	
15																	
16																	
17	3		1620	800	38	.080	-40	840	35	.078	0	840	35	.078	0	840	35
18	14"		4900	150	4	.045	-40	110	23	.040	0	110	23	.040	0	110	23
19	8		400	-1320	-20	.028	-40	-1360	-21	.029	0	-1360	-21	.029	0	-1360	-21
20	13"		1200		-14	.040	-40		-17	.040	0		-17	.040	0		
21						$8/.193 = 41.5$					$-07/.187 = -3.74$				$-02/.187 = -3.74$		
22																	
23																	
24																	
25																	
26																	
27																	
28																	
29																	
30																	
31																	
32																	

CITY WATER FLOW TEST DATA:

Alpha Street: Static Head-75 psi (175 ft of water)
 Residual Head - 48 psi (111 ft of water) with
 1500 gpm flowing past Point A.

Beta Street: Static Head-100 psi (251 ft of water)
 Residual Head-63 psi (146 ft of water)
 with 1200 gpm flowing past Point B.

FIRE PUMP DATA:

For simplicity, the following fire pump data is based upon recommended curves for Horizontal Shaft Centrifugal Fire Pumps:

Rated Capacity and Head - 1000 gpm @ 125 psi (289 ft of water).

Other points along the characteristic curve are,


0 gpm (zero flow) -	$125 \times 1.2 = 150$ psi	(347 ft of water).	
500 gpm @	140 psi	(322 ft of water).	} <u>Note:</u> Pump has 8" suction and discharge flanges.
1320 gpm @	104 psi	(240 ft of water).	
1500 gpm @	81 psi	(188 ft of water).	
1600 gpm @	52 psi	(120 ft of water).	

DETERMINE THE FOLLOWING INFORMATION FROM THE ABOVE DATA AND THE SKETCH:

NOTE: For purposes of this problem, friction head losses in valves and fittings may be neglected.

1. Based upon the City Water flow test data,
 - a. Determine the Alpha Street City Water Supply Curve effective at Point C.
 - b. Determine the Beta Street City Water Supply Curve effective at Point C.
2. Based upon the Centrifugal Fire Pump Data,
 - a. Determine the curve representing the effective ~~K&M~~ Fire Pump Supply Curve at Point C.
3. Based upon all available data,
 - a. Determine the curve representing the combined operation of all supplies effective at Point C.

PROBLEM - ANALYSIS OF PRIVATE FIRE MAIN SYSTEM AND WATER SUPPLIES - 1961




ALPHA ST.

STATIC HEAD = 75 psi = 173'
48 psi = 111' @ 1500 gpm

ELEVATION

130' (A)

16" C.W.M.



50
150
650

ELEVATION 100'


BETA ST.

STATIC HEAD 100 psi = 231'

63 psi = 146' @ 1200 gpm

12" C.W.M.

(B)




No.	SEQUENCE OF CALCULATIONS	Individual Flow G.P.M.	Total Flow G.P.M.
1	H(1) = hn(1)	Q(1) 30.1	30.9
2	hf(2-1).....(9 Ft. 1 In. Pipe) +		
3	Z (2-1).....+		
4	H(2)	15.7	30.7
5	hf(2-1).....(1 In. Pipe)	31.8	61.9
6	hn(2)	46.0	61.9
7	hf(3-2).....(.85 Ft. In. Pipe) +		
8	Z (3-2)		
9	H(3)		46.9
10	hf(4-3) T.&E. (In. Pipe)	16.2	
11	hn(3)	Q(3) 32.8	94.7
12	H(3) From Above		
13	hf(4-3) ... (9 Ft. 1/2 In. Pipe) +		
14	Z (4-3)		
15	H(4)		63.5
16	hf(5-4) T.&E. (In. Pipe)	16.6	
17	hn(4)	Q(4) 38.0	132.7
18	H(4) From Above		
19	hf(5-4) ... (8.5 Ft. 2 In. Pipe) +		
20	Z (5-4)		
21	H(5)		
22	hf(6-5) T.&E. (In. Pipe)		
23	hn(5)	Q(5)	
24	H(5) From Above		
25	hf(6-5) .. (Ft. In. Pipe) +		
26	Z (6-5)		
27	H(6)		
28	hf(7-6) T.&E. (In. Pipe)		
29	hn(6)	Q(6)	
30	H(6) From Above		
31	hf(7-6) .. (Ft. In. Pipe) +		
32	Z (7-6)		
33	H(7)		
34	hf(8-7) T.&E. (In. Pipe)		
35	hn(7)	Q(7)	
36	H(7) From Above		
37	hf(8-7) .. (Ft. In. Pipe) +		
38	Z (8-7)		
39	H(8)		
40	hf(9-8) T.&E. (In. Pipe)		
41	hn(8)	Q(8)	
42	H(8) From Above		
43	hf(9-8) .. (Ft. In. Pipe) +		
44	Z (9-8)		
45	H(9)		
46	hf(10-9) T.&E. (In. Pipe)		
47	hn(9)	Q(9)	
48	H(9) From Above		
49	hf(10-9) .. (Ft. In. Pipe) +		
50	Z (10-9)		
51	H(10)		
52	hf() .. (In. Pipe)		
53	H()		

11-7-55 W.G.L.

1. a.

231
173
58



850
3000
500
1500

5850


11.50

1690
700

2390 @ 30' loss.

or 1600 @ 14.5' loss

1.6



4650'
10"
C=100
hf = 50
@ ~~1050~~

2350'
10"
C=100
hf = ~~50~~ 50
@ 1520

750'
10"
C=140
B

1600 gpm = 1150 gpm
C=140
hf = 9.75'

1500
850

2350

2000
1500
1150

4650

600'
8"
C=140 = C=100
1600 gpm

1150

23

1040
720


1760

850
750

1600

2a.

$250'$
 $8''$
 $C=140 = 1600 \text{ gpm}$
 $C=100$
 1040
 $hf = 8$



$hf = 75$
 $Q = 1600$

$600' 8''$
 $C=140 = 1600 \text{ gpm}$
 $hf = 19$

$hf = 75$
 $Q = 1420$
 1600
 3020

19
 23
 42

19
 18
 32

1220
 1420

Handwritten scribbles at the bottom right of the page.



ILLINOIS INSTITUTE OF TECHNOLOGY

NAME LUCHT

SUBJECT _____

CLASS _____ DATE _____


INSTRUCTOR _____

a 1 ✓	11
b 2 5	12
c 3 ✓	13
d 4 ✓	14
e 5 ✓	15
6	16
7	17
8	18
9	19
10	20

Handwritten notes:
5
95

i.a.

RED #'S
are assumed
flaws.




GRID OF EQ. 8" PIPE C=100

$$\begin{array}{r} 4.06 \\ \times 600 \\ \hline 2436.00 \end{array}$$

$$\left. \begin{array}{l} (2500)(.14)(1.22) = 427 \\ (1500)(.14)(1.22) = 256 \\ (1100)(.84) = 923 \\ (3100)(.71) = 2200 \end{array} \right\} \begin{array}{l} \text{all other} \\ \text{conversions} \\ \text{done on} \\ \text{slide rule} \end{array}$$

SYSTEM REDRAWN



2410
1000
427

3867

Too high instead of 790
you must use 990g

10 c. A-B 21.5 ✓

B-C = 2+3+4+4a+5 = 129.3 *90.3*

C-D 10.8 ✓

A-D = 21.5 + B-C + ~~10.8~~ = ~~161.6~~ *122.6*

		<i>122.6</i>	
		<i>90.3</i>	
70	<i>45.0</i>	21.5	}
29	<i>19.0</i>	10.8	
12	<i>8.0</i>	129.3	
3.3	<i>3.3</i>	161.6	
15	<i>15.0</i>	129.3	
	<i>90.3</i>	161.6	
	<i>95.3</i>		

from worksheet
122.6

10 d. A-D lose ~~161.6~~ *~127* *122.6*


@ 1500 gpm ⇒ 2600' 8"

(2600' 8")

~ 2000' *correct*

SYSTEM THE DRAWING

e. 2600' 8" @ 1500 gpm \Rightarrow 161.6' feet loss




Handwritten notes in red and blue ink on the left side of the page, including '100 H.H.H.' and '100'.

A-B = 21.2 ✓

B-C = 2+3+4+4+2 = 15.8 ✓

C-D = 10.8 ✓


A-D = 21.2 + B-C + 10.8 = 42.8 ✓



Handwritten notes at the bottom of the page, including 'A-D per 100' and '2600' 8" @ 1500 gpm'.

2600' 8" (circled in red)

1. The following sketch represents a simple loop system of Cast Iron Underground pipings:



- (a) Convert all piping to its equivalent in feet of 8" Cast Iron Pipe, $C = 100$.
- (b) Assuming a total flow through the system of 1500 gpm, calculate the flow rate through each leg of the loop, (B) - (C).

Note: Assume negligible elevation head and neglect fitting losses.

- (c) For the same assumptions as Item (b), determine the loss due to friction in feet of water from (A) to (B), (B) to (C), (C) to (D) and (A) to (D).

- (d) Calculate the equivalent length of 8" pipe, $C = 100$ which could be used to replace the system (A) to (D).

- (e) Point (A) of the system is connected to a water supply for which the following test data, with respect to Point (A), is available:

Head ft.	Flow Rate gpm.
280 (121 psi)	0
260	1200
230	2000

Using a graphical method:

- Draw the supply curve for the water available at Point (A).
- Draw the friction loss curve for the system between Points (A) and (D).
- Draw the yield curve representing the water available at Point (D), assuming no change in elevation (A) to (D).
- How much water would be available at Point (D) at a Head of ~~80~~ feet of water?


800 - 10 = 790


1. b. flow thru each leg of loop B-C - for direction of diagram of system, except #12

LUCHT

WORK SHEET FOR ANALYSIS OF FLOW IN WATER DISTRIBUTION SYSTEMS																	
A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
LINE NUM-BER	L FT.	PIPE SIZE IN.	EQ. L. 8" FT.	Q G.P.M.	h FT. OF WTR.	$n \frac{h}{Q}$	CORRECTION	Q G.P.M.	h FT. OF WTR.	$n \frac{h}{Q}$	CORRECTION	Q G.P.M.	h FT. OF WTR.	$n \frac{h}{Q}$	CORRECTION	Q G.P.M.	h FT. OF WTR.
2	2440	1	2440	800	46	.110	-10	990	70	.136	0						
3	1000		1000	800	19	.045	-10	990	29	.055	0						
4	430		430	800	8.5	.020	-10	990	12	.023	0						
12	550		550	-200	-0.8	.008	-10	60	0.1	.028	0						
10	2200		2200	-700	-32.0	.083	-10	-710	-30.4	.090	0						
11	2440		2440	-700	-36.0	.098	-10	-710	-40.0	.100	0						
7	46		46	46	4.7	1.364	= 12.9	11.0	40.6	1.426	= 9.5						
8	18.5		18.5	18.5	2.6			-70.4	2.4	1.926	= 0						
9	36		36	36	1.2			40.6									
10	64.8		64.8	64.8	4.7			3.3									
11	260		260	1000	6.8	.013	-270	730	15.0	.040	0						
5	920		920	1000	27.0	.050	-270	730	15.0	.040	0						
7	440		440	-500	-3.6	.013	-270	-770	-8.0	.020	0						
8	256		256	-500	-2.0	.008	-270	-770	-3.6	.010	0						
9	270		270	-500	-2.2	.008	-270	-770	-4.0	.010	0						
12	550		550	500	0.8	.009	-270	-60	-0.1	.028	0						
17	-5.6		-5.6	26.8	1.0	.00	= 26.8		2.6	1.156	= 0						
18	-7.8		-7.8	34.6	1.1												
19																	
20																	
21																	
22																	
23																	
24																	
25																	
26																	
27																	
28																	
29																	
30																	
31																	
32																	

Assumed wrong direction for #12






Sprinkler Systems


WBFU # 13

Pg. 34 * FIG. 3010




3 different kinds of piping schedules


LIGHT
Pg 36



ORD
Pg 37



EXTRA
Pg 38



Read Section 3 Components

NBFU 13

pg 34

SS 3001

ASA schedule 40, 80, 30, etc. designate pipe wall thickness req.

refers only to PIPE

Schedule 40 = "Standard wall" Pipe
Schedule 30 = acceptable in 8" + larger.

Dimensions for all pipe must meet ASA B-36.10 1959 - can use for pressures up to 300 PSI.

Pg. 54

SS 3300

working pressure not < 175 PSI COLD H₂O

not same as steam pressure.

Small fittings up to 2" - can use CI < 175 PSI
> 2" CI > 175 PSI must use heavy CI pattern

Ductile Iron = CI + alloys => not as brittle

Malleable Iron OK up to + incl. 6" < 300 PSI

FITTINGS

SS 3317

FF 3315 Values.

pressure rating stamped on valve.
certified by mfr.

SS 3316 JOINTS

10-12-64

pg 56 §§ 3321 Couplings + Unions
 see also pg. 14-15 CRANE "Piping (Painters)"

pg. 56 Reducers + Bushings pg 16 CRANE

pg. 56 VALVES

§§ 3420

pg 56 Valves Controlling Water Supplies

3421 - no valve on F.D. connection

but must have ① valve to control all of rest of supply. (see fig. 3424)
 → to each system


~~§§~~

~~§§~~

3422 Also ① valve in EACH source


3423 Check valves

e.g.




3424


one water supply
must still check




3425




3426



3427



3428



Pg 58

3431 You don't put a supply of water into bldg w/o a way to shut it off!

3432

Don't want other supply going into broken pipes & pump & all over the place in the bldg.

3433

If check is overhead @ lower level it is vulnerable - not so important if one fire area however.

3434 Control valves must be accessible

3440 Large yard systems are sectioned by valves.

HANGARS - Pg. 61 Be careful to choose proper hangar.


pg. 82.

4040 DEFINITIONS

4041-4044 Types Construction.

~~4040~~

PS 84 Staggered Spacing




Pg. 84

§ 4130 Protection Area Limitation

MAX. Area covered by 10. spkr.

Max distance between spkrs.

Max distance between branch lines




1. Decide type Const.

2. ~~Get~~ Get Max area

Max spkr. dist.

Max branch dist

3. Layout





if girders are wide enough \rightarrow lines
will be betw. them, may have
to put 2 lines betw. if one want cover.

Sprinkler on Branch Line




Pipe hanger

common




or whatever you want
+ key it.


Flanged Joints





Intersection




At each end of each pipe
must show elevation of
E of pipe for slope.





Don't put sprinkler < 6'

Read article ~~by~~ by art Guys
fire ext
& Extinction of fire by water sprays



re: "Chemical Aspects of Fire Extinguishment"

FPE 420

10-26-69

Can:

1. Cool fuel \Rightarrow sufficient gases aren't given off to support comb.
2. Space occupied by flame.

a. mix inert gas with it to dilute O_2 + comb. gases.

But if fuel is hot enough, may reignite after initial extinguishment. If fire can burrow down into fuel, the fuel will cool very slowly and CO_2 etc. aren't very effective, unless applied for long period of time.


b. Chain Breaking method applied to space occupied by flame.
e.g. Dry Chemical

Some CO_2 + H_2O formed, but not sufficient to extinguish. Extinguishment is primarily obtained by chain breaking process. (Capture free radicals)

Water - Plain Water
1. + 2.

Cools and Steam acts as inert gas in flame.

Foam.




Absorbs heat + cuts off O_2
reduce temp below fire point
⇒ can't give off vapors to support flame.

Note: gasoline + ethyl ether etc. is above fire pt. at ordinary temperatures.
∴ must rely on restriction of O_2 only,
+ cover ⇒ vapors can't get thru foam.

Wetting Agents:

Reduce runoff time ⇒ more water will stay on fuel to evaporate.



On open fire, most of spray cools fuel only, as steam is carried away + doesn't affect flame area.

If fire area is somewhat enclosed cooling + steam are both effective.

In most of our cases, we will have the effect of both.


Note, with hose stream you can get to the seat of fire + cool fuel + still get steam dilution of O_2 + fuel gases even in open fire.

FPE 420

10-30-64

(AS) PROBLEM DUE DEC. 11 - LATEST DEC. 14

What we should get out of these ~~papers~~ papers.
Write down firm conclusions from these
papers. - How we might use them.



Man 10-26-64

Chemical Aspects of Fire Extinguishment

Concepts of fire and fire extinguishment must be revamped because recent findings add a fourth dimension to the fire triangle

by A. B. Guise, Ansul Chemical Co.

AS A RESULT of fairly recent and not too widely publicized research, our understanding of how fire extinguishing agents work has increased greatly. This may lead to more effective provision for the control and extinguishment of fires.

The old familiar fire triangle concept which postulates that fire can exist only when heat, fuel, and oxygen are present, is an oversimplification. In the light of new findings it must be refined to a square. A new factor, a chemical chain reaction in the flame itself, is the fourth essential. Consequently, *infered* extinguishment a new factor has been added: "interrupt the name chain reaction." This action may be extremely important as an explanation of the effectiveness of certain extinguishing agents.

Water includes foam, loaded stream etc.

Water. The most common—oldest, cheapest, and most plentiful of all—is water, applied to a fire as a liquid stream or spray. With one exception, the extinguishing action of water and water solutions is purely physical. Steam acts as a smothering agent by displacement of oxygen, and the mechanical and chemical foams act as blanketing agents to separate the fuel from the air. Wetting agents and viscosity-increasing agents increase the effectiveness of the cooling action of water by retarding runoff.

The first indication of true chemical action in extinguishment where water is concerned is the "loaded stream," a solution of potassium carbonate in water with other additives to reduce the freezing point to -40° F., used in hand portable and wheeled extinguishers. It is *more* effective than plain water on fires in ordinary combustibles such as wood, cloth, or paper and is approved for use on flammable liquid

fires where water would not be effective even as a spray.

Early work in this area was described by Thomas and Hochwalt in 1928. They concluded that water solutions of metallic salts based on elements in Group I of the Periodic Table (lithium, sodium, potassium, rubidium, or cesium) were more effective as the atomic weights of the cations increased. Alkali metal salts with anions containing oxygen and halogens were most effective and they ascribed the action to a "negative catalytic" effect on the combustion reaction. It is probable that the effectiveness of these solutions is due to a chemical chain-breaking action. This is also indicated by practical experience with the loaded stream extinguisher, which is most effective on flammable liquid fires when the solution is applied to produce a spray.

Carbon Dioxide. Carbon dioxide is essentially as simple in its action as water. When introduced into the combustion zone, it dilutes the reactants—oxygen and fuel vapors—below the concentration necessary to support combustion.

Carbon dioxide may be used on any type of fire, regardless of the type of fuel involved or the presence of electrical hazards. However, confinement is required in fires involving ordinary combustibles to assure effective exclusion of oxygen long enough to cool to below reignition temperatures.

(Halogenated Hydrocarbons) Much research has been carried out on the extinguishing effectiveness of a large variety of halogenated hydrocarbons. At one time it was thought that their action was due to cooling by vaporization and smothering by vapor dilution of air and fuel vapors. It is now believed that the major extinguishing mechanism is a chemical chain-breaking action and that the halogens inhibit continuation of the combustion reaction by combining with hydrogen atoms and removing them.

Carbon tetrachloride is an inexpensive extinguishant, but its application is declining because of its toxicity and the toxicity of the products of thermal decomposition. Chlorobromomethane, developed




Figure 1. Comparative effectiveness of extinguishing agents on weight basis




Figure 2. Branched-chain combustion reaction of hydrogen and oxygen

are used. Where streams from *be* extinguishers or hose lines *must* used, the physical characteristics *exist* of the halogenated compounds *do* not allow the theoretical effectiveness of the extinguishing agent to be obtained. This is shown by Figure 1.

Dry Chemical. Dry chemical consists of finely divided sodium bicarbonate with additives used primarily to enhance flowing action and water repellency.

Potassium bicarbonate is under consideration, but is not yet commercially available. Both laboratory and practical evaluations indicate greater extinguishing effectiveness than sodium bicarbonate dry chemical.

The finely divided chemical is expelled from its container by dry gas (air, carbon dioxide, or nitrogen) under pressure through a nozzle which controls the pattern of application much as water is controlled. Dry chemical is believed to extinguish primarily by chemical chain-reaction interruption. Cooling dilution of reactants is believed *to be* a relatively minor factor. *Many* chemicals not readily decomposed *post* by heat, such as sodium chloride, are effective extinguishing agents when applied as a powder.

The chain reaction involves the presence of free radicals in the flame zone. These interact with fuel and oxygen to produce a continuing or increasing supply of free radicals to continue the flame reaction (Figure 2). A simple hydrogen flame reaction illustrates this point. The free radicals are self-propagating unless captured by condensation on or interaction with some inerting substance. The fine particles introduced to the flame area are believed to capture sufficient free radicals to interrupt the chain reaction, and flame suppression is nearly instantaneous.

A cloud of dry chemical therefore is similar to a flame arrester, in that a flame cannot pass through a cloud of particles, when in proper concentration; conversely, when *the* cloud of particles is produced *while* the combustion reaction is *pro-*ceeding, extinguishment takes *place*.

It takes about 200,000,000 particles of dry chemical per cubic

by the Germans during World War II, has slightly less toxicity and is a more effective extinguishing agent.

Methyl bromide gained wide acceptance in foreign countries but has never been widely used in the United States. Its use abroad has also declined, because of toxicity.

New halogenated agents of considerable effectiveness are fluorobromo compounds. Bromotrifluoromethane (Halon 1301) is receiving concentrated attention from the military, but its cost, about \$4 per pound, has delayed commercial application despite excellent extinguishing effectiveness and low toxicity.

Laboratory evaluation of halogenated compounds must be care-

fully weighed in the light of field application. There is considerable discrepancy between practical extinguishing results and laboratory evaluation, especially by the explosion buret method.

Although the explosion buret method is a convenient way of carrying out preliminary evaluations in the laboratory, it does not represent actual conditions of fire extinguishment, because the values are obtained under conditions where combustion is not already proceeding. Laboratory evaluations on a larger scale by the use of fixed nozzles may be converted to practical applications, where properly engineered piped systems with fixed nozzles




Figure 3. Effect of application rate

limited use for aircraft




Figure 4. Relation of particle size to extinguishing effectiveness of dry chemicals

foot of flame to extinguish a gasoline fire and approximately 2,000,000 particles to extinguish a hydrogen fire.

All extinguishing agents may be *generally* compared for effectiveness *in* terms of the quantity required for extinguishing a given fire. Each curve in Figure 3 is derived from extinguishing data and all illustrate an important factor in the effectiveness of any type of agent—rate of application.

In the case of dry chemical extinguishing one more factor is vital—particle size (Figure 4). Attachment of free radicals to a surface is apparently a basic factor in chain-reaction interruption. The dry chemical particles in the flame zone provide such a surface and the finer the powder the greater the effective surface for a given quantity of agent and the shorter the distance of diffusion of a free radical.

Division of Industrial and Engineering Chemistry, 136th Meeting, ACS, Atlantic City, N. J., September 1959.

The Extinction of Fires by Water Sprays

D. J. Rasbash

Joint Fire Research Organization, Boreham Wood, England

Introduction

Water spray has long been widely used for the extinction of fires in both liquid and solid fuels. Although there have been numerous *ad hoc* investigations on the effect of sprays from various nozzles on fires of different types, it is only in recent years that any systematic study has been made using sprays and fires with controlled and measured properties. Work of this nature has been carried out for about ten years at the Joint Fire Research Organization. In this work attention has been paid in particular to the ability of spray to penetrate to the seat of a fire, the mechanism of extinction, and the properties of sprays required to extinguish fires of various types. To some extent the work has also permitted an approach to be made to defining critical heat transfer criteria for extinguishing fire. In this paper these aspects of the problem will be discussed and illustrated by experimental results obtained at the above organization and elsewhere. The results of the experiments also suggest certain broad principles on which fire-fighting operations should be based, and these will be outlined.

Penetration of Spray to the Seat of a Fire

In order for a spray to be able to exert a useful effect on a fire, it is usually necessary for the spray to penetrate to the seat of the fire, particularly to the burning fuel. To do this the spray must be either formed near the fuel or it must have sufficient forward force to prevent too much of the spray being either deflected by or evaporated in the flame and hot gases associated with the fire.

The factors which control the penetration of spray to the seat of a fire are the drop size and thrust of the spray, the thrusts of the flames and wind, gravity, and the evaporation of spray in the flames. When sprays are applied to fires by hand the effects of the thrust of the flames and the wind, and the evaporation of spray in the flames are usually minimized by applying the spray directly through the base of the flames to the fuel from the upwind side of the fire; the reach of the spray, which is determined mainly by gravity and the forward thrust of the spray, usually controls the penetration to the seat of the fire under these conditions. When spray is applied downward to a fire, all the above factors are of importance but particularly the relative thrusts of the spray and the flames. Little information is available from the literature on either of these two factors but work carried out at the Joint Fire Research Organization indicates that they may be estimated from readily measured properties of the spray and the flame. The thrust within a spray is a function of the reaction at the nozzle and the width of the spray; there is also evidence that at some distance from the nozzle it is approximately equal to the thrust of the entrained air current. The latter depends on the flow rate of spray per unit area and the pressure at the nozzles. The thrust of flames is proportional to the buoyancy head. Further information on these relationships is given in the appendix.

Experimental information on the penetration of sprays to burning fuel is available for fires in kerosine burning in a 30 cm diameter vessel using downward application of spray.¹ The results were scattered mainly because the penetration was very sensitive to the pattern of the spray at the fire area, a factor which was very difficult to control experimentally. Broadly, however, the penetration decreased as the pattern of the spray became more peaked in the centre of the vessel and as the thrust and the drop size of the spray decreased. The effect of the latter two factors is illustrated in Figure 1 which refers to sprays in which




Figure 1. Penetration of spray to the fuel of a fire.

the peak of the spray distribution was contained in the central half of the vessel but in which not more than one-fourth of the area of the vessel was covered by a flow rate less than one-half of the peak value. In spite of the scatter of the points, the effect of spray thrust, as calculated from the entrained air current, and the drop size on the penetration is clearly seen. There is, however, an indication that at drop sizes greater than about 0.8 mm the penetration was usually considerably greater.

In the tests referred to in Figure 1 the height of the flame as judged visually was 150 cm before the application of spray and was reduced to mean values between 80 and 140 cm during the application of the spray. These heights correspond to upward flame thrusts of 34 and 18-30 dynes/cm² (see appendix). It will be

↳ ~ 10 LB/IN²

seen from Figure 1 that the thrusts of the spray required to give a 50 per cent penetration for the finer sprays is comparable to these values.

It was observed during the tests that as the thrust of the spray was increased above 20 dynes/cm² the flames became increasingly unstable. Sprays with higher thrusts than represented in Figure 1 often caused stabilization of the flame as a relatively flat flame above the vessel after a period of instability. The minimum spray thrust at which this phenomenon occurred was 77 dynes/cm². It would be expected that under these conditions the bulk of the spray, even if it were fine and of a peaked pattern at the fire area, would penetrate to the burning fuel; this might also be inferred by extrapolation of the results in Figure 1. This critical thrust, T_c might be related to x , the height of the flames as judged visually prior to the application of spray, by equation (1).

$$T_c = 0.5 \rho_0 g x \quad (1)$$

ρ_0 = density of air, g = acceleration due to gravity.

It would be expected that since equation (1) represents the thrust in the air current of the spray required to overcome the buoyancy head of the flames, T_c should scale with flame height for larger sizes of fire than the fire tested.

For a given flow rate of spray in the absence of fire, and for a given pressure, the thrust of the spray in these experiments was approximately independent of the drop size. Therefore, as the drop size decreased the penetration decreased. However, as the drop size decreased the efficiency of unit mass of spray in reducing the rate of burning increased since the finer spray cooled the liquid more efficiently. As a result of these two phenomena a drop size occurred at which there was a minimum rate of burning for a given flow rate and pressure. This drop size depended on the spray thrust, and decreased from 0.8 to 0.33 mm as the thrust increased from 6 to 26 dynes/cm².

Mechanism of Extinction

There are two main ways of extinguishing a fire with water spray: (1) cooling the burning fuel and (2) cooling the flame. The mechanism of smothering the flame with steam is one aspect of cooling the flame and will be dealt with under that heading.

Cooling the Fuel

To reduce the temperature of the fuel the spray must be capable of abstracting heat from the fuel at a rate greater than the rate at which the fuel will take up sensible heat. Heat will normally reach the fuel by heat transfer from neighbouring hot bodies and from the flame. Information on heat transfer from bodies may be obtained from texts on heat transfer although there are many important cases, for example, on the flow of films of fluid over hot surfaces where information is lacking. There is evidence, which will be given later, that radiation from the flame to the fuel that is being cooled does not normally play a large part in determining critical conditions for extinction, although if only a part of the fire is being extinguished at any one time, radiation from the rest of the flames might become an important factor. In this paper, therefore, particular attention will be paid to estimating critical conditions when the surface receives heat mainly by convective or conductive transfer from the flame. Such estimates may be obtained from known relationships between the rate of burning and the heat

how measured?
see Appendix

Boris
Cavel

ABSTRACTS AND REVIEWS

transferred from the flame to the surface. The method used may be best illustrated by an example. Equation (2) was found by Spalding to give the rate of burning of liquid fires flowing over surfaces with a vertical dimension (d).²

$$\dot{m}'' = \frac{0.45k}{dc} B^i \sqrt{\frac{gd^3}{a^2}} \quad (2)$$

where

- \dot{m}'' is the average rate of vaporization per unit surface area,
- d is the linear dimension of the surface,
- k, c a² are thermal conductivity, specific heat and thermal diffusivity of air at room temperature,
- g is the acceleration due to gravity,
- B is a transfer number equal to

$$\frac{M_{og} H/r + c (T_r - T_s)}{Q}$$

where

- Q is the heat transfer to the fuel surface per unit mass of fuel vaporized,
- M_{og} is the concentration of oxygen in air (by weight),
- H is the heat of combustion of the fuel,
- T_r is the ambient gas temperature and T_s the surface temperature,
- r is the stoichiometric ratio (weight of oxygen/weight of fuel).

Normally, under steady conditions, the value of Q in the transfer number is equal to λ_f, the heat required to vaporize unit mass of fuel. However, when a spray is acting on the fuel and heat is being removed from the fuel, Q will be greater than λ_f.

For most liquid hydrocarbons equation (2) may be reduced with little error to

$$\dot{m}'' = \frac{0.17}{d^{0.25} Q^{0.75}} \quad (3)$$

(\dot{m}'' in g cm⁻²s⁻¹; d in cm; Q in cal/g.)

The rate at which heat reaches unit area of the burning liquid from the flame is Q \dot{m}'' ; the rate at which heat needs to be transferred to vaporize the fuel is λ_f \dot{m}'' . Therefore, a steady condition as expressed in equation (3) will be maintained if the spray removes from the liquid a quantity of heat γ given by

$$\gamma = (Q - \lambda_f) \dot{m}'' \quad (4)$$

Combining equations 3 and 4 gives either

$$\gamma = \frac{0.17}{d^{0.25} Q^{0.75}} (Q - \lambda_f) \quad (5)$$

or

$$\gamma = \left(\left(\frac{0.17}{d^{0.25} \dot{m}''} \right)^{1/3} - \lambda_f \right) \dot{m}'' \quad (6)$$

If the spray is capable of removing heat at a greater rate than the temperature of the fuel will be reduced. This will result in a smaller value of \dot{m}'' and a correspondingly larger value of Q and γ. The reduction in temperature will also bring about a reduction in the rate at which spray can remove heat from the fuel.

In a burning fuel in which the temperature of the fuel has reached steady conditions, Q = λ_f and γ = 0. The application of spray with a lower temperature than the fuel will therefore result in the fuel being cooled. This will continue until

Handwritten notes and corrections:

- Equation (3) is written as $\dot{m}'' = \frac{0.17}{d^{0.25} Q^{0.75}}$ with a handwritten '4' above the denominator's Q term.
- Equation (6) is written as $\gamma = \left(\left(\frac{0.17}{d^{0.25} \dot{m}''} \right)^{1/3} - \lambda_f \right) \dot{m}''$ with a handwritten '- then' next to it.
- Below equation (6), there are several crossed-out equations:
 - $\gamma = \left(\frac{Q - \lambda_f}{\lambda_f} \right) \dot{m}'' - Q$
 - $\frac{1}{Q} = \frac{Q^2}{Q} = \frac{(1 - Q^2)}{Q}$

either a steady burning condition is established at a particular temperature or one of the two following critical conditions for extinction is reached.

- 1) The value of Q may reach the maximum value, Q_c , which the flame is capable of imparting to the surface without becoming extinguished.
- 2) The value of \dot{m}'' may reach a minimum value, \dot{m}_c'' , below which a flame cannot continue to exist above the surface.

heat transfer to fuel
rate of vaporization

The rate γ_c at which the spray must abstract heat from the fuel at the particular fuel temperature at which these critical conditions occur will be given by one of the equations (5) and (6), and if Q_c and \dot{m}_c'' are assumed independent of the linear dimension of the burning surface, then γ_c will be expected to decrease slowly as this dimension increases.

By a similar argument to that developed above, it is possible to put forward equations giving γ_c for a wide range of conditions, indeed for all conditions for which there is a known relationship between the Nusselt number for heat transfer from a gas and other relevant dimensionless groups, e.g., the Reynolds, Grashof, and Prandtl numbers. By these means it may be shown that above a certain dimension of the surface γ_c will cease to decrease with increase in d , and if the wind is sufficiently strong γ_c will be proportional to the square root of the wind velocity and inversely proportional to the square root of d .

Basic Concl.
 γ_c heat from fuel by spray
Basic Concl.

A certain amount of information is available for the critical value of Q . Thus for flame quenching in channels³ and in flame arresters⁴ it has been found that for stoichiometric hydrocarbon flames the maximum amount of heat a flame can impart to a surface before it is extinguished is 23 per cent of the heat of combustion of the fuel, i.e., about 2500 cal/g. Spalding² carried out experiments on the circulation of kerosine burning on the surface of a sphere and here again it was found that the fire was extinguished when the heat transferred to the burning surface by the flame was 2500 cal/g of fuel vaporized. Spalding's experiment is analogous to extinguishing a fire by cooling with water spray, the only difference being that heat was removed by excess fuel rather than by water spray. It would be expected that the conditions under which the maximum fraction of the heat of combustion can reach the surface of the burning fuel would occur when a stoichiometric mixture burns very close to the liquid surface. The temperature of the surface should, therefore, be near to the value corresponding to equilibrium with a stoichiometric mixture. For kerosine this temperature is 15°C higher than the temperature at which the surface is in equilibrium with the lower limit mixture and is approximately equal to the fire point.

Using 2500 cal/g as the value for Q_c , the following values for γ_c may be calculated for fires burning under conditions of natural convection.

heat abstraction rate from fuel by spray

$\gamma_c = \frac{.6}{2.34}$	Pool or spill fires	$\gamma_c = 0.6/d^{0.25}$	(7)
$\gamma_c = .256 \text{ cal. cm}^{-2} \text{ sec}^{-1}$	Fires on tubes	$\gamma_c = 1.2/d^{0.25}$	(8)
	Fires on vertical surfaces	$\gamma_c = 1.2/l^{0.25}$ for $l < 100 \text{ cm}$	(9)
		$= 0.4$ for $l > 100 \text{ cm}$	(10)

γ_c is in cal/cm²/sec; d, l characteristic dimension in cm.

There is little information on the minimum value of \dot{m}'' below which a flame will not be sustained. It might be postulated that \dot{m}_c'' should be not less than the value required to sustain a lower limit flame at its appropriate burning velocity over the whole surface; this would give \dot{m}_c'' equal to about 1.5×10^{-4}

"d"
flammable liquid is harder than wood.

$\frac{0.256}{45} = .0057 \text{ gm. cm}^{-2} \text{ sec}^{-1}$
 $(.0057)(60) = .342 \text{ gm. cm}^{-2} \text{ min}^{-1}$

fig 2 shows .3 to .35 mm drop size

g/cm²/sec for fires in hydrocarbon liquids. On the other hand experiments on the extraction of heat from laminar propane-air flames⁷ indicate that a stoichiometric mixture may continue to burn close to a surface to which it is imparting heat at a rate similar to Q_c when the combustion rate is as low as 2.6×10^{-4} g/cm²/sec. The above figures for m_c are about one-tenth of the rate of combustion of pool fires under steady conditions; they imply that γ_c may depend on critical rate of vaporization when the dimension of the fire is greater than 30 cm, for fires burning in a natural draught.

The analysis so far has dealt only with burning liquids. There are difficulties in applying a similar analysis to wood. The main difficulty as far as the extinction of flaming combustion is concerned is that the heat required to produce unit mass of volatiles is not known. The slow decomposition of wood is an exothermic process, i.e., λ_r is negative, but Klason¹⁰ showed that as the rate of decomposition increases the process changes from being exothermic to endothermic. There is evidence that for the rates of decomposition required to sustain a flame over a wood surface, the decomposition is indeed highly endothermic. For the extinction of glowing combustion the analysis would have to be modified to take into account the loss of heat from the surface by radiation and the effect of surface temperature on the combustion rate.

The above considerations are concerned with the rate at which heat must be removed from the fuel in order that the fire may be extinguished by cooling the fuel. The ability of the spray to remove this heat will depend on the properties of the spray and the fuel; this aspect of the problem will be referred to when experimental results are discussed.

Extinction of the Flame

The criterion of extinction of a flame by heat abstraction inside the flame is that the combustion products as they leave the reaction zone should not exceed the temperature they would have for lower limit flames; this temperature is about 1580°K for a wide range of flammable vapours and gases. A decrease in temperature approximately to this value is obtained when extinction is obtained by adding nitrogen, water vapour, carbon dioxide, or inert dust to flames in stoichiometric mixtures.

The amount of heat which it is necessary to remove from the flame to accomplish this is the difference in heat of combustion of stoichiometric and lower limit mixtures. For most flammable organic compounds and probably also for the volatiles from some common dry woods this is about 45 per cent of the heat of combustion of the fuel. Since with diffusion flames it would be expected that there would be a zone between the fuel and the atmosphere where the stoichiometric mixture occurs, the heat which has to be removed from the flame as a whole is 45 per cent of the heat of combustion of the fuel. It is important, however, that this heat be removed either from the reactants or the reaction zone. If the heat is removed from the combustion products the heat removal will not substantially affect the temperature of the products leaving the reaction zone. In a turbulent diffusion flame it is very difficult to differentiate between the reactants, the reaction zone and the combustion products. However, it would be expected that if a spray is capable of removing all the heat of combustion from the flame, then the flame will be extinguished.

2380°F
1307 C.

2

what about dilution and chain breaking as per Ansul?

It is interesting to note that the heat removal required to extinguish the flame by cooling the flame is twice as great as the heat which an extended surface on the reactant side of the flame may abstract from the flame before the flame is extinguished. This might be explained by a different balance of heat release and heat loss rates for a vitiated flammable mixture and a stoichiometric flammable mixture close to an extended surface.⁸ Owing to the intractability of defining the position and properties of the reaction zone in a turbulent diffusion flame the approach to estimating critical conditions for extinction of the flame by water spray has been made on the basis of heat transfer taking place within the whole flame. If V is the volume of the flame, Z the mass rate of burning, and H the heat of combustion of the fuel, then I , the mean rate of the heat production per unit volume of flame, assuming complete combustion of the fuel, is $\frac{ZH}{V}$. If the capacity for heat transfer of the spray within the flame is defined as X , the rate of heat transfer per unit volume of flame to the spray, then three critical criteria for X may be put forward.

- 1) Removal of all the heat in the flame neglecting the production of steam as a result of heat transfer to the spray

$$X_1 = I \quad (11)$$

- 2) Removal of heat only from the reaction zone and the reactants, but also neglecting steam formation

$$X_2 = 0.45 I \quad (12)$$

- 3) Removal of heat only from the reaction zone and the reactants, but assuming that all the heat transfer for the drops result in steam formation. This will only be the case if the drops enter the flame at the wet bulb temperature (about 75°C). It may be assumed that the steam formed will contribute to the cooling of the flame a quantity β per unit mass of steam equal to the whole of the sensible heat of steam from 370–1580°K. The ratio of β to λ , the latent heat of steam, is 1.23. This gives

$$X_3 = \frac{\lambda}{\beta + \lambda} 0.45 I = 0.195 I \quad (13)$$

A fourth criterion may also be put forward if steam is formed outside the flame either at the burning surface or at surrounding hot bodies. Under these conditions the latent heat of vaporization does not contribute to cooling the flame but the sensible heat of steam up to 1580°K does. If the steam is formed at or sufficiently near to the burning surface to accompany the reactants into the flame then the critical flow rate, W , of water required would be

$$W = 0.45 \frac{ZH}{\beta} \quad (14)$$

If the steam is formed well away from the burning surface and is heated by the combustion products, then W may rise to values equal to $\frac{ZH}{\beta}$.

The quantity I in equations (11) through (13) is an intensity of combustion and depends on the conditions of combustion, particularly the air current in which the flame is burning. For petrol, kerosine, benzole and alcohol fires 30 cm diameter

burning under conditions of natural draught, I was found to be independent of the fuel or the rate of burning and equal to 0.45 to 0.50 cal cm²sec⁻¹.

The entrained air current in a spray not only affects the intensity of combustion but also affects the critical heat transfer rate required to extinguish flame. There is very little information to allow the assessment of this factor on a quantitative basis, but an indication of what might be expected may be obtained from work on the blowout of flame at obstacles. For example, if the assumption is made that the fundamental burning velocity of the flame decreases in proportion to the heat transfer capacity of the spray, then on the basis of relationships between the blowout velocity and the fundamental burning velocity¹⁰ it may be expected that

$$V_{BO} = a_3 - bX^{1.5} \text{ to } 2d^{0.5 \text{ to } 1} \quad (15)$$

where V_{BO} is the velocity of the entrained air current that will cause a blowout when the spray has a flame heat transfer capacity X , d is a characteristic dimension of the system and a_3 and b are constants.

It is of interest to compare critical heat transfer rates for extinction by cooling the flame and cooling the fuel. It follows from equations (11) to (14) that the critical heat transfer rate for cooling the flame is greater than 20 per cent of the total heat of combustion of the fire. Equation (4) and subsequent remarks indicate that for cooling the fuel the critical heat transfer is less than 25 per cent of the much smaller rate of combustion that would occur under critical conditions. On this basis much lower critical flow rates would be expected for extinguishing the fire by cooling the fuel than by cooling the flame. As opposed to this, however, it is feasible that unit mass of water can, under critical conditions, be the sink of a much greater amount of heat from the flame (about 1300 cal/g) than it can from a solid or liquid fuel (45 cal/g for kerosine and 750 cal/g for wood).

Experimental Investigations on the Extinction of Fire

In order to examine the relevance of the above analyses of extinction mechanism, experimental investigations have been divided into two groups covering investigations in which there is substantial evidence that extinction was by cooling the fuel and the flame, respectively. For investigations on the extinction of fires in rooms, however, there has not usually been sufficient evidence to decide on the mechanism of extinction and these investigations will be dealt with separately.


Cooling the Fuel

Critical flow rate of spray for extinction of pool fires. Evidence has been obtained from experiments with pool fires that the critical heat transfer rate for extinction of the fire by cooling the fuel is controlled mainly by convection from the flame to the liquid rather than by radiation from the flame. This evidence may be summarised briefly as follows:

- 1) With sprays at less than the critical rate a steady fire condition could be established with a temperature near the liquid surface not greatly in excess of the fire point, with a flame size very much less than the size of the flame if no spray were applied, and with the flame reaching down to the surface of the liquid.¹ In these fires the predominant mechanism of heat transfer to the fuel surface was by convection.
- 2) The effect of scale on the critical flow rate was what was expected if convection controlled the critical heat transfer rate rather than radiation.

} Basic
Concl.

The reason for the above phenomenon is that when radiation is the predominant mechanism of heat transfer from the flame to the surface, the bulk of the heat reaching the surface is taken up as latent and sensible heat of the vapour leaving the surface and does not manifest itself as sensible heat in the remaining fuel. There is thus little resistance to the cooling of the fuel by water spray. The temperature of the surface is also much higher than the fire point and the capacity of the water spray for taking up heat is correspondingly much greater. Figure 2



- (I) 30 cm diameter Kerosine fire spray applied downwards
- (II) 11 cm diameter Kerosine fire spray applied downwards
- X 30 cm diameter Kerosine fire spray applied 10° to horizontal
- 243cm diameter Kerosine fire spray applied by hand
- 30 cm diameter transformer oil fire spray applied downwards
- 243cm diameter transformer oil fire spray applied by hand

Figure 2. Critical flow rates for extinction of pool fires by cooling the liquid.

~~Handwritten scribbles~~

50% of drops < ^{mass} median size
 50% of drops > ^{mass} median size

shows critical rates to extinguish kerosine and transformer oil fires by cooling the fuel plotted against the mass median drop size for fires burning in vessels 11, 30, and 243 cm diameter. The curves for the 30 and 11 cm diameter kerosine fires were obtained by extrapolating to the fire point relationships between the flow rate of spray reaching the fuel and the resulting steady temperature near the fuel surface for sprays of different drop size; the spray was applied in a downward direction.¹¹ The curves obtained separate tests in which extinction took place by cooling from tests in which no extinction occurred. Although for both fires the critical rate was approximately proportional to the drop size, for a given drop size the rate was slightly less for the 30 cm diameter fire than for the 11 cm diameter fire. If radiation controlled the critical heat transfer rate, the critical flow rate for extinction would be expected to be 100 per cent greater for the 30 cm diameter fire but, if convection controlled, about 15 per cent smaller. The difference between the points for tests with horizontal application of spray to a kerosine fire 30 cm diameter and for hand application of spray to a fire 243 cm diameter may be accounted for by the different drop sizes of the spray. If radiation controlled the critical heat transfer rate, a ratio of 2.5 would be expected in the critical rate. After taking into account the probable effect of drop size there was in fact no difference in the critical rates. However, the critical rate for horizontal application for the 30 cm diameter fire was about half that for vertically downward application. A possible reason for this difference is that the spray pushed the flame sideways; as a result the drops did not become heated in the flame and had a greater cooling capacity when they reached the liquid.

The effect of radiation is likely to be much greater with pool fires in which the burning surface can "see" all the flame than with other fires. Since radiation from the flame of the fuel being extinguished has a minor effect on the critical rates for extinguishing pool fires by cooling, it is reasonable to neglect it for other fires.

The effect of drop size on the critical rate follows from the fact that the drops are in the liquid for only a limited time and their size is a controlling factor in the rate at which heat is transferred. It would be expected¹¹ that the heat transfer from the body of the liquid to the drops would be proportional to $D^{-1/2}$. However, the transfer of heat from the surface of the liquid to the interior would be expected to increase as the eddy conductivity caused by the turbulent eddies set up by the motion of the drops on the liquid; this is estimated to increase as $D^{1/2}$. The actual effect of drop size results from a combination of these two factors.

The driving force for heat transfer in the liquid may be represented by ΔT , the difference in temperature between the surface of the liquid under critical conditions (for practical purposes the fire point) and the temperature of the drops (for practical purposes the ambient temperature). It would, therefore, be expected that for a given drop size the critical rate should be inversely proportional to ΔT . Measurements of critical rate indicated in Figure 2 for downward application of spray to a 30 cm diameter transformer oil fire and hand application of spray to a 243 cm diameter fire support this.

Extinction Time for Pool Fires

As long as the flow rate of spray is greater than the critical value, then extinction will take place in a time which depends on the amount of heat present in the burning fuel which must be removed by the spray to reduce the surface

temperature to the fire point. With most pool fires this heat content increases as the preburn time increases up to about 10 to 20 minutes but for hot zone forming liquids, e.g., heavy fuel oils, this heat content may increase indefinitely. Experiments^{12, 13} on extinction of pool fires using fixed nozzles sited vertically above the burning liquid (see Plate 1) and for hand extinction of an 8 ft diameter fire gave the following relationships:

Fixed nozzle

$$t = 6800 (D/M)(Y/\Delta T^{1.75}) \quad (16)$$

Hand application for 8 ft diameter vessel

$$t = 121,600 D^{0.85} F_1^{-0.08} Y^{0.39} \Delta T^{-1.07} L^{-0.33} \quad (17)$$

where

- D is the mass median drop size of the spray in mm
- M is the flow rate of spray in gallons ft⁻²min⁻¹ *
- Y is the preburn time in minutes
- ΔT is the difference between fire point and ambient temperature °C
- F₁ is the total flow to the fire in gallon/min
- L is the total number of tests carried out by the operator
- t is the extinction time, sec

The influence of drop size and of flow rate of spray are as may be expected from considerations of heat transfer between the liquid and the drops. The influence of ΔT , however, is greater than may be expected from a heat transfer basis alone. A reason for this may be that the higher the value of ΔT the greater was the temperature of the surface of the liquid in excess of 100°C, particularly when application of water spray commenced, and the greater was the steam formation in the liquid during the extinction process. This steam probably accelerated the cooling of the liquid surface by stirring the bulk liquid. An increase in the preburn time increased the extinction time, although to a lesser extent for hand application than for fixed application. The experience of the operator as expressed by the factor L in equation 17 was also an important factor in the extinction of fire by hand application.

Both the equations (16) and (17) presume that the bulk of the spray reaches the burning liquid. If the downward thrust of the spray was less than the upward thrust of the flames and if the flames could burn vertically upwards against the spray, then the extinction time was prolonged. In this connection it is noteworthy that the size of the flames in the first few seconds of application were usually considerably greater than the size before application of spray, as indicated in Plate 1. This was due to the sputtering of fuel into the flame. However, for tests on fires 3 ft and 4 ft diameter in a large roofless structure, the ambient wind was usually sufficient to blow the flames away from the upright position and the force of the spray was not a significant factor in extinction of the fire, if the spray was much wider than the fire. With hand application of spray to an 8 ft diameter fire there was no difficulty in enabling even fine sprays of low thrust to reach the burning liquid, since the fire could be approached on the upwind side and the spray applied directly to the base of the flames. A complicating factor in all these tests was the occurrence of splash fires with coarse sprays; burning fuel was splashed into the flame by the spray and a vigorous flame maintained even though the liquid was cooled well below the fire point. If, when a splash fire was established, the spray were taken away the fire often went out.

* "gallon" refers to imperial gallon in this paper 1 imp. gal. = 1.2 U.S. gal.

$$1 \text{ gm.}/\text{min}/\text{cm}^2 = 0.246 \text{ gpm}/\text{ft}^2$$

$$1 \text{ gpm}/\text{ft}^2 = 4.07 \text{ gm.}/\text{min}/\text{cm}^2$$

Fires in Oil Running Over Metal Work

When sprays are applied to a pool fire which has been burning for some time, there is an initial upsurge of flame and the flames then reduce in size gradually within the extinction time. When burning liquids are flowing over a surface the liquid layer is very thin and the sensible heat in the liquid which needs to be





Plate 1. Extinction of fire in transformer oil by downward application of spray from fixed nozzle (extinction time 8.8 sec).


removed is very small. Providing the flow rate of water spray is near the critical rate the flames are reduced in size almost immediately after turning on the water spray and thereafter are reduced in size much more slowly. This is illustrated in Plate 2 which shows a fire in transformer oil flowing over a test rig consisting of a bank of tubes 5 cm diameter. The rate of flow required to extinguish the fire in a given time depended on the preburn time in this case, since during the preburn period the tubes themselves were heated and acted as a reservoir of heat during the application of spray. The effect of the temperature of the tubes on the rate



Application



5 s




30 s

Plate 2. Control of fire in transformer oil on a bank of tubes.

ABSTRACTS AND REVIEWS

of flow required to control and extinguish the fire is given in Figure 3. The relationships in Figure 3 were obtained for sprays projected directly downwards from 5 ft above the point in the tube rig where oil was injected (6 in below the top), but tests in which the sprays were projected from a similar distance from the side of the



- I No control
- II More than 50 per cent of rig cleared of flame in 30s
- III More than 50 percent chance of complete extinction in 45s
- IV Estimated certain extinction in 45s

Spray pressure 90 lbf/in²
 Drop size 0.6 – 3.0 mm
 Envelope area of rig 90 ft²
 Transformer oil—flow rate 5.25 gal/min

Figure 3. Control and extinction of oil fires on tube rig.

rig did not give significantly different results, nor was there any difference if the tube bank was horizontal rather than vertical. The drop size of the spray was found to have no significant effect in the range tested (mass median 0.6 to 3.0 mm); there was evidence, however, that an increase in drop velocity increased the efficiency of the spray¹⁴ and the effect of the drop size may have been masked by the fact that the ratio of drop size to drop velocity was constant for the sprays referred to in Figure 3. The tests covered a wide range of ambient wind conditions. However, Figure 3 indicates that the critical rate for these varying conditions increased as the temperature of the tubes increased. These critical rates may be taken as lying between curves (1) and (3) in Figure 3.

A large number of tests have been carried out in the United States in which water spray has been applied to oil fires on sheet metal structures simulating transformers.^{15, 16} A comparison between the results of these tests and those carried out on the tube rig in England has indicated that to obtain a given extinction performance under given conditions of nozzle pressure, oil fire point and preburn time, a mean flow to unit area of the envelope of the tube rig on the average 2.3 times as great as that to the large sheet metal simulated transformers was required. Equations (8) and (10) indicate that the ratios of critical heat transfer rates to the surface would be about 1.8, the expected ratio of flow rates to the envelopes of the two risks would be between 1.8 and 2.8. If the wind velocity controlled the critical heat transfer rate the expected ratio would be greater. It is unlikely that the condition for heat transfer to the drops in the oil would differ between the oil running down tubes and a vertical surface although it would be expected that the accessibility of spray to the surfaces would be easier for a flat surface than for a nest of tubes. Broadly, however, the comparison does support the theoretical approach.

Critical Rate for Extinction of a Wood Fire

Bryan¹⁷ has measured the critical rate for a wood fire consisting of 2 inch square pieces with a total surface area of 80 ft². The minimum rate at which he obtained extinction with water was 0.16 g/min corresponding to a rate of 0.01 g/cm²/min. Bryan concluded from other observations that extinction was by cooling the wood. Under the conditions he used it may be assumed that the water was entirely vaporized; this would correspond to a heat transfer of 0.1 cal/cm²/sec at the wood surface. From information on the heat of combustion of wood volatiles and assuming that critical criteria as described above may be applied to burning wood, it may be estimated that 0.8 cal/cm²/sec would have been transferred from the flame to the wood surface under critical conditions. The difference between the measured and estimated values might be taken to indicate that a substantial heat transfer, of the order of 800 cal/g, was required to cause the evolution of sufficient volatiles for combustion.

Direct Extinction of Flame

To examine the relevance of the theory developed above it is necessary to have an estimate for X, the heat transfer capacity for the sprays. These estimates were obtained using equation (18), a modification of the Ranz and Marshall

ABSTRACTS AND REVIEWS

relationship for heat transfer from gases to drops¹⁸ which was found to hold for water drops evaporating in a bunsen flame.¹⁹

$$\frac{hD}{k} = \frac{1}{1+0.4\beta/\lambda} \left[2 + 0.6 \left(\frac{c\mu}{k} \right)^{0.33} \left(\frac{V_D D \rho}{\mu} \right)^{0.5} \right] \quad (18)$$

c, μ, k, ρ specific heat, viscosity, thermal conductivity, density in boundary layer;

D drop size, V_D drop velocity relative to gas stream;

h heat transfer coefficient;

β enthalpy increase per unit mass of vapour between surface and flame temperature;

λ heat required to vaporize unit mass of the liquid.

In estimating X it was assumed that the concentration and velocity of the drops in the flame were the same as in the approaching spray, and that the contribution of the individual fractions of the different drop sizes could be added. Since the surface area of drops of size D present per unit volume of space through which the drops are passing is proportional to $M_D/V_D D$ where M_D is the flow rate per unit area, it follows from equation 18 that

$$X \propto M D_r^{-(1.5 \text{ to } 2.0)} V_r^{-(0.5 \text{ to } 1.0)} \quad (19)$$

where M is the total flow rate per unit area, D_r and V_r are a representative drop size and drop velocity.

The extinction of fire by water spray by extinguishing the flame has been studied with fires in kerosine, petrol, and benzole in a vessel 30 cm diameter.^{20, 1} Extinction of the flame differed from extinction by cooling the fuel in that there was a sudden clearance of a comparatively large volume of flame which led to extinction.

When the spray was applied in a downward direction the flames of the petrol and kerosine fires were not extinguished unless the downward thrust of the spray was greater than 60 and 40 dynes/cm², respectively. These forces are comparable with the upward force of the flames before the spray was applied. With sprays of greater downward force the flames were extinguished as long as the heat transfer capacity of the spray was greater than about 0.15 cal/cm²/sec, and as long as the preburn time was not very short. The above value is intermediate between those expected from equations (12) and (13), if I is taken to refer to the upward moving flames before spray application.

For a given type of spray the most important factor in the heat transfer capacity is the drop size of the spray (equation (19)) and in the thrust of the spray the rate of flow per unit area of the fire. If the drop size of the spray is plotted against the critical rate of flow for extinction at that drop size, the above phenomenon of critical thrust manifests itself as a flow rate below which the fire is difficult to extinguish with sprays of any drop size. Critical flow rates for extinction of a flame have been plotted in this way in Figure 4 for the kerosine and petrol fires; points for extinction and nonextinction are shown for the petrol fire. For comparison critical flow rates for the extinction of the kerosine fire by cooling the liquid have been included. Similar relationships obtained by the author for sprays produced by hypodermic needles acting on a kerosine fire 11 cm diameter,²¹ and by the National Board of Fire Underwriters for sprays acting on a petrol fire 15 cm diameter²² have been given elsewhere. The critical flow rate below which extinction was difficult was smaller in both cases than those shown in Figure 4

for the 30 cm diameter fires. This may be mainly attributed to the smaller dimension of the fires and the resulting smaller upward force of the flames, but different conditions of test and different patterns of spray at the fire area also probably played a part. Extinction of the flame has been found to be easier if the peak concentration of the spray is near or even outside the edge of the vessel,




Figure 4. Critical flow rates for extinction of kerosine and petrol fires 30 cm diameter, downward application of spray.

since after a clearance of part of the flame, the remnants of flame from which a flash back may occur are at the edge.²⁰ This phenomenon may account also for comparatively low flow rates for extinction of flame reported by Y. Yazici.²³

During the tests the flames were usually wild with frequent partial clearance and flash backs. However, with petrol and benzole fires when the preburn time was very short (less than 10 sec) and when sprays with high downward thrust were used, the spray pushed the flame immediately into a flat flame close to the liquid surface which was very difficult to extinguish. The appearance of the flame

depended on the drop size and heat transfer capacity of the spray. A spray with a value of X equal to $0.44 \text{ cal/cm}^3/\text{sec}$ gave thin blue flames near the inside edge of the vessel; with a value of X of $0.14 \text{ cal/cm}^3/\text{sec}$, a belt of yellow flame covered the whole vessel. Flames stabilized close to the liquid surface were also obtained if spray were applied to the surface at an angle less than 30° to the horizontal. It was estimated that the value of I for flames stabilized in this way was about $2.5 \text{ cal/cm}^3/\text{sec}$. It would, therefore, be expected that value of X equal to about 0.5 to $1 \text{ cal/cm}^3/\text{sec}$ would have been required to extinguish these flames reliably.

Regression analyses on the extinction time for the kerosine and petrol fires²⁰ indicated that for sprays with a given value of X the entrained air current had a powerful effect on the extinction time. This effect was much more powerful than might be expected from a relation such as is given in equation (15). This may be attributed to two reasons. Firstly, the entrained air current helped to present the spray to all parts of the flame; associated with this reason it also helped the spray penetrate to the burning liquid, cooling the latter and thus reducing the size of the flame. Secondly, the entrained air current tended to blow away the thick vapour zone which was usually established after burning for about 10 seconds and thus rendered the flames unstable.

Extinction of Fires in Rooms

Tests have been carried out by many authorities on the extinction of solid fuel fires in rooms. It is not yet clear, however, whether these fires are more efficiently controlled by cooling of the fuel or by the formation of steam which cools the flames.

Kawagoe²⁴ has found that the rate of burning in room fires is, on the average, directly proportional to the ventilation, and the constant of proportionality indicates that the ratio of air to fuel volatiles is the stoichiometric ratio. When fires in rooms are attacked with sprays from an opening in the wall, then additional air would be entrained into the room comparable with the normal ventilation rate through the opening. Under these conditions it may, therefore, be expected that the fire is burning with excess air when extinction is commenced. The critical amount of steam required to smother the flames would then be governed by equation (14). It may be estimated using equation 14 that if steam is obtained by the impact of spray on the burning surface, the critical flow rate of water to form sufficient steam to extinguish the flames is 10 to 15 times greater than that found by Bryan¹⁷ to be necessary to extinguish a wood fire by cooling. However, conditions in practical fire fighting may still frequently be such that steam extinction would require the use of a smaller total quantity of water.

From the intrinsic nature of extinction of the flame by steam and extinction by cooling the fuel, the qualitative effect of various factors on the efficiency of control (i.e., critical flow rate and quantity of water required) may be deduced. These effects are compared in Table 1.

Available test results have been summarised by Hird *et al.*²⁵ but owing to the lack of a systematic investigation of the above factors, at least on the full scale, it is not possible to give a firm opinion on the extinction mechanism. The amounts of water used to control the fires varied from 2 to 15 gal/1000 ft³. The above workers also carried out a comprehensive series of tests in which sprays of varying pressures from 80 to 500 lb/in² and with flow rates from 5 to 25 gal/

min were used against a standard fully developed fire in a room of volume 1750 ft³. The quantity of water required to control and extinguish the fire was 7 and 17 gallons, respectively, and within the variance of the results, was independent of the pressure, the flow rate and whether jets or sprays were used.

TABLE 1
EFFECT OF VARIOUS FACTORS ON CONTROL OF ROOM FIRES
BY COOLING AND BY STEAM FORMATION

Factor	Cooling the Fuel	Steam Formation
1. Increase in preburn time.	Critical flow rate increased somewhat. Quantity increased approximately in proportion to preburn time.	No effect.
2. Decrease in ease of access of water spray to burning surfaces.	Quantity increased.	No substantial effect if walls are hot.
3. Increase in the fraction of incombustible surface present; total area of combustibles remaining the same.	Critical flow rate increased (due to radiant heat falling onto burning surfaces).	No substantial effect if incombustible surfaces are hot.
4. Increase in ventilation.	No effect.	Critical flow rate and quantity increased.
5. Linear dimension d.	Critical rate proportional to d ² .	Critical rate proportional to d ^{5/2} .

Use of Water Sprays in Practical Fire Fighting

The following broad principles may be put forward on the basis of the experimental work carried out at the Joint Fire Research Organization and elsewhere.

1) In general the best way of putting a fire out is that spray should be made to reach and cool the burning fuel. The rate at which the spray need absorb heat in doing this is generally far less than the rate of production of heat by the fire. Experimental results are available giving information on critical rates for a few systems. On the basis of equations (7) to (10) or other relationships developed in similar manner, it is possible to extrapolate these results to other systems as long as heat transfer between the spray drops and the fuel behaves in a similar way. Perhaps the most important consequence of equations (7) to (10) is that critical flow rates per unit area for a given type of system should not increase as the scale increases; under some conditions they may in fact decrease.

2) If sprays are applied downwards to a fire with a flame moving steadily upwards, then for the bulk of the water to reach the burning fuel the downward thrust of the spray should be comparable to the upward thrust of the flame. These two thrusts may be calculated as indicated in the paper. If the sprays are applied laterally or by hand from the windward side of a fire, a much smaller thrust is necessary.

3) Water sprays in current use are unreliable in extinguishing a fire that cannot be extinguished by cooling the fuel. However, extinction may frequently be obtained with available fire sprays produced by pressure nozzles (mass median

ABSTRACTS AND REVIEWS

drop size 0.2–0.4 mm) particularly if there is no change to stable burning in the air current of the spray. When extinction is not obtained, a large reduction in the size of flame may be achieved.

4) For most of the fires for which water sprays are useful, e.g., fires in solids and fires in high boiling liquids flowing over solid surfaces, the drop size of the spray is not usually an important practical factor. However, for fires in deep pools of high boiling liquids the efficiency of the spray increases as the drop size is reduced.

5) The pressure at a nozzle influences a number of factors that affect the extinction of fire. However, where sprays may be reliably used for extinction of fire, an increase in pressure about 100 lb/in² with a given flow rate of spray has not been found to confer any extra efficiency on the spray, providing that the water can reach the seat of the fire. The choice of pressure for a pump, therefore, depends rather on operational factors, in particular the length and diameter of hose line and the flow rate which it is desired to give the operator, than on intrinsic efficiency of the spray in fighting the fire. It should be added here that an increase in flow rate, or a decrease in cone angle, has a greater effect on increasing the throw of a spray^{26, 27} than an increase in pressure, and that an increase in pressure has a smaller effect on reducing the drop size of a spray when the pressure is above 100 lb/in² than when it is below 100 lb/in².

Finally, it is instructive to compare quantities of water which have been found necessary to extinguish experimental fires with those actually used in practical fire fighting. For fires in rooms it has been found experimentally that about 10 gallons per 100 ft² of floor area is required and, according to the drop size of the spray, from 5 to 15 gallons may be used to extinguish a gas oil pool fire of the same size. According to information provided by Mobius²⁸ the minimum quantity of water to extinguish fully developed room fires under operational conditions is about 100 gallons. Thomas²⁹ made an analysis of the amount of water used at large fires based on the number of pumps called to the fire. It may be estimated from this analysis that for large fires approximately 1000 gallons of water are used for 100 ft² of the fire. Thus, either wastage or operational difficulties in applying water to fires is by far the most important factor governing the amount of water used, and this would appear to be a direction where a substantial research effort is worthwhile.

APPENDIX

Thrust of Flames and Sprays


Thrust of Flames

A complete analysis of the movement of flame has not yet been made, but as this movement is controlled by the buoyancy of the flame, it would be expected that the upward thrust would be proportional to the flame height. Analysis of buoyant columns rising from small heat sources indicate^{30, 31} that the thrust at the centre of the column is given by

$$\rho_z V_z^2 = 1.5 \text{ to } 2.0(\rho_0 - \rho_z)gz \quad (20)$$

where ρ_z is the density of the column at a point z above the source and ρ_0 is the density of the ambient air.

In Figure 5 some calculated thrusts based on measurements of the upward velocity of flames and the flame temperature⁹ are plotted against the buoyancy



N.B. x refers to the height in the flame at which v_f was measured and not maximum height of flame.

Figure 5. Relation between upward thrust of flames and buoyancy head—freely burning liquid fires 30 cm diameter.

head $(\rho_0 - \rho_f)gx$ for fires in different liquids burning in a vessel 30 cm diameter; ρ_f is the density of the flame and x the height of the point in the flame for which the thrust was estimated. The velocity measurements were made by observing the upward motion of the top of the flame and eddies at the side of the flame as recorded by a cine camera; the calculation of the thrust was made for the mean

ABSTRACTS AND REVIEWS

time of burning and the mean height of the flame at which measurements were made. The temperature on which ρ_r was based was a mean temperature across the flame as measured by the Schmidt method. The straight line relation (equation 21) obtained

$$\rho_r v_r^2 = 0.27(\rho_o - \rho_r)gx \quad (21)$$

confirms the proportionality expected and indicates that thrust is independent of the nature of the burning fuel. The constant, however, is considerably less than would be expected from equation (20).

On the basis of equation (21) it is possible to calculate the upward thrust of the flame knowing the flame heights. The latter has been related by Thomas to the rate of burning and the main dimension of the fuel layer for solid fuel fires.³²

Thrust of a Spray

A spray after leaving a nozzle very soon becomes a suspension of drops moving in an air stream. The air stream is generated by the transfer of momentum from the drops and is of importance in determining the velocity of the drops and the motion of the spray as a whole. The total forward thrust of a spray may be measured by the reaction at the nozzle. Measurements of the entrained air current of sprays directed downward from a number of nozzles³³ have shown that for sprays of mass median drop size less than 1.0 mm, the bulk of the thrust is transferred into momentum of the airstream by the time the spray has reached a plane 6 ft below the nozzle; most of the remaining thrust may be accounted for by momentum of the drops moving at the velocity of the air stream. For very coarse sprays (mass median drop size 1.5–3.5 mm) about 50 per cent of the initial thrust is converted into momentum of the air current.


The reaction of a jet is the product of the flow rate and the velocity at the nozzle, both these factors being proportional to the square root of the pressure. The reaction of a spray nozzle, however, is less than the product mentioned above due mainly to the presence of lateral motion in the spray. Figure 6 shows the ratios of the reaction of a number of spray nozzles to that of corresponding perfect jets and indicates the extent to which the reaction is reduced as the cone angle increases and as the spray pattern becomes less peaked in the centre. Knowing the reaction at the nozzle, an approximate estimate of the mean forward thrust in a plane is given by R/A , where A is the cross-sectional area of the spray in the plane, and if the assumption is also made that the thrust has been entirely converted into movement of the entrained air stream then the air velocity v_n may be given by:—

$$\rho_o v_n^2 = \frac{R}{A} = a_1 \rho^{0.5} \frac{F}{A} \quad (22)$$

where

- a_1 is a constant depending on the nozzle
- P is the nozzle pressure
- F is the flow rate

Equation (22) gives, of course, a mean value of v_n . There is evidence, however, that the distribution of entrained air velocity in a plane perpendicular to the spray axis, when both entrained air velocity and distance from the axis are expressed in dimensionless terms, is approximately independent of the distribution of flow rate within the spray. In addition the distribution of the entrained air



* N.B. Fig.7 gives pattern of a spray falling into this category

Figure 6. Reaction of spray nozzles.

velocity is similar to the distribution found in a turbulent air jet. These points are illustrated in Figure 7 which shows an almost identical distribution of the entrained air for sprays with widely different spray pattern. The radii of the sprays referred to in this figure are those radii where the entrained air velocity and water flow rate were respectively $\frac{1}{100}$ of the values in the centre of the spray.

For sprays with a similar pattern over a given area it follows from equation 22 that for a given part of the spray

$$v_n \propto P^{0.25} M^{0.5} \tag{23}$$




Figure 7. Comparison of distribution of entrained air current and water flow in sprays from given nozzles.

where M is the local flow rate per unit area. A relation similar to this has been found to hold for a wide range of values of P and M for sprays projected downward from a battery of impinging jet nozzles.²⁰

Symbols

a_1, a_2, a_3, b	Constants
c	Specific heat in gas boundary layer
d	Linear dimension
g	Acceleration due to gravity
h	Heat transfer coefficient
k	Thermal conductivity
l	Linear dimension
M_{og}	Concentration of oxygen in the air
\dot{m}''	Rate of burning per unit area per unit time
r	Stoichiometric ratio (weight of air/weight of fuel)
t	Time
v_n, v_D, v_{BO}	Velocity of entrained air, of spray drops, and velocity to blow out flame
v_f, v_x	Upward velocity in flame, in buoyant hot column
x	Height of flame
z	Height of buoyant column
A	Cross sectional area of spray
B	Transfer number (after Spalding)
D	Drop size
F	Total flow rate of spray
H	Heat of combustion
I	Intensity of combustion in flame
M, M_D	Total flow rate of spray per unit area, flow rate of drop size D
L	Number of tests carried out by operator
P	Pressure to produce spray with pressure nozzles
Q, Q_c	Heat transfer to fuel surface per unit mass of fuel vaporized, critical value of Q
R	Reaction of nozzle
T_g, T_s	Gas temperature, surface temperature
ΔT	Difference in temperature between fire point and ambient
V	Volume of flame
W	Critical flow rate of water to extinguish flame by steam formation
X_1, X_2, X_3	Critical values of X
X	Heat transfer to spray within unit volume of flame in unit time
Y	Preburn time
Z	Rate of fuel consumption in fire
α	Thermal diffusivity
β	Sensible heat of steam or vapour
γ	Heat taken up as sensible heat in fuel per unit area of surface per unit time
λ, λ_f	Heat required to vaporize unit mass of liquid, of fuel
μ	Viscosity in boundary layer
$\rho, \rho_f, \rho_o, \rho_2$	Density in boundary layer, in flame, ambient air, in buoyant column
T_c	Thrust of spray
γ_c	Critical value of γ

ABSTRACTS AND REVIEWS

References

1. Rashbash, D. J. and Rogowski, Z. W. Department of Scientific and Industrial Research and Fire Offices' Committee *Joint Fire Research Organization F.R. Note No. 58* (1953)
2. Spalding, D. B. *Fourth (International) Symposium on Combustion*, p. 847 (1952)
3. Potter, A. E. and Berlad, A. L. *Sixth (International) Symposium on Combustion*, p. 27 (1956)
4. Palmer, K. N. *Seventh (International) Symposium on Combustion*, p. 497 (1958)
5. Botha, J. P. and Spalding, D. B. *Proceedings of the Royal Society* 225, p. 71 (1954)
6. Klason, P. *Praktische Chemie* 90, 413 (1914)
7. Burgoyne, J. H. and Richardson, J. F. *Fuel* 28, 150 (1949)
8. Berland, A. L. and Yang, C. H. *Combustion and Flame* 4, 325 (1960)
9. Rashbash, D. J., Rogowski, Z. W., and Stark, G. W. V. *Fuel* 35, 94 (1956)
10. Spalding, D. B. *Some Fundamentals on Combustion*, Butterworths, London p. 192 (1955)
11. Rashbash, D. J. *F. R. Note 290* (1957) (See reference 1)
12. Rashbash, D. J. and Rogowski, Z. W. *Combustion and Flame* 1, 453 (1957)
13. Rashbash, D. J. and Stark, G. W. V. *F. R. Note 304* (1959) (See reference 1)
14. Rashbash, D. J. and Stark, G. W. V. *F. R. Note No. 303* (See reference 1)
15. *Factory Mutual Laboratories Research Project 12549* (1954)
16. Automatic Sprinkler Corporation of America. Transformer Fire Protection Programme.
17. Bryan, J. *Engineering* 159, 457 (1945)
18. Ranz, W. E. and Marshall, W. R. *Chemical Engineering Progress* 48, 141-146 and 173-180 (1952)
19. Rashbash, D. J. and Stark, G. W. V. *F. R. Note No. 26* (1952) (See reference 1)
20. Rashbash, D. J., Rogowski, Z. W., and Stark, G. W. V. *Combustion and Flame* 4, 223 (1960)
21. *Annual Report, Joint Fire Research Organization, 1950* Her Majesty's Stationery Office
22. *National Board Fire Underwriters Research Report No. 10* (1955)
23. Yazi, Y. *Bulletin of Fire Prevention Society of Japan* 9, No. 2, 58 (1960)
24. Kawagoe, K. *Building Research Institute of Japan Research Report No. 27* (1958)
- 25. Hird, D., Pickard, R. W., Fittes, D. W., and Nash, P. *F. R. Note No. 388* (See reference 1)
- 26. Rashbash, D. J. *F. R. Note 181* (1955) (See reference 1)
- 27. Thomas, P. H. and Smart, P. M. T. *F. R. Note No. 168* (1955) (See reference 1)
- 28. Mobius, K. *V.F.D.B.* 5, 33-42 (1956)
29. Thomas, P. H. *Quarterly Journal Institute Fire Engineers* 19, 130-132 (1959)
30. Yokoi, S. *Report of Building Research Institute of Japan No. 34* (November 1960)
31. Yih, C. S. *Proceedings First U. S. National Congress Applied Mechanics*, 941-947 (1952)
32. Thomas, P. H. *Combustion and Flame* 4, 381 (1960)
33. Rashbash, D. J. and Stark, G. W. V. *F. R. Note No. 445* (1960) (See reference 1)
34. Goldstein, S. *Modern Developments in Fluid Dynamics*, Clarendon Press, p. 596 (1952)

The work described in this paper forms part of the program of the Joint Fire Research Organization of the Department of Scientific and Industrial Research and Fire Offices' Committee; the paper is published by permission of the Director of Fire Research. The author would like to express his thanks to Dr. F. E. T. Kingman for advice and criticism in the preparation of the paper.

Basic Conclusions of Roshko paper.

Liq. pool fires


must be heat transfer from flame to liq.
⇒ vaporization sufficient to sustain Comb.

Radiation predominates in lg. pool fires. As containers get larger, hot container walls giving heat as ~~Radiation~~ convection + conduction mean less and less.


PG 30 But [→] As you cool, convection takes over ??
↳ middle last #

PG 32

$$\gamma_c \propto \frac{\sqrt{v_w}}{\sqrt{d}}$$



recall, "wind isn't sufficiently strong" to affect



PG. 32. 23%

can perform heat balance of flame
 heat goes: back to fuel
 up hot gas col.
 radiates
 etc.

eg. 7, 8, 9, + 10 ~~should be~~

→ remember where + what they are.

PG. 35 Item #1, cooling the fuel.

German Paper-Redusch Water Drops

Eq. 9



Says: .35 mm most favorable drop size.

Compares well with eq. # 7 of Raebach.

↳ Fig. # 2 giving .345 mm.

Also NBFU came up with .3 mm.

→ read
Cn A - hydraul. calc. of Sph. sys.
+ ditto - Intro. to Hyd. of Sph. sys.
↳ look over



All of energy after pt 2.
will be expended, completely
into velocity head out of
orifice # 1.

e.g. assign 15 gpm from # 1
find it would take certain pressure to
get 15 gpm. e.g. ≈ 18.48 ft water.

Assign Q_1

$$H_1 = 18.48' = \text{TOTAL HEAD from table}$$

$$h_{f_{2-1}}$$

$$H_2 = H_1 + h_{f_{2-1}} + Z$$

h_{n_2} = head causing flow at 2 = (static pressure head)
also = h_p

$$h_{n_2} = H_2 - h_{v_{2-1}}$$

later notation

Eq. 3

$$H_3 = \underbrace{h_{n_2} + h_{v_{3-2}}}_{\text{}} + h_{f_{3-2}} + z_{3-2} \text{ ~~TTTTT~~}$$

$$h_{n_3} = H_3 - h_{v_{4-3}}$$

~~#~~ To find pressure head @ 9

$$\text{TOTAL HEAD} = H(9) = 76.74'$$



$$\#41 \quad h_v(9-7) = 5.89'$$

$$\therefore h_p(9) = 76.74' - 5.89'$$

Problem

1. Br. Line
Ord. Haz. schedule for pipe
8 heads
 $Z = 0$
 $L = 10 \text{ } \phi \text{ to } \phi.$
 $Q_1 = 30$

$$Q = k \sqrt{h}$$



if (1) + (2) are two different conditions

$$Q(q)_1 = K(q)_1 \sqrt{h_p(q)_1}$$

$$Q(q)_2 = K(q)_2 \sqrt{h_p(q)_2}$$

$$\frac{Q(q)_2}{Q(q)_1} = \frac{K(q)_2 \sqrt{h_p(q)_2}}{K(q)_1 \sqrt{h_p(q)_1}}$$

$$K(q)_2 = K(q)_1 = 24.3$$

$$K = \frac{Q}{\sqrt{h}} = \frac{\text{gpm}}{(F_T)_{h_0}^{1/2}}$$

Say we know from calculation of sample problem #5 $K = \frac{204.36}{\sqrt{70.85}} = \frac{Q_q \text{ (Total)}}{\sqrt{P_g}}$

$$K = 24.3$$


Can find out values of Q (demand) for different supply pressures.

can calculate K or use Ratio

$$\sqrt{\frac{157.29}{70.85}} \approx 1.5$$

note $\frac{30}{20} \approx 1.5$ also

\therefore can apply ratio to each sprinkler - don't have to recalculate for each cond.



$$Q_1 + Q_2 + Q_3 + Q_4 + Q_5 + Q_6 + Q_7 + Q_8 + Q_9 = Q_9$$

$$\text{or } 1.5(Q_1 + Q_2 + Q_3 + Q_4 + Q_5 + Q_6 + Q_7 + Q_8) = Q_9 (1.5)$$

$$\frac{Q_{9(2)}}{Q_{9(1)}} = 1.5$$

(the K remains const. + cancels)

But Can't change physical PIPING

Can use pieces of an already calculated line for other lines to same time.

PROBLEM #2

Same 8 hd. hr. line.

20 gpm @ sph. #1.

slope positive @ 30°
(pushing water uphill)

PROBLEM #3

$Q_1 = 15 \text{ gpm.}$

@ 10° slope. positive

$Q = K\sqrt{h}$ may be used on all - HORIZONTAL lines (no slope) or on lines with insignificant slope.

① Orifices Equation

$$Q_{\text{gpm}} = \frac{29.83}{\sqrt{2.31}} C_d d^2 \sqrt{h_h} \quad \swarrow 19.54$$

$$Q_{\text{gpm}} = K_{\text{orifice}} \sqrt{h_h}$$

h_h = head causing flow

② Velocity Head.

$$h_{v, \text{ft.}} = \frac{Q_{\text{gpm}}^2}{3850^4}$$

$$Q^2 = 3850^4 h_v$$

$$Q = \underbrace{\sqrt{3850^4}}_{K_v} \sqrt{h_v}$$

③ Friction Loss:

$$h_f = f \frac{L}{D} h_v$$

$$h_f = f \frac{L}{D} \left(\frac{Q^2}{3850^4} \right)$$

$$Q^2 = \frac{385 D^4}{f \left(\frac{L}{D}\right)} h_f$$

$$Q = \underbrace{\sqrt{\frac{385 D^4}{f \left(\frac{L}{D}\right)}}}_{K_f} \sqrt{h_f}$$

④ ELEVATION HEAD


~~Flow~~ →


$Z_{ft} \propto$ change in elevation

Does NOT follow the general law as do other pressure calculations.

$$Q = K \sqrt{h}$$

Ordinary drainage requirements are not significant slopes.





$$H_2 = hf(2-1) + Z_{(2-1)}$$

Z is here

$$h_{m2} = H_2 - (H_v(2-1))$$

this accumulates all the way down the line.

PROBLEMS MON.

DUE

Do the

8 head in line with $Q_1 = 15$ 0° slope

apply ratios

Problem #4 →

Problem #5 →

Problem #6 →

$Q_1 = 15$ 20° slope.


$Q_1 = 15$ 30° slope.

FPE 420

Problem #7 10° neg. slope. } $15 \text{ gpm} = Q_l$
 Problem #8 20° neg. slope }

Flow from sloping Branch line

Same Length of line



Subscript l refers to level line
 " ~~s~~ " " sloping "

$$\Delta Q = Q_s - Q_l$$

$$\Delta H = H_s - H_l$$

$$\frac{\Delta Q}{Q_l} = \frac{Q_s - Q_l}{Q_l} = \left(\frac{Q_s}{Q_l} - 1 \right)$$

$$\frac{\Delta H}{H_l} = \frac{H_s - H_l}{H_l} = \left(\frac{H_s}{H_l} - 1 \right)$$

$$Q_s = \left[1 + \left(\frac{\Delta Q}{Q_l} \right) \right] Q_l$$

$$H_s = \left[1 + \left(\frac{\Delta H}{H_l} \right) \right] H_l$$

$$K_l = \frac{Q_l}{\sqrt{H_l}}$$

$$K_e = \frac{\sqrt{\left[1 + \left(\frac{\Delta H}{H_s}\right)\right]}}{\left[1 + \left(\frac{\Delta Q}{Q_s}\right)\right]} \cdot \frac{Q_s}{\sqrt{H_s}} = \frac{1}{C} \cdot \frac{Q_s}{\sqrt{H_s}}$$

$$Q_s = C K_e \sqrt{H_s}$$

~ Knowing $Q_s + H_s + K_e$ from problems,
find values of C ~

$$Q_s = CK_e \sqrt{H_s}$$

Slope

$$C = \frac{Q_s}{K_e \sqrt{H_s}}$$

$$K_e = 23.28$$

0	1.000
5	0.970
10	0.947
15	0.929
20	0.914
25	0.903
30	0.892

$$Q_s = CK_e \sqrt{H_s}$$


	5°	10°
$\frac{H_s(9)}{H_x(9)}$	1.189	1.37

$\frac{Q_s(9)}{Q_x(9)}$	1.060	1.111
-------------------------	-------	-------

It can be seen that
slope makes big difference.

modified Pipe Schedule

→ changed his length



Problem

9 $Q_1 = 15 \text{ gpm}$

0° slope

10 $Q_1 = 15 \text{ gpm}$


20° positive slope

Pg. 6 Ditto sheet Example # 2

line 9 from Bottom

$H(9) \Rightarrow$ should be $h_p(9)$

86 should be 70.5 feet of H_2O



Calculate A+B & find $h_p(9)_A \neq h_p(9)_B$

\therefore hold $h_p(9)_A$ const + adjust B

$\Rightarrow h_p(9)_B = h_p(9)_A$ which MUST BE

GET:

$Q(9)_A$

$Q(9)_B$

$$Q_{RN} = Q(9)_A + Q(9)_B$$

corrected

$$Q(9)_A = 209.7$$

$$h_p(9)_A = 70.85$$

spacing
10


Extra Hazard pipe Schedule
problem # 11 $Q_1 = 15 \text{ gpm}$ 0° slope
problem # 12 $Q_2 = 15 \text{ gpm}$ $20^\circ +$ slope

~~XXXXXXXXXX~~


Joining Branch Lines

Pg. 6 of Ditto

(make connections given in last class)



may want to
re design for
better Balance.



can find $Q + H(TOTAL) +$ find K value at this point

$$K = \frac{Q}{\sqrt{H}}$$

If K is same @ bottom of each river nipple - calculate Cross Main just as branch line -

get $h_{L2} + Q_2 = K \sqrt{h_{L2}}$

Go over pg. 7
also connections

Item 23 - mult. 14.13 by 2 since there are 2 tees

Item 35 - $198.34 = 212.47$
 \uparrow should be

Bottom $85.9 \text{ mm} = 92$

$$\frac{212.47 - 3.10}{2.31} = \frac{209.37}{2.31} \approx 90.6$$

Pg. 8 add.


$$H = \text{Total head} = h_p + z + h_v$$

$$N_R = LV/\nu$$

ν = kinematic viscosity (last item)

ϵ = roughness factor

PROBLEM # 13



- Determine
1. total flow rate
 2. total head at point 12
 3. K_{12} value


$$h_f(\text{fittings}) = k h_v$$

\uparrow
 fittings
 resistance
 coeff.

\uparrow
 no. of fittings
 upstream


k 's are listed in hydraulic data manual
 table 32a. pg 28
 Use Inlet diameter + Inlet Velocity

$\sqrt{150.18}$
 $\sqrt{305.18}$
 $\sqrt{410}$




No.	SEQUENCE OF CALCULATIONS		Individual Flow G.P.M.	Total Flow G.P.M.
1	H(1) = hn(1)	65.00		
2	hf(2-1).....(10 Ft. 1 In. Pipe) +(.565)	5.65	Q(1) 30.00	30.00
3	Z (2-1).....+	0.00		
4	H(2)	70.65		
5	hv(2-1).....(1 In. Pipe)	- 1.92		
6	hn(2)	68.70	Q(2) 30.40	60.40
7	hf(3-2).....(1 In. Pipe).....+	7.90	32.6	35.7
8	hf(3-2).....(10 Ft. 1 In. Pipe) +(.216)	27.60	33.8	35.6
9	Z (3-2)	0.00	34.7	35.6
10	H(3)	98.20	35.0	95.4
11	hf(4-3) T.&E. (1/2 In. Pipe)	6.50		
12	hn(3)	91.70	Q(3) 35.00	95.40
13	H(3) From Above	98.20	34.6	37.7
14	hf(4-3) ... (10 Ft. 1/2 In. Pipe) +(.131)	13.10	36.6	37.8
15	Z (4-3)	0.00	37.6	37.8
16	H(4)	111.30	37.8	133.00
17	hf(5-4) T.&E. (1/2 In. Pipe)	6.90		
18	hn(4)	104.40	Q(4) 37.80	133.20
19	H(4) From Above	111.30	39.8	41.5
20	hf(5-4) ... (10 Ft. 1/2 In. Pipe) +(.113)	11.30	41.3	37.0
21	Z (5-4)	0.00	39.0	38.8
22	H(5)	122.60	38.9	172.1
23	hf(6-5) T.&E. (1/2 In. Pipe)	11.90		
24	hn(5)	111.30	Q(5) 38.8	172.0
25	H(5) From Above	122.60	40.0	43.0
26	hf(6-5) .. (10 Ft. 1/2 In. Pipe) +.155	18.90	42.0	42.9
27	Z (6-5)	0.00	42.9	42.9
28	H(6)	141.50		
29	hf(7-6) T.&E. (2 In. Pipe)	6.60		
30	hn(6)	134.90	Q(6) 42.9	214.9
31	H(6) From Above	141.50	44.1	43.5
32	hf(7-6) .. (10 Ft. 2 In. Pipe) +	7.90	43.4	
33	Z (7-6)	0.00		
34	H(7)	149.40		
35	hf(8-7) T.&E. (2 In. Pipe)	9.50		
36	hn(7)	139.90	Q(7) 43.5	258.4
37	H(7) From Above	149.40	44.2	45.0
38	hf(8-7) ... (10 Ft. 2 In. Pipe) +	11.20	44.6	
39	Z (8-7)	0.00	44.8	
40	H(8)	160.60		
41	hf(9-8) T.&E. (2 In. Pipe)	13.00		
42	hn(8)	147.60	Q(8) 44.8	303.2
43	H(8) From Above	160.60		
44	hf(9-8) (5 Ft. 2 In. Pipe) +(.151)	7.55		
45	Z (9-8)	0.00		
46	H(9)	168.15		
47	hf(10-9) T.&E. (In. Pipe)	13.50		
48	hn(9)	154.65	Q(9) 44.8	303.2
49	hn ()			
50	hf ()			
51	Z ()			
52	hf ()			
53	H ()			

11-7-55 W.G.L.



No.	SEQUENCE OF CALCULATIONS	Individual Flow G.P.M.	Total Flow G.P.M.
1	H(1) = hn(1) 29.54	Q(1) 20.00	20.00
2	hf(2-1).....(10 Ft. 1 In. Pipe) + 2.55		
3	Z (2-1).....+ 5.00		
4	H(2) 37.09		
5	hv(2-1).....(1 In. Pipe)- 0.85		
6	hn(2) 36.24	Q(2) 22.25	42.25
7	hf(3-2).....(1 In. Pipe).....+ 3.85	25	67.25
8	hf(3-2).....(10 Ft. 1 In. Pipe) + 10.80	26.6	68.85
9	Z (3-2)+ 5.00		
10	H(3) 53.89		
11	hv(4-3) T.&E. (1/4 In. Pipe)- 3.35		
12	hn(3) 52.54	Q(3) 26.60	68.85
13	H(3) From Above 55.89	28.15	97.00
14	hf(4-3) ... (10 Ft. 1/2 In. Pipe).+ 7.00	29.70	
15	Z (4-3)+ 5.00		
16	H(4) 67.89		
17	hv(5-4) T.&E. (1/2 In. Pipe)- 3.79		
18	hn(4) 64.10	Q(4) 29.70	98.55
19	H(4) From Above 67.89	81.50	129.55
20	hf(5-4) ... (10 Ft. 1/2 In. Pipe)+ 6.30	31.30	31.3
21	Z (5-4)+ 5.00		
22	H(5) 79.19		
23	hv(6-5) T.&E. (1/2 In. Pipe)- 6.50		
24	hn(5) 72.69	Q(5) 31.30	160.85
25	H(5) From Above 79.19	36	196.85
26	hf(6-5)..(10 Ft. 1/2 In. Pipe)+ 17.80	36.1	
27	Z (6-5)+ 5.00		
28	H (6) 101.99		
29	hv(7-6)T.&E. (2 In. Pipe)- 5.50		
30	hn(6) 96.49	Q(6) 36.1	196.95
31	H(6) From Above 101.99	38	134.95
32	hf(7-6)..(10 Ft. 2 In. Pipe)+ 6.65	38.8	
33	Z (7-6)+ 5.00		
34	H(7) 113.64		
35	hv(8-7) T.&E. (2 In. Pipe)- 2.82		
36	hn(7) 110.82	Q(7) 38.8	135.75
37	H(7) From Above 113.64	40.25	176.00
38	hf(8-7) ..(10 Ft. 2 In. Pipe)+ 3.28	40.00	175.75
39	Z (8-7)+ 5.00		
40	H(8) 121.92		
41	hv(9-8) T.&E.(2 In. Pipe)- 4.40		
42	hn(8) 117.52	Q(8) 40.00	175.75
43	H(8) From Above 121.92		239.10
44	hf(9-8)(5 Ft. 2" In. Pipe)+ 2.68		
45	Z (9-8)+ 2.50		
46	H(9) 127.10		
47	hv(10-9)T.&E.(2 In. Pipe) (9-8).....- 4.40	hp(9) 122.70	
48	hn(9) 122.70		
49	hn ()+		
50	hf ()(ft. In. Pipe)+		
51	Z ()+		
52	hv ()(In. Pipe)+		
53	H ()+		

Problem #3



No.	SEQUENCE OF CALCULATIONS	Individual Flow G.P.M.	Total Flow G.P.M.
1	H(1) = hn(1) 16.50	Q(1) 15.00	15.00
2	hf(2-1).....(10 Ft. 1 In. Pipe) + 1.50		
3	Z (2-1).....+ 1.74		
4	H(2) 19.74		
5	hv(2-1).....(1 In. Pipe)- 1.48		
6	hn(2) 19.26	Q(2) 16.25	31.25
7	hf(3-2).....(1 In. Pipe).....+ 2.10	18.75	50.00
8	hf(3-2).....(10 Ft. 1 In. Pipe) + 6.10	19.25	50.50
9	Z (3-2)+ 1.74		
10	H(3) 29.20		
11	hv(4-3) T.&E. (1 1/4 In. Pipe)- 1.80		
12	hn(3) 27.35	Q(3) 19.25	50.50
13	H(3) From Above 29.20		
14	hf(4-3) ... (10 Ft. 1 1/4 In. Pipe).+ 3.84	22	72.50
15	Z (4-3)+ 1.74	21.1	71.60
16	H(4) 34.78		
17	hv(5-4) T.&E. (1 1/2 In. Pipe)- 2.00		
18	hn(4) 32.78	Q(4) 21.10	71.60
19	H(4) From Above 34.78		
20	hf(5-4) ... (10 Ft. 1 1/2 In. Pipe)+ 3.35	23	94.60
21	Z (5-4)+ 1.74	22.25	93.85
22	H(5) 39.87		
23	hv(6-5) T.&E. (1 1/2 In. Pipe)- 3.40		
24	hn(5) 36.47	Q(5) 22.25	93.85
25	H(5) From Above 39.87		
26	hf(6-5) .. (10 Ft. 1 1/2 In. Pipe)+ 3.65	24.15	118.00
27	Z (6-5)+ 1.74	24.90	118.75
28	H(6) 47.26		
29	hv(7-6) T.&E. (2 In. Pipe)- 2.02		
30	hn(6) 45.24	Q(6) 24.90	118.75
31	H(6) From Above 47.26		
32	hf(7-6) .. (10 Ft. 2 In. Pipe)+ 2.50	27	145.75
33	Z (7-6)+ 1.74	25.7	144.45
34	H(7) 51.50		
35	hv(8-7) T.&E. (2 In. Pipe)- 2.99		
36	hn(7) 48.51	Q(7) 25.7	144.45
37	H(7) From Above 51.50		
38	hf(8-7) .. (10 Ft. 2 In. Pipe)+ 3.75	26.5	170.95
39	Z (8-7)+ 1.74		
40	H(8) 56.99		
41	hv(9-8) T.&E. (2 In. Pipe)- 4.15		
42	hn(8) 52.84	Q(8) 26.7	171.15
43	H(8) From Above 56.99		
44	hf(9-8) (5 Ft. 2 In. Pipe)+ 2.55		
45	Z (9-8)+ .87		
46	H(9) 57.12		
47	hv(10-9) T.&E. (2 In. Pipe)- 4.11		
48	hn(9) 55.81	Q(9) = 56.26	
49	hn () 56.26		
50	hf () (Ft. In. Pipe)+		
51	Z ()+		
52	hv () (In. Pipe) +		
53	H ()+		

15.5
25.5
11-7-55 W.C.L.
27.74

PROBLEM # 4

Same @ head branch.
with $Q_1 = 15 \text{ GPM}$
 0° Slope.

from problem ①

$Q_1 = 30.00$	$h_{m1} = 66.50$
$Q_2 = 30.81$	$h_{m2} = 70.09$
$Q_3 = 35.55$	$h_{m3} = 91.70$
$Q_4 = 37.92$	$h_{m4} = 104.40$
$Q_5 = 39.10$	$h_{m5} = 111.30$
$Q_6 = 43.02$	$h_{m6} = 134.90$
$Q_7 = 43.80$	$h_{m7} = 139.90$
$Q_8 = 44.98$	$h_{m8} = 147.60$
	$H(9) = 168.15$

$$\frac{Q}{Q'} = \sqrt{\frac{k}{k'}} = 2$$


$$Q' = \frac{Q}{2}$$

$$k' = \frac{k}{4}$$

$Q'_1 = 15.00$	$h'_{m1} = 16.62$
$Q'_2 = 15.40$	$h'_{m2} = 17.52$
$Q'_3 = 17.77$	$h'_{m3} = 22.92$
$Q'_4 = 18.96$	$h'_{m4} = 26.10$
$Q'_5 = 19.55$	$h'_{m5} =$
$Q'_6 = 21.51$	$h'_{m6} = 33.72$
$Q'_7 = 21.90$	$h'_{m7} =$
$Q'_8 = 22.49$	$h'_{m8} =$
$Q'_T = 153.47$	$H'(9) = 41.68$


Handwritten calculation showing a division: $134.90 / 4 = 33.725$

Handwritten calculation showing a division: $26.1 / 4 = 6.525$



No.	SEQUENCE OF CALCULATIONS	Individual Flow G.P.M.	Total Flow G.P.M.
1	H(1) = hn(1)	16.50	
2	+ hf(2-1).....(10 Ft. 1 In. Pipe) +	1.50	
3	+ Z (2-1).....	3.42	
4	H(2)	21.42	
5	- hv(2-1).....(1 In. Pipe)48	
6	hn(2)	20.94	Q(2) 17.00
7	+ hv(3-2).....(1 In. Pipe).....	2.20	19.5
8	+ hf(3-2).....(10 Ft. 1 In. Pipe) +	6.40	20.6
9	+ Z (3-2)	3.42	
10	H(3)	32.96	
11	- hv(4-3) T.&E. (1 1/4 In. Pipe)	2.00	
12	hn(3)	30.96	Q(3) 20.5
13	H(3) From Above	32.96	23.00
14	+ hf(4-3) ... (10 Ft. 1 1/4 In. Pipe) +	4.06	22.80
15	+ Z (4-3)	3.42	
16	H(4)	40.44	
17	- hv(5-4) T.&E. (1 1/2 In. Pipe)	2.23	
18	hn(4)	38.21	Q(4) 22.8
19	H(4) From Above	40.44	25.2
20	+ hf(5-4) ... (10 Ft. 1 1/2 In. Pipe) +	3.78	24.4
21	+ Z (5-4)	3.42	
22	H(5)	47.64	
23	- hv(6-5) T.&E. (1 1/2 In. Pipe)	3.90	
24	hn(5)	43.74	Q(5) 24.4
25	H(5) From Above	47.64	27.00
26	hf (6-5) .. (10 Ft. 1 1/2 In. Pipe) +	6.44	27.60
27	Z (6-5)	3.42	
28	H (6)	58.50	
29	hv (7-6) T.&E. (2 In. Pipe)	2.30	
30	hn(6)	56.20	Q(6) 27.60
31	H(6) From Above	58.50	30.00
32	hf (7-6) .. (10 Ft. 2 In. Pipe) +	2.87	28.90
33	Z (7-6)	3.42	
34	H(7)	64.79	
35	hv(8-7) T.&E. (2 In. Pipe)	3.50	
36	hn(7)	61.29	Q(7) 28.90
37	H(7) From Above	64.79	32.00
38	hf(8-7) .. (10 Ft. 2 In. Pipe) +	6.75	30.60
39	Z (8-7)	3.42	
40	H(8)	74.36	
41	hv (9-8) T.&E. (2 In. Pipe)	5.00	
42	hn (8)	69.36	Q(8) 30.60
43	H(8) From Above	74.36	
44	hf (9-8) (5 Ft. 2 In. Pipe) +	3.00	
45	Z (9-8)	1.71	
46	H(9)	75.47	
47	hv (10-9) T.&E. (2 In. Pipe)	4.83	
48	hn (9)	74.07	Q(9) 30.60
49	hn ()		
50	hf () (Ft. In. Pipe) +		
51	Z		
52	hv () (In. Pipe)		
53	H ()		

hp(9)
74.07



No.	SEQUENCE OF CALCULATIONS	Individual Flow G.P.M.	Total Flow G.P.M.
1	H(1) = hn(1)	16.50	
2	hf(2-1)....(10 Ft. 1 In. Pipe) +	1.50	
3	Z (2-1).....+	5.00	
4	H(2)	23.00	
5	hf(2-1)....(1 In. Pipe)48	
6	hn(2)	22.52	Q(2) 17.60
7	hf(3-2)....(1 In. Pipe).....+	2.27	20.00
8	Z (3-2)....(10 Ft. 1" In. Pipe) +	6.60	21.60
9	H(3)	5.00	
10	hf(4-3) T.&E. (1/2 In. Pipe)	36.39	
11	hn(3)	2.13	
12	H(3)	34.26	Q(3) 21.60
13	hf(4-3) ... (10 Ft. 1/2 In. Pipe) +	36.29	23.00
14	Z (4-3)	4.70	24.40
15	H(4)	5.00	
16	hf(5-4) T.&E. (1/2 In. Pipe)	46.09	
17	hn(4)	2.40	
18	H(4)	43.59	Q(4) 24.40
19	hf(5-4) ... (10 Ft. 1/2 In. Pipe) +	46.09	27.00
20	Z (5-4)	4.07	26.20
21	H(5)	5.00	
22	hf(6-5) T.&E. (1/2 In. Pipe)	55.16	
23	hn(5)	4.32	
24	H(5)	50.84	Q(5) 26.2
25	hf(6-5) .. (10 Ft. 1/2 In. Pipe) +	55.16	28.00
26	Z (6-5)	7.02	29.50
27	H(6)	5.00	
28	hf(7-6) T.&E. (2 In. Pipe)	67.18	
29	hn(6)	2.57	
30	H(6)	64.61	Q(6) 29.5
31	hf(7-6) .. (10 Ft. 2 In. Pipe) +	67.18	31.00
32	Z (7-6)	3.20	31.00
33	H(7)	5	
34	hf(8-7) T.&E. (2 In. Pipe)	75.38	
35	hn(7)	3.91	
36	H(7)	71.47	Q(7) 31.00
37	hf(8-7) .. (10 Ft. 2 In. Pipe) +	75.38	32.7
38	Z (8-7)	4.80	32.0
39	H(8)	5.00	
40	hf(9-8) T.&E. (2 In. Pipe)	85.18	
41	hn(8)	5.6	
42	H(8)	79.58	Q(8) 33.0
43	hf(9-8) .. (5 Ft. 2 In. Pipe) +	85.18	
44	Z (9-8)	3.40	
45	H(9)	2.50	
46	hf(10-9) T.&E. (2 In. Pipe) 9-8	85.18	
47	hn(9)	5.50	
48	H(9)	80.68	Q(9)
49	hf ()	91.08	
50	Z ()	5.60	
51	H ()	86.48	
52	hf ()	68.40	
53	Z ()	3.40	

11-7-55 W.G.L.


problem 7

$Q_1 = 15 \text{ gpm}$

10° negative slope

$$\begin{array}{r} 19.74 \\ 3.48 \\ \hline 16.26 \end{array}$$

$$\begin{array}{r} 15.78 \\ 3.45 \\ \hline 12.33 \end{array}$$



$$\begin{array}{r} 1/4'' \text{ } h_{v4-3} = 1.55 \\ h_{n3} = 19.89 \end{array}$$

$$H(4-3) \text{ } 1/4''$$

$$h_{v5-4} \text{ } 1/2''$$

$$h_f(5-4) \text{ } 1/2''$$

$$h_v(6-5) \text{ } 1/2''$$

$$h_f(6-5) \text{ } 1/2''$$

$$2'' \text{ } h_v(7-6) =$$

	16.50
	1.50
	<u>18.00</u>
	-1.74
H_2	16.26
$-h_{v2-1}$	-0.48
h_{n2}	<u>15.78</u>
$h_v 3-2 \text{ } 1''$	1.85
	<u>5.55</u>
	23.18
	-1.74
$H(3)$	<u>21.44</u>

$$21.44$$

$$H(4) = 22.90$$

$$22.90$$

$$H(5) = 23.83$$

$$21.32$$

$$H(6) = 25.88$$

$$24.49$$

$Q_1 = 15.00$	TOTAL Q	15.00
---------------	---------	-------

$Q_2 = 14.70$	TOTAL Q	29.70
---------------	---------	-------

13.00	TOTAL Q	42.70
-------	---------	-------

16.60	TOTAL Q	45.70
16.00		

15.20	TOTAL Q	44.90
-------	---------	-------

16.50	TOTAL Q	46.20
-------	---------	-------

$Q_3 = 16.50$	TOTAL Q	46.20
---------------	---------	-------

15.00	TOTAL Q	61.20
-------	---------	-------

17.10	TOTAL Q	63.30
-------	---------	-------

17.00	TOTAL Q	63.20
-------	---------	-------

$Q_4 = 17.00$	TOTAL Q	63.20
---------------	---------	-------

18.00	TOTAL Q	81.20
-------	---------	-------

17.00	TOTAL Q	80.20
-------	---------	-------

17.1	TOTAL Q	80.3
------	---------	------

$Q_5 = 17.1$	TOTAL Q	80.3
--------------	---------	------

17.7	TOTAL Q	98.0
------	---------	------

18.3	TOTAL Q	98.6
------	---------	------

$Q_6 = 18.3$	TOTAL Q	98.6
--------------	---------	------

~~18.3~~ ~~18.3~~ 18.8
 # Q₆ = 18.3 98.6

H(6) 25.88
 $h_f(7-6) 2''$ $\frac{1.76}{27.64}$
 $- 1.74$
 H(7) = 25.90

18.50 117.1
 18.10 116.7
 18.3
 Q₇ = 18.10 116.7

$h_v(8-7) 2''$ $\frac{1.95}{23.95}$

H(7) 25.90
 $h_f(8-7) 2''$ $\frac{2.45}{28.35}$
~~28.35~~
 $- 1.74$

18.30 135.0
 18.00 134.7

$\frac{.32}{.35} / 1.5$

H(8) → 26.61
 $h_v(9-8) 2''$ $\frac{2.60}{24.01}$

18.4
 Q₈ = 18.00 136.0
 134.7

H(8) = 26.61
 $h_f(9-8) 5' 2''$ $\frac{1.60}{28.21}$
 $.87$

H(9) → 27.34
 $- h_v(9-8) - 2.60$

$h_p(9) = 24.74$
 26.27

$Q_1 = 15 \text{ gpm}$
 slope = -20°
 $z = -3.42$

problem # 8

$H(1) = h_{m1} = 16.50$	$Q_1 = 15.00$	$Q_T = 15.00$
$h_f = 1.50$		
18.00		
$-z(2-1) = 3.42$		
$H(2) = 14.58$		
$h_v(2-1) 1" = 0.48$	14.0	15.10
$h_m(2) = 14.10$	$Q_2 = 13.90$	$Q_T = 28.90$
$h_v(3-2) 1" = 1.80$	15.00	44.00
$h_f(3-2) 1" = 5.25$		
21.15		
-3.42		
$H(3) = 17.73$		
$h_v(4-3) 1\frac{1}{4}" = -1.40$	15.2	
$h_m(3) = 16.33$	$Q_3 = 15.00$	$Q_T = 43.90$
$H_3 = 17.73$	14	57.90
$h_f(4-3) 1\frac{1}{4}" = 2.88$	14.2	
19.61		
3.42		
$H(4) = 16.19$		
$h_v(5-4) 1\frac{1}{2}" = 1.30$	14.8	13.7
14.89	$Q_4 = 14.2$	58.10
$H(4) = 16.19$	13.4	71.5
$h_f(5-4) 1\frac{1}{2}" = 2.30$		
18.49		
3.42		
$H(5) = 15.07$		
$h_v(6-5) 1\frac{1}{2}" = 2.00$	14.1	
13.07	$Q_5 = 13.3$	$Q_T = 71.4$
$H(5) = 15.07$	13.6	85.0
$h_f(6-5) 1\frac{1}{2}" = 3.40$		
18.47		
3.42		
$H(6) = 15.05$		
$h_v(7-6) 2" = 1.03$	14.5	
14.02	$Q_6 = 13.8$	85.2

$H(6)$	15.05	$Q_6 = 13.8$	$Q_7 = 85.2$
$h_f(7-6) 2''$	<u>1.33</u>	12.8	98.0
	16.38	12.6	97.8
	<u>- 2.42</u>		

$H(7) \rightarrow$	12.96		
$h_v(8-7) 2''$	<u>1.38</u>	13.3	
	11.58	$Q_7 = 12.6$	$Q_8 = 97.8$

$H(7)$	12.96	13.2	111.0
$h_f(8-7) 2''$	<u>1.23</u>		


$H(8) \rightarrow$	14.69		
$h_v(9-8) 2''$	<u>1.75</u>	12.3	113.2
	12.94	$Q_8 = 13.3$	111.1

$H(8) \rightarrow$	14.69		
$h_f(9-8) 2''(5')$	<u>1.10</u>		
	15.79		
	<u>1.71</u>		

$H(9) \rightarrow$	14.08		
$- h_v(9-8)$	<u>- 1.75</u>		
$h_p(9) \rightarrow$	12.33		
	10.45		

1.22
- 1.10

0.12




0° SLOPE



No.	SEQUENCE OF CALCULATIONS	Individual Flow G.P.M.	Total Flow G.P.M.
1	H(1) = hn(1)	16.50	
2	hf(2-1)....(10 Ft. 1 In. Pipe) +	1.50	
3	Z (2-1).....+	0.00	
4	H(2)	18.00	
5	hv(2-1)....(1 In. Pipe)	1.48	
6	hn(2)	17.52	Q(2) 15.50
7	hf(3-2)....(1 1/4 In. Pipe).....+	.68	15.5
8	hf(3-2)....(10 Ft. 1 1/4 In. Pipe) +	1.43	16.00
9	Z (3-2)	0.00	15.70
10	H(3)	19.63	
11	hv(4-3) T.&E. (1 1/4 In. Pipe)	1.55	15.8
12	hn(3)	18.08	Q(3) 15.70
13	H(3) From Above	19.63	
14	hf(4-3) ... (10 Ft. 1 1/2 In. Pipe).+	1.47	16.00
15	Z (4-3)	0.00	16.40
16	H(4)	21.10	
17	hv(5-4) T.&E. (1 1/2 In. Pipe)	1.53	17.0
18	hn(4)	19.57	Q(4) 16.40
19	H(4) From Above	21.10	
20	hf(5-4) ... (10 Ft. 1 1/2 In. Pipe)+	2.67	17.00
21	Z (5-4)	0.00	17.10
22	H(5)	23.77	
23	hv(6-5) T.&E. (1 1/2 In. Pipe)	2.47	17.8
24	hn(5)	21.30	Q(5) 17.10
25	H(5) From Above	23.77	
26	hf (6-5)..(10 Ft. 1 1/2 In. Pipe)+	.415	18.0
27	Z (6-5)	0.00	19.0
28	H (6)	27.92	
29	hv (7-6)T.&E. (2 In. Pipe)	1.38	19.7
30	hn(6)	26.54	Q(6) 19.0
31	H(6) From Above	27.92	
32	hf (7-6)..(10 Ft. 2 In. Pipe)+	1.77	20.00
33	Z (7-6)	0.00	19.50
34	H(7)	29.69	
35	hv(8-7) T.&E. (2 In. Pipe).....	2.00	20.0
36	hn(7)	27.69	Q(7) 19.50
37	H(7) From Above	29.69	
38	hf(8-7) ..(10 Ft. 2 In. Pipe)+	2.50	20.2
39	Z (8-7)	0.00	20.0
40	H(8)	32.19	
41	hv (9-8) T.&E.(2 In. Pipe)	2.75	20.7
42	hn (8)	29.44	Q(8) 20.0
43	H(8) From Above	32.19	
44	hf (9-8)(5 Ft. 2 In. Pipe)+	1.70	
45	Z (9-8)	0.00	
46	H(9)	33.89	
47	hv (10-9)T.&E.(2 In. Pipe).....	2.75	
48	hn(9)	31.14	Q(9) 20.0
49	hn ()		
50	hf ()		
51	Z ()		
52	hv ()		
53	H ()		

hp(9)
31.14

Note - getting just as good as w/ no supply w. less supply + pressure req.



20° SLOPE (positive)

No.	SEQUENCE OF CALCULATIONS $Z = 3.42$	Individual Flow G.P.M.	Total Flow G.P.M.
1	H(1) = hn(1)	16.50	
2	hf(2-1)....(10 Ft. 1 In. Pipe) +	1.50	
3	Z (2-1).....+	3.42	
4	H(2)	21.42	
5	hv(2-1)....(1 In. Pipe)48	17.0
6	hn(2)	20.94	Q(2) 17.00
7	hf(3-2)....(1 1/4 In. Pipe).....+	.74	17.5
8	hf(3-2)....(10 Ft. 1 1/4 In. Pipe) +	1.57	18.4
9	Z (3-2)	3.42	
10	H(3)	26.67	
11	hv(4-3) T.&E. (1 1/4 In. Pipe)	1.85	18.4
12	hn(3)	24.82	Q(3) 18.4
13	H(3) From Above	26.67	
14	hf(4-3) ... (10 Ft. 1 1/2 In. Pipe) +	3.80	20.0
15	Z (4-3)	3.42	20.8
16	H(4)	33.89	
17	hv(5-4) T.&E. (1 1/2 In. Pipe)	1.95	20.9
18	hn(4)	31.94	Q(4) 20.8
19	H(4) From Above	33.89	
20	hf(5-4) ... (10 Ft. 1 1/2 In. Pipe) +	3.38	22.0
21	Z (5-4)	3.42	22.5
22	H(5)	40.69	
23	hv(6-5) T.&E. (1 1/2 In. Pipe)	2.38	22.7
24	hn(5)	37.31	Q(5) 22.5
25	H(5) From Above	40.69	
26	hf(6-5) .. (10 Ft. 1 1/2 In. Pipe) +	5.70	24.3
27	Z (6-5)	3.42	25.5
28	H(6)	49.81	
29	hv(7-6) T.&E. (2 In. Pipe)	2.03	25.7
30	hn(6)	47.78	Q(6) 25.5
31	H(6) From Above	49.81	
32	hf(7-6) .. (10 Ft. 2 In. Pipe) +	2.65	26.3
33	Z (7-6)	3.42	26.7
34	H(7)	55.78	
35	hv(8-7) T.&E. (2 In. Pipe)	3	26.8
36	hn(7)	52.78	Q(7) 26.7
37	H(7) From Above	55.78	
38	hf(8-7) .. (10 Ft. 2 In. Pipe) +	3.71	28.1
39	Z (8-7)	3.42	
40	H(8)	62.91	
41	hv(9-8) T.&E. (2 In. Pipe)	4.3	28.3
42	hn(8)	58.61	Q(8) 28.2
43	H(8) From Above	62.91	
44	hf(9-8) (5 Ft. 2 In. Pipe) +	2.65	
45	Z (9-8)	1.71	
46	H(9)	67.27	
47	hv (10-9) T.&E. (2 In. Pipe)	4.30	62.97 = hp(9)
48	hp (9)	62.97	Q(9)
49	hn ()		
50	hf ()		
51	Z ()		
52	hv ()		
53	H ()		

Look at all these values to get an idea of how change in variable affects answer


53
5
2.65

Extra Hazard Schedule - 8 heads, - $Q_1 = 15 \text{ gpm}$

~~Answers~~

problem # 11	0° slope	$Q_T = 138.34 \text{ gpm.}$	$hp(9) = 31.27$
problem # 12	20° slope	$Q_T = \del{162.34} \text{ gpm.}$ 171.80	$hp(9) = \del{55.69}$ 60.80

H₂O Cont.



$Q_1 = 15$ gpm. 0° slope

From problem # 1 + # 4.

$$Q_{TOTAL} \text{ at } (6) = \frac{216.4}{2} = 108.2 \text{ gpm.}$$

$$H(6) = h_{m(6)} + h_v(7-6)$$

$$H(7) = H(6) + h_f(7-6)$$

$$h_{m(7)} = H(7) - h_v(7-6)$$

$$h_{m(7)} = H(6) + h_f(7-6) - h_v(7-6)$$

$$h_{m(7)} = h_{m(6)} + h_v(7-6) + h_f(7-6) - h_v(7-6)$$

$$h_{m(7)} = h_{m(6)} + h_f(7-6)$$

$$h_{m(7)} = 33.72 + (0.21)(5) = 33.72 + 1.05 = 34.77$$

$$h_{m(7)} = 34.77$$

~~127.5~~
~~4.05~~

2 $\overline{) 134.28}$
67.14
127.14
7.14

Q_{TOTAL} @ ④ from problem #1 x #4:

$$Q_T = \begin{matrix} 67.14 \\ 67.50 \end{matrix}$$

$h_m(7)$ for 67.14 gpm:

$$h_m(7) = h_m(4) + h_f(7-4)$$

$$h_m(7) = 26.10 + .3(5) = 26.10 + 1.50$$

$$h_m(7) = \begin{matrix} 27.60 \\ 28.5 \end{matrix}$$

But it must equal ^{36.00} 34.77
 \therefore find new flow in Right Branch:

$$\frac{Q_1}{Q_2} = \left(\frac{h_1}{h_2} \right)^{\frac{1}{2}}$$

$$\frac{67.14}{Q_2} = \left(\frac{27.60}{34.77} \right)^{\frac{1}{2}}$$

$$Q_2 = \frac{67.14}{\left(\frac{27.60}{34.77} \right)^{\frac{1}{2}}} = \frac{67.14}{.892} = \begin{matrix} 75.3 \text{ gpm.} \\ 75.6 \end{matrix}$$

\therefore Total flow thru RN will be:

75.30

108.20

183.50 gpm.
184.60

$h_p(7)$	→	34.77	36.00
$h_v(12-7)$ 2½" pipe	→	2.37	
h_f (2" x 1½" x 2½" tee)	→		
($K=1.3$) ($h_v = 2.37$)		3.08	
↑ <u>inlet dia?</u>			<i>always use inlet dia + inlet h_v</i>
h_f RN 1' 2½" pipe		.24	
Σ RN		1.00	
$H(12)$	→	41.46	= $h(n)_{12}$

TOTAL HEAD @ 12 = 41.46 feet H_2O 42.53

TOTAL FLOW @ 12 = 183.50 gpm 184.6

$$K_{12} = \frac{Q}{\sqrt{h}} = \frac{183.5}{\sqrt{41.46}} = \frac{183.5}{6.44} = 28.5$$

420

AN INTRODUCTION TO
THE HYDRAULICS OF SPRINKLER SYSTEMS

by
WILLIS G. IABES
Associate Professor
Fire Protection Engineering
Illinois Institute of Technology
Chicago, Illinois

I. PURPOSE

The purpose of this paper is to present a basic understanding of the calculation of pressure and flow distribution in sprinkler systems designed for the control and extinguishment of fires. The basic mathematical relationships are described. Calculations associated with the solution of a simple sprinkler system are presented to explain the method.

II. BASIC EQUATIONS (See Page 8 for notation)

A. Material Balance - $Q(\text{total}) = Q_1 + Q_2 + Q_3 \dots\dots Q_x$ Eq. 1

B. Energy Balance - At any cross-section in a flowing pipe system,

$$H = h_p + z + h_v \quad \text{Eq. 2}$$

Between any two points in a pipe system,

$$H_1 = H_2 + h_f \quad \text{Eq. 3}$$

C. Other useful equations -

$$h_v = \frac{v^2}{2g} = \frac{Q^2}{385 D^4} \quad (\text{velocity head}) \quad \text{Eq. 4}$$

$$h_f = f \frac{L}{D/12} \frac{v^2}{2g} \quad (\text{friction head loss}) \quad \text{Eq. 5}$$

$$f = 0.0055 \left[1 + (20,000 \frac{\epsilon}{D/12} + \frac{10^6}{N_R}) \right]^{1/3} \quad \text{Eq. 6}$$

$$Q = 19.62 C_d d_o^2 \sqrt{h_n} \quad (\text{nozzle flow}) \quad \text{Eq. 7}$$

$$Q = K \sqrt{h} \quad \text{Eq. 8}$$

$$N_R = \frac{v D/12}{\nu} \quad (\text{Reynolds Number}) \quad \text{Eq. 9}$$

For water at 60°F, $\nu = 1.216 \times 10^{-5} \text{ ft}^2/\text{sec}$
and Reynolds Number becomes,

$$N_R = 6850 \ V D = 2810 \ Q/D \quad \text{Eq. 10}$$

$$V = \frac{Q}{2.44 \ D^2} \quad (\text{pipe velocity}) \quad \text{Eq. 11}$$

P. By combining various equations and solving for Q, the relations for nozzle flow, velocity head and friction head loss may be put into the form of Eq. 8, as follows:

Nozzle flow, from Eq. 7:

$$Q_n = K_n \sqrt{h_n} \quad \text{Eq. 12}$$

in which, for a particular nozzle

$$K_n = 19.62 \ C_d \ d_o^2 \quad \text{Eq. 13}$$

Velocity head, from Eq. 4:

$$Q = K_v \sqrt{h_v} \quad \text{Eq. 14}$$

in which, for a particular cross-section in a flowing system

$$K_v = D^2 \sqrt{385} \quad \text{Eq. 15}$$

Friction head loss, from Eqs. 4 and 5:

$$Q = K_f \sqrt{h_f} \quad \text{Eq. 16}$$

in which, for a particular cross-section in a flowing system

$$K_f = D^2 \sqrt{385} \left(\sqrt{\frac{D/12}{fL}} \right) = K_v \sqrt{\frac{D/12}{fL}} \quad \text{Eq. 17}$$

III. BRANCH LINE CALCULATIONS IN EQUATION FORM - Following the sequence of calculations on the form used for branch line calculations, Example No. 1, equations for TOTAL HEADS at each sprinkler are written below:

- 1. $H(1) = hn(1)$
- 2. $H(2) = H(1) + hf(2-1) + z(2-1)$
- 3. $H(3) = hn(2) + hf(3-2) + z(3-2) + hv(3-2)$
- 4. $H(4) = H(3) + hf(4-3) + z(4-3)$
- 5. $H(5) = H(4) + hf(5-4) + z(5-4)$
- 6. $H(6) = H(5) + hf(6-5) + z(6-5)$
- 7. $H(7) = H(6) + hf(7-6) + z(7-6)$
- 8. $H(8) = H(7) + hf(8-7) + z(8-7)$

Equations for the head causing flow from each sprinkler may be written as follows:


Minimize

- 1. $hn(1) = H(1)$
- 2. $hn(2) = [H(1) + hf(2-1) + z(2-1)] - hv(2-1)$
- 3. $hn(3) = [hn(2) + hf(3-2) + z(3-2) + hv(3-2)] - hv(4-3)$
- 4. $hn(4) = [H(3) + hf(4-3) + z(4-3)] - hv(5-4)$
- 5. $hn(5) = [H(4) + hf(5-4) + z(5-4)] - hv(6-5)$
- 6. $hn(6) = [H(5) + hf(6-5) + z(6-5)] - hv(7-6)$
- 7. $hn(7) = [H(6) + hf(7-6) + z(7-6)] - hv(8-7)$
- 8. $hn(8) = [H(7) + hf(8-7) + z(8-7)] - hv(9-8)$

Please Note: Elevation head z has been included as a separate term in the above equations as a matter of convenience, and is not implied as having been included in the Total Head H , as shown in Eq. 2, page 1.

IV. CALCULATIONS FOR A SIMPLE SYSTEM


The following sketch represents a simple layout of building and sprinkler system, as a basis for demonstrating the hydraulic calculations involved: (SCALE:- 1/2 inch = 10 ft.)



EXAMPLE NO. 1

Z = 0.00
Q(1) = 20 gpm -5-

CALCULATION OF A TYPICAL BRANCH LINE




Example Problem

No.	SEQUENCE OF CALCULATIONS	Individual Flow G.P.M.	Total Flow G.P.M.
1	H(1) = hn(1) 29.54	Q(1)	
2	hf(2-1)....(10 Ft. 1 In. Pipe) +(0.255) 2.55	20.00	20.00
3	Z (2-1).....+ 0.00		
4	H(2) 32.09		
5	hv(2-1)....(1 In. Pipe)- 0.85		
6	hn(2) 31.24	Q(2) 20.57	40.57
7	hf(3-2)....(1 In. Pipe).....+ 3.51		
8	hf(3-2)....(10 Ft. 1 In. Pipe) +(0.997) 9.97		
9	Z (3-2)+ 0.00		
10	H(3) 44.72		
11	hv(4-3) T.&E. (1 1/4 In. Pipe)- 2.96		
12	hn(3) 41.76	Q(3) 23.78	64.35
13	H(3) From Above 44.72		
14	hf(4-3) ... (10 Ft. 1 1/4 In. Pipe).+(0.599) 5.99		
15	Z (4-3)+ 0.00		
16	H(4) 50.71		
17	hv(5-4) T.&E. (1 1/2 In. Pipe)- 3.11		
18	hn(4) 47.60	Q(4) 25.39	89.74
19	H(4) From Above 50.71		
20	hf(5-4) ... (10 Ft. 1 1/2 In. Pipe)+(0.518) 5.18		
21	Z (5-4)+ 0.00		
22	H(5) 55.89		
23	hv(6-5) T.&E. (1 1/2 In. Pipe)- 5.18		
24	hn(5) 50.71	Q(5) 26.20	115.94
25	H(5) From Above 55.89		
26	hf(6-5).. (10 Ft. 1 1/2 In. Pipe)+(0.853) 8.53		
27	Z (6-5)+ 0.00		
28	H(6) 64.42		
29	hv(7-6)T.&E. (2 In. Pipe)- 2.96		
30	hn(6) 61.46	Q(6) 28.85	144.79
31	H(6) From Above 64.42		
32	hf(7-6).. (10 Ft. 2 In. Pipe)+(0.361) 3.61		
33	Z (7-6)+ 0.00		
34	H(7) 68.03		
35	hv(8-7) T.&E. (2 In. Pipe)- 4.28		
36	hn(7) 63.75	Q(7) 29.38	174.17
37	H(7) From Above 68.03		
38	hf(8-7) .. (10 Ft. 2 In. Pipe)+(0.517) 5.17		
39	Z (8-7)+ 0.00		
40	H(8) 73.20		
41	hv(9-8) T.&E.(2 In. Pipe)- 5.89		
42	hn(8) 67.31	Q(8) 30.19	204.36
43	H(8) From Above 73.20		
44	hf(9-8) (5 Ft. 2 In. Pipe)+(0.707) 3.54		
45	Z (9-8)+ 0.00		
46	H(9) GET PRESSURE HEAD @ 9 76.74	hp9 = 70.95	
47	hv(10-9)T.&E.(In. Pipe)- 5.57		
48	hn(9) 71.17	Q(9)	
49	hn ()+		
50	hf ()(Ft. In. Pipe)+		
51	Z ()+		
52	hv ()(In. Pipe)+		
53	H ()+		

11-7-55 W.G.L.

EXAMPLE NO. 2 - Applying the information available in Example No. 1, calculate the flow of water into a 12-head branch line, having 8 sprinklers on one side and 4 on the other side of the junction, as shown in the following sketch (assume all sprinklers flowing):



From Example No. 1, the Total Flow from the 8 sprinklers = 204.4 gpm.

Also, the Total Head at Point 9 $H(9)$ has been calculated to be 76.74 ft. of water; the Static Pressure Head at Point 9, $h_p(9) = H(9) - h_v(9-8) = 76.74 - 5.89 = 70.85$

The Total Flow through Sprinklers 11, 12, 13 and 14, with 70.85 ft. of water at Point 9 will now be calculated:

It is seen by inspection of the sketch that the right-hand side of the branch line is similar to a part of the left-hand side, consisting of Sprinklers 1, 2, 3 and 4 to the midpoint between Sprinklers 4 and 5. Referring to Item 18 (see arrows) of Example No. 1,

- (a) The total flow from Sprinklers 1, 2, 3, 4 = 89.74 gpm
- (b) The Static Pressure Head at the midpoint between Sprinklers 4 and 5 may be calculated by adding the Friction Head Loss through 5 ft. of $1\frac{1}{2}$ " pipe to the Static Pressure Head at Point 4, $h_n(4)$, as follows:

$$47.60 + (5 \text{ ft.} \times 0.518) = 47.60 + 2.59 = \underline{50.19 \text{ ft. of water.}}$$

Since there can be only one head acting at the junction, Point 9, the Total Flow into Sprinklers 11, 12, 13 and 14 may be calculated as follows:

$$Q(\text{total}) = 89.74 \sqrt{\frac{70.85}{50.19}} = 89.74 \times 1.188 = 106.6 \text{ gpm.}$$

The individual flows from the sprinklers may be calculated similarly:

$$\begin{aligned} Q(11) &= 20 \times 1.188 = 23.76 \text{ gpm.} \\ Q(12) &= 20.57 \times 1.188 = 24.44 \text{ "} \\ Q(13) &= 23.78 \times 1.188 = 28.25 \text{ "} \\ Q(14) &= 25.39 \times 1.188 = 30.16 \text{ "} \\ Q(\text{total}) &= \underline{106.61 \text{ gpm.}} \end{aligned}$$


The Total Flow into the junction at Point 9, with all sprinklers flowing under an inlet head $H(9)$ of 86 ft. of water, is then

$$204.4 + 106.6 = \underline{311.0 \text{ gpm.}}$$

Referring once more to Example No. 1, Item 30, if the 12 sprinklers in the above branch line were supplied at the midpoint,

- (a) The Total Flow from all sprinklers would be 289.58 gpm., a decrease of about 6.9% from the previously calculated unbalanced supply point.
- (b) The Static Pressure Head h_p at the midpoint has been calculated to be 63.26 ft. of water, a decrease of about 10.7 from the previously calculated unbalanced supply point.

EXAMPLE NO. 3 -- Applying the information available from Example No. 2, calculate the total flow of water necessary to supply 48 sprinklers (4 12-head branch lines, 1/3 of the 144 sprinklers in the building); also calculate the Total Head at Point 20 H(20), as well as the Static Pressure Head h_p necessary to supply the 48 flowing sprinklers. The following sketch represents part of the cross-main involved in the calculations:



SEQUENCE OF CALCULATIONS	Calculation of Individual Flows, gpm	Total Flow gpm.
1 hp(9) (at junction) 70.85	$K = \frac{311}{\sqrt{88.14}} = \frac{311}{9.39}$	311.0
2 hv(15-9) 2 1/2" pipe 6.80	$K = 33.12$	
3 hf(1 1/2 x 2 x 2 1/2 Tee)		
4 (k = 1.3) (hv = 6.80) 8.84		
5 hf(RN) 1 ft. 2 1/2" pipe (0.65) 0.65		
6 Z (RN) (15-9) 1.00		
7 H (15) 88.14		
8 hf (16-15) 2 1/2" pipe (0.65) 6.50		
9 H (16) 94.64	$Q(16) = 33.12 \sqrt{87.84}$	
10 hv (16-15) 2 1/2" pipe -6.80	$= 33.12 \times 9.37$	
11 hn (16) 87.84	$= 310.33$	621.3
12 hv (17-16) 3" pipe 11.30		
13 hf (17-16) 10' of 3" (0.81) 8.10		
14 H(17) 107.24	$Q(17) = 33.12 \sqrt{93.04}$	
15 hv (18-17) T & E 3 1/2" pipe -14.20	$= 33.12 \times 9.65$	
16 hn (17) 93.04	$= 319.6$	940.9
17 H(17) 107.24		
18 hf(18-17) 10' of 3 1/2" (0.88) 8.80		
19 H(18) 116.04	$Q(18) = 33.12 \sqrt{100.34}$	
20 hv (19-18) T & E 4" pipe 15.70	$= 33.12 \times 10.02$	
21 hn (18) 100.34	$= 331.9$	1272.8 gpm
22 H(18) 116.04		<u>Total Flow</u>
23 hf (two 4x4x2 1/2 Tees)		
24 (k = 0.9) (hv = 15.7) 14.13	$= 28.26$	
25 hf (19-18) 25' 4" pipe (0.81) 20.25		
26 hf (4x4x5 Tee, flgd.)		
27 (k = 0.65) (hv = 6.4) 4.16		
28 hf (5" flgd. Ell)		
29 (k = 0.3) (hv = 6.4) 1.92		
30 hf (20-19) 60' of 5" pipe (0.255) 15.30		
31 Z (Riser height) 20.00		
31 hf (6" flgd. ck. va.)		
32 (k = 2) (hv = 3.1) 6.20		
33 hf (6" flgd. gate va.)		
34 (k = 0.11) (hv = 3.1) 0.34		
35 H (20) 198.34 ft. of water		

198.34 / 2.31 ft. of water per psi = 85.9 psi (TOTAL HEAD AT POINT 20)

$h_p = \frac{198.34 - 3.1}{2.31} = \frac{195.24}{2.31} = 84.5 \text{ psi (STATIC PRESSURE HEAD) (AT POINT 20)}$

NOTATION USED IN EQUATIONS

Unless otherwise stated, the notation used is as follows:


- C_d = Coefficient of discharge, orifices and nozzles.
- D = Internal pipe diameter, inches.
- d_o = Orifice or nozzle diameter, inches.
- f = Friction factor for pipe flow, dimensionless.
- g = Acceleration of gravity, ft/sec²
- H = Total Head = $h_p + z + h_v$, ft. of water.
- h = Any fluid head, ft. of water.
- h_f = Head lost in friction, ft. of water.
- h_n = Head causing flow at a nozzle or orifice, ft. of water.
- h_p = Static pressure head, ft. of water.
- h_v = Velocity head, $V^2/2g$, ft. of water.
- K = Constant in the equation $Q = K \sqrt{h}$
- k = Loss coefficient for pipe fittings and other parts of a system, where h_f (fitting, etc.) = $k h_v$.
- L = Length of pipe, feet.
- N_R = Reynolds Number = $L V/\nu$, dimensionless.
- Q = Volume flow rate, gallons per minute (gpm).
- V = Mean fluid velocity, ft/sec.
- z = Elevation head above an arbitrary datum plane, ft. of water.
- ϵ = Absolute pipe roughness factor, feet.
- ν = Kinematic viscosity, sq. ft/sec.



No.	SEQUENCE OF CALCULATIONS	Individual Flow G.P.M.	Total Flow G.P.M.
1	H(1) = hn(1)	Q(1)	
2	hf(2-1).....(Ft. In. Pipe) +		
3	Z (2-1).....+		
4	H(2)		
5	hv(2-1).....(In. Pipe)		
6	hn(2)	Q(2)	
7	hf(3-2).....(In. Pipe).....+		
8	hf(3-2).....(Ft. In. Pipe) +		
9	Z (3-2)		
10	H(3)		
11	hv(4-3) T.&E. (In. Pipe)		
12	hn(3)	Q(3)	
13	H(3) From Above		
14	hf(4-3) ... (Ft. In. Pipe) +		
15	Z (4-3)		
16	H(4)		
17	hv(5-4) T.&E. (In. Pipe)		
18	hn(4)	Q(4)	
19	H(4) From Above		
20	hf(5-4) ... (Ft. In. Pipe) +		
21	Z (5-4)		
22	H(5)		
23	hv(6-5) T.&E. (In. Pipe)		
24	hn(5)	Q(5)	
25	H(5) From Above		
26	hf (6-5) .. (Ft. In. Pipe) +		
27	Z (6-5)		
28	H (6)		
29	hv (7-6) T.&E. (In. Pipe)		
30	hn(6)	Q(6)	
31	H(6) From Above		
32	hf (7-6) .. (Ft. In. Pipe) +		
33	Z (7-6)		
34	H(7)		
35	hv(8-7) T.&E. (In. Pipe)		
36	hn(7)	Q(7)	
37	H(7) From Above		
38	hf(8-7) .. (Ft. In. Pipe) +		
39	Z (8-7)		
40	H(8)		
41	hv (9-8) T.&E. (In. Pipe)		
42	hn (8)	Q(8)	
43	H(8) From Above		
44	hf (9-8) (Ft. In. Pipe) +		
45	Z (9-8)		
46	H(9)		
47	hv (10-9) T.&E. (In. Pipe)		
48	hn (9)	Q(9)	
49	hn ()		
50	hf () (Ft. In. Pipe) +		
51	Z ()		
52	hv () (In. Pipe)		
53	H ()		


11-7-55 W.G.L.

PROBLEM:



$Q_1 = 15 \text{ GPM}$

$Z = 0$



TOTAL Flow IN?
+ head Causing flow

.26

$\frac{.35}{1.05}$

$\frac{.26}{15}$

$\frac{.37}{1.98}$

$\frac{.185}{1.110}$

$\frac{.28}{1.68}$

$\frac{.57}{3.42}$

$\frac{.56}{.9}$

$\frac{.456}{2.170}$

$$\left. \begin{aligned} Q_{TOTAL} &= 140.7 \text{ GPM} \\ h_m(9) &= 29.53 \text{ Ft. H}_2\text{O} \end{aligned} \right\} \text{ 8 head Side}$$

$$\left. \begin{aligned} Q_{TOTAL} &= 82.4 \text{ GPM} \\ h_m(9) &= 25.96 - 2.70 = 23.26 \text{ Ft H}_2\text{O} \end{aligned} \right\} \text{ 5 head Side}$$

$$\frac{Q_1}{Q_2} = \sqrt{\frac{h_1}{h_2}}$$

$$\frac{82.4}{Q_2} = \sqrt{\frac{23.26}{29.53}} = .888$$

$$Q_2 = \frac{82.4}{.888} = \boxed{92.7 \text{ GPM}}$$

$$\begin{array}{r} 92.7 \\ 140.7 \\ \hline 233.4 \end{array}$$

$$\begin{aligned} Q_{TOTAL} \text{ INTO BRANCH} &= 92.7 + 140.7 \\ &= 233.4 \text{ GPM} \quad 230 \end{aligned}$$

$$\text{Pressure head at tee} = 29.53 \text{ Ft. H}_2\text{O}$$

$$h_m(13) = 48.9$$

944 gpm into (13)

$$H(13) \approx 64$$

944 gpm thru $3\frac{1}{2}$ " pipe.
1000 is limit for $3\frac{1}{2}$ " pipe - beyond this not economical

Item No.	Sequence of Calculations	Calculation of Individual Flows		Total Flow G.P.M.
1	$H(1) = h_m(1)$	16.50	$Q_1 = 15$	15
2	$h_f(2-1)$ 6' of 1"	.90		
3	$H(2)$	17.40		
4	$h_v(2-1)$ (1")	- .49		
5	$h_m(2)$	16.91	$Q_2 = 15.2$	30.20
6	$h_v(3-2)$ (1")	1.97		
7	$h_f(3+2)$ 6' of 1"	3.42		
8	$H(3)$	22.30		
9	$h_v(4-3)$ T+E 1 1/4"	- 1.53		
10	$h_m(3)$	20.77	$Q_3 = 16.8$	47.0
11	$H(3)$ from above	22.30		
12	$h_f(4-3)$ 6' of 1 1/4"	1.98		
13	$H(4)$	24.28		
14	$h_v(5-4)$ T+E 1 1/2"	- 1.63		
15	$h_m(4)$	22.65	$Q_4 = 17.6$	64.6
16	$H(4)$ from above	24.28		
17	$h_f(5-4)$ 6' 1 1/2"	1.68		
18	$H(5)$	25.96		
19	$h_v(6-5)$ T+E 1 1/2"	- 2.70	$Q_5 = 17.8$	
20	$h_m(5)$	23.26		82.4
21	$H(5)$ from above	25.96		
22	$h_f(6-5)$ 6' 1 1/2"	2.70		
23	$H(6)$	28.66		
24	$h_v(7-6)$ T+E 2"	- 1.46		
25	$h_m(6)$	27.20	$Q_6 = 19.2$	101.6
26	$H(6)$ from above	28.66		
27	$h_f(7-6)$ 6' 2"	1.11		
28	$H(7)$	29.77		
29	$h_v(8-7)$ T+E 2"	- 2.20		
30	$h_m(7)$	27.57	$Q_7 = 19.4$	121.0
31	$H(7)$ from above	29.77		
32	$h_f(8-7)$ 6' 2"	1.56		
33	$H(8)$	31.33		
34	$h_v(9-8)$ T+E 2"	- 2.85		
35	$h_m(8)$	28.48	$Q_8 = 19.7$	140.7
36	$H(8)$ from above	31.33		
37	$h_f(9-8)$ 3' 2"	1.05		
38	$H(9)$	32.38		
39	$h_v(9-8)$ from above	2.85		
40	$h_m(9)$	29.53		
41				
42				
43				
44				
45				
46				
47				
48				
49				

5.88

Item No.	Sequence of Calculations	Calculation of Individual Flows	Total Flow G.P.M.
	$h(P) 9$	29.53	$Q_T(9)$
	$h_f(1\frac{1}{2}'' \times 2'' \times 2\frac{1}{2}'' \text{ tee})$		233.4
	$k = 1.3 \quad k_v = 3.85$	5.00	
	$h_f(10-9) \quad 1'' \quad 2\frac{1}{2}'' \text{ pipe } (.38)$.38	
	$\Sigma (10-9)$	1.00	
	$h_m(10)$	35.91	$K_{10} = \frac{233.4}{\sqrt{35.91}} = 39.6$
	$h_f(11-10)$		
	$H(11)$		
	$k_v(11-10)$		
	$h_m(11)$		
	$k_v(12-11)$		
	$h_f(12-11)$		
	$H(12)$		
	$k_v(13-12) \quad T+E$		

$$Q_{TOTAL} = K_{INLET} \sqrt{H_{INLET}}$$

increase H_{inlet} by X to account for ageing

to $X H_{inlet}$

$\therefore Q_{TOTAL}$ will increase by \sqrt{X}

\rightarrow distribute its self.

h_f will increase along lengths of pipe

$$h_{f \text{ ft}} = y h'_{f \text{ ft water}} L$$

we don't know what y is

$$h_{f \text{ OLD}} = y h'_{f} L$$

K may change too

Darcy Weisbach $h_f = f \frac{L}{D} h_v$

$$f = f\left(\frac{\epsilon}{D^{1/2}}\right)$$



Selection of proper pipe size

Curve C-8 Hydraulic Data Manual


eg. 1" pipe ~ 60 gpm, $h_v \approx 20-22$ is about
limit

Try + keep well under 30,
preferably close to 20 or 20-25
for h_v .

Item No.	Sequence of Calculations	Calculation of Individual Flows	Total Flow G.P.M.	
1	$H(1) = h_m(1) (K = 4.8)$	27.15	$Q(1) = 25.0$	25.0
2	$h_f(1" 90^\circ \text{ ell}) K = 1.4 h_v = 1.35 + 1.89$			
3	$H(2)$	29.04	$K_2 = 25 / \sqrt{29.04} = 4.65$	
4	$h_f(3-2) 6'-0" 1" \text{ PIPE } (0.40)$	2.40		
5	$h_f(1" 90^\circ \text{ ell}) \text{ REE ITEM 2}$	1.20		
6	$H(3)$	32.64		
7	$h_v(3-2) 1" \text{ pipe}$	-1.35		
8	$h_m(3)$	31.29	$Q_3 = 4.65 \sqrt{31.29} = 26.0$	51.0
9	$h_v(4-3) 1\frac{1}{2}" \text{ pipe}$	1.87		51.2
10	$h_f(4-3) 6' 1\frac{1}{2}" \text{ pipe } (1.385)$	2.31		
11	$h_f(1\frac{1}{2}" 90^\circ \text{ ell}) K = 1.3 h_v = 1.87$	2.43		
12	$H(4)$	37.90		
13	$h_v(5-4) 1\frac{1}{2}" \text{ pipe T \& E}$	2.40		
14	$h_m(4)$	35.50	$Q_4 = 4.65 \sqrt{35.5} = 27.7$	78.7
15	$h_f(5-4) 2' 1\frac{1}{2}" \text{ pipe } (1.05)$.81		78.9
16	$h_p(5) \text{ (JUNCTION POINT 5)}$	36.31		
17	Branch lines symmetrical about pt 5	36.31	$\therefore Q_5 = 78.7 \times 2 = 157.4$	157.4
18	$h_f(1\frac{1}{2}" \times 1\frac{1}{2}" \times 2" \text{ tee})$ $K = 1.35 h_v = 3.54$	4.77		157.8
19	$h_f(6-5) 5' 2" \text{ pipe } (1.432)$	2.16		
20	$Z(6-5)$	1.00		
21	$h_m(6)$	45.24		
Calculation of Branch line ABC to point 6				
22	$H(a) = h_m(a) (K_m = 4.8)$	27.15	$Q(a) = 25.0$	25.0
23	$h_f(b-a) 3' 1" \text{ pipe } (1.40)$	1.20		
24	$H(b)$	28.35		
25	$h_v(b-a) 1" \text{ pipe}$	1.35		
26	$h_m(b)$	27.00	$Q_b = 1.0 \sqrt{27} = 24.9$	49.9
27	$h_f(b-c) 1' 6" 1\frac{1}{2}" \text{ pipe } (1.369)$.55	24.9	49.9
28	$h_p(c)$	27.55		
Branch lines symmetrical about Junction AC				
29	$h_p(c) \text{ (Item 28)}$	27.55	$Q_c = 49.9 \times 2 = 99.8$	99.8
30	$h_f(1\frac{1}{2}" \times 1\frac{1}{2}" \times 2" \text{ tee})$ $K = 1.35 h_v = 1.42$	1.92		99.8
31	$h_f(RN) 1' 2" \text{ pipe } ()$.18		
32	$h_v(RN) 2" \text{ pipe}$	1.42		
33	$Z(RN)$	1.00	17.6	
34	$H(6) \text{ (Inlet to RN @ point (6))}$	32.07	$K_6 = 99.8 / \sqrt{32.07} = 17.5$	
Continuation from Item 21 @ pt. 6				
35	$h_m(6) \text{ (Item 21)}$	45.24	$Q(6) = 17.5 \sqrt{45.24} = 117.5$	157.4 117.5 274.9
36	Note: Increase flows in Sprinklers A & B above point (6) by			



75
86-3
43 1/2



ELEVATOR PENT
HOUSE CEILING
PLAN - EXTENDS
8' ABOVE ROOF

EXCEPT AS MODIFIED,
ALL DIMENSIONS THE
SAME AS BMT. & 1ST
FLOOR CEILING PLAN.

ROOF PITCHED 2" IN
10' FROM NORTH TO
SOUTH.

SECOND FLOOR CEILING
PLAN (ROOF)


~~XXXXXXXXXX~~
W. G. LABES
SCALE: 1/16" = 1'

30.

S-A-10


$\frac{14}{56} - 4$
 $\frac{55-16}{53-6}$
 $\frac{2-10}{16}$

$\frac{50-10}{58-10}$
 $\frac{53-10}{53-10}$



OPEN ELEVATOR BMT., 1ST. & 2ND

END BEAM BOLTED TO WALL



ENTRANCE 1ST FLOOR THIS BAY

SCHOOL STREET

8" CITY WATER MAIN

BASEMENT & FIRST FLOOR CEILING PLAN

~~NO. 50, 1910~~
 W. G. LABES
 SCALE: $\frac{1}{16}'' = 1'$

$\frac{14}{56}$
 $\frac{55-16}{53-6}$
 $\frac{2-10}{16}$

$\frac{14}{56}$
 $\frac{55-16}{53-6}$
 $\frac{2-10}{16}$

$\frac{14}{56}$
 $\frac{55-16}{53-6}$
 $\frac{2-10}{16}$

420

Exam Jan. 6

$Q_T = \text{~~843~~ } \boxed{Q_T = 843}$ for the water
spray problem.
 $h_m(6)$

~~843~~
 $Q_6 = 280.6 ?$

$Q_5 = 157.8$


$Q \quad ABC \quad 99.72 \rightarrow 122.8$
 $\propto 1.23 \quad \approx 1.25 = \frac{25}{20}$

Pg. 39 ~~of~~ sampled 15
Item b. etc. which fitting
to include + neglect in calculations


FPE 120

12-14-64

If perfectly balanced
no flow
here with all heads open.



$$Q = K_m \sqrt{h_m}$$



if there is flow


$$h_{m1} = \frac{Q^2}{K_m^2}$$

$$H_1 = h_{m1} + h_{v(2-1)}$$

↑
may be $h_{v(1-2)}$
Must must
test experimentally
to find out
for sure

we can get h_n , knowing $Q_1 + R_n$

$$h_{v(2-1)} = \frac{Q_1 + Q_{(1-7)}}{385 \text{ D}^4}$$



420

Fall
1964



FPE DEPARTMENT

TITLE SPRINKLER SYSTEM DESIGN EXP. No. _____

Name LUCHT - FPE 420 Group No. _____

12-14-64

Laboratory Day _____
Grade <u>93</u>
Instructor <u>LABES</u>

Dates Performed _____
Date Presented _____
Returned for Correction _____
Returned After Correction _____


F.P.E. 450

ave 81

93

LUCHT

1. Plans are usually drawn with NORTH at the top or right.
2. Provide flushing connections at the ends of cross mains.
3. Indicate underground supply main or extension - 6" C.I.
4. Provide check valve in F.D. line equipped with ball drip.
5. RE: 1st Story and Basement Plan, believe you may have difficulty with trapped pipe because branch line crosses under girder.
6. Indicated heated pent house or provide for cold weather protection.
7. Label elevator, stairway and elevator pit.
- 8.



5 1/4" x 13 1/4" WOOD BEAMS FRAMED INTO 13" x 17 1/4" WOOD GIRDERS

- UPRIGHT SPRINKLERS (FIRST FL.)
- UPRIGHT SPRINKLERS (BSMT)

BASEMENT AND FIRST FLOOR CEILING PLAN


NOTE:
 FIGURES MARKED THUS * DENOTE DISTANCE DOWN IN INCHES FROM BEAMS TO CENTER OF PIPE

SCALE: 1/8" = 1'

SCHOOL STREET

8" CITY WATER MAIN






SECOND FLOOR OR ROOF PLAN

NOTE:
FIGURES W
DISTANCE
OF JOISTS


46
WET
160'

UPRIGHT SPRINKLERS
CORR. RESISTANT




ISOMETRIC VIEW OF RISER CONNECTIONS

☐ TO ☐ LENGTHS AND FLANGED JOINTS INDICATED



ELEVATION "B-B"



NOTE:

APPROVED CORROSION-RESISTANT OR SPECIAL COATED SPRINKLERS TO BE INSTALLED TO WITHSTAND CORROSIVE VAPORS. ON SECOND FLOOR AND ELEVATOR HOUSE. ALL UPPER STORY PIPING ALSO TO BE PROPERLY PROTECTED.

ALL HANGERS ARE STANDARD U-TYPE FOR THE RESPECTIVE SIZE PIPE AND APPLICATION EXCEPT THOSE OTHERWISE MARKED AS FOLLOWS:


- T TRAPEZE HANGER RING HANGER
- F CEILING FLANGES

HANGERS LOCATED CLOSE TO SPRINKLERS ARE APPROXIMATELY 18" FROM SPRINKLERS

ASSUME 5" FROM DEFLECTOR TO ϕ OF BRANCH LINE

SCALE: $\frac{1}{8}" = 1'$

ES MARKED THUS * DENOTE DISTANCE IN INCHES FROM BOTTOM JOISTS TO CENTER OF PIPE.



D. LUCHT
F.P.E. 397
15-14-51



ILLINOIS INSTITUTE OF TECHNOLOGY

NAME D. LUCHT

SUBJECT _____

CLASS _____ DATE _____

INSTRUCTOR _____

1	5	11	
2	✓	12	
3		13	
4		14	
5	∞	15	
6		16	
7		17	
8		18	
9		19	
10		20	

5
—
95

2. Using the same scheme for branch line calculation, the total head causing flow ~~at~~ for any part of a branch line for its respective calculated flow may be found. e.g. H and Q (total head and flow) the relationships between H & Q may be expressed as

$$Q = K\sqrt{H}$$

where K is a constant. This is valid since all flow-pressure parameters in the line follow the same relationships, a.e.

$$Q = K_v \sqrt{H_v} \quad \text{for vel. head}$$

$$Q = K_f \sqrt{H_f} \quad \text{for friction loss}$$


It must be noted that elevation head does not follow the same relationship, but for ordinary drainage requirements,

the effect is negl.


Knowing this relationship
therefore, enables one to substitute
an orifice for the particular
part of the branch which exhibits
the same relationship

$$Q = K\sqrt{H}$$

with identically the same K value.



Itm. No.	Sequence of Calculations	Calculation of Individual Flows	Total Flow G.P.M.
	- Branch Line A -		
1.	Assume a flow in head # 1 and find h_m from curves or knowing K value of sprinkler		
2.	$H(1) = h_m(1)$ $+ h_f(2-1)$ $+ 0$ (elevation diff. negl.) $H(2)$ $- h_v(2-1)$ $h_m(2)$ $+ h_f(3-2)$ $+ h_v(3-2)$ $H(3)$ $- h_v(4-3)$ T+E $h_m(3)$ $H(3)$ from above $+ h_f(4-3)$ $H(4)$ $- h_v(5-4)$ T+E $h_m(4)$ $+ h_f(5-4)$ $H(P) 5$	Q_1 ✓ Q_2 ✓ Q_3 ✓ Q_4 ✓	Q_1 ✓ $Q_1 + Q_2$ ✓ $Q_1 + Q_2 + Q_3$ ✓ etc. ✓
	Now Calculate Right Branch line of A same as left and get another $h(P) 5'$ since $h(P) 5 \neq h(P) 5'$ multiply the flow into the lower pressure line by $\sqrt{\frac{h(P) 5'}{h(P) 5}}$ (which it will be assumed) in 71	Assume $h_{P5} > h_{P5}'$ $\therefore \sqrt{\frac{h_{P5}}{h_{P5}'}}$	
	To this product add the flow in the other branch and get total flow into RNA		Q_A ✓
	$h(P) 5$ $+ h_f$ in the at top of RNA $+ h_v$ in RNA $+ \text{length of RNA}$ $+ h_f$ in RNA H (at bottom of RNA)		



5

Itm. No.	Sequence of Calculations	Calculation of Individual Flows	Total Flow G.P.M.
✓	$K(RN)A = \frac{Q_A}{\sqrt{H(\text{bottom } RNA)}}$		
✓	$H(\text{bottom of } RNA)$		
✓	$+ h_f(B-A)$		
✓	$\frac{H(B)}{h_v(B)}$		
✓	$- h_v(B-A)$		
✓	$h_m(B) \Rightarrow Q_B = K_B \sqrt{h_m(B)}$	(Must adjust flows in heads in lines B)	$Q_A + Q_B$
	(calculate K_B same as K_A)		
✓	$h_m(B)$		
✓	$+ h_v(C-B)$		
✓	$+ h_f(C-B)$		
✓	$\frac{H(C)}{h_v(C)}$		
✓	$- h_v(D-C) T+E$		
✓	$h_m(C) \quad Q_C = K_A \sqrt{h_m(C)}$		$Q_A + Q_B + Q_C$
	Follow this same procedure which is identical to the Branch line calculation using $\checkmark K_A = K_C = K_E$ $\checkmark K_B = K_D = K_F$		
	until $h_m(F)$ is obtained (head causing flow at bottom of RN F.		
	to $h_m(F)$ add h_f from RNF to the alarm check valve plus the elevation difference and obtain the pressure head at the valve at the calculated total flow, Q_T		
	where $Q_T = Q_A + Q_B + Q_C + Q_D + Q_E + Q_F$		
	Suggest you start with H_F instead of $h_m(F)$. and then subtract $h_v(4" Rise)$ from $H(4" Rise)$ to get $h_P(4" Rise)$. You can visualize that $h_v(G-F) \Rightarrow h_v(4" RISER)$.		

See p22 (2A)

PHYSICAL PROPERTIES OF CARBON DIOXIDE

Courtesy
Cardox Corporation
Bell Building
Chicago, Illinois

Table 9
Solid and Saturated Carbon Dioxide

(Values from Plank and Kuprianoff (6) converted by G. C. Hodsdon (7), arranged by Editor)

Temp. °F t	Pressure lb./in. ² p	Volume		Total Heat from -40°			Entropy from -40° plus 1.0	
		Solid ft. ³ /lb. v _f	Vapor ft. ³ /lb. v _g	Solid Btu./lb. h _f	Latent Btu./lb. h	Vapor Btu./lb. h _g	Solid Btu./lb.°F s _f	Vapor Btu./lb.°F s _g
-140	3.18	0.01008	24.320	-121.5	250.7	129.2	0.6847	1.4690
-130	5.39	0.01012	14.740	-118.8	249.4	130.6	0.6932	1.4500
-120	8.90	0.01018	9.179	-116.0	248.0	132.0	0.7014	1.4418
-115	11.31	0.01021	7.279	-114.6	247.3	132.7	0.7055	1.4231
-110	14.22	0.01024	5.848	-113.2	246.4	133.2	0.7096	1.4145
-109	14.88	0.01025	5.597	-112.9	246.2	133.3	0.7105	1.4128
-108	15.57	0.01026	5.358	-112.6	246.0	133.4	0.7114	1.4111
-107	16.29	0.01027	5.129	-112.3	245.8	133.5	0.7123	1.4085
-106	17.04	0.01027	4.911	-112.0	245.6	133.6	0.7132	1.4079
-105	17.82	0.01028	4.703	-111.6	245.4	133.8	0.7141	1.4063
-104	18.63	0.01029	4.505	-111.3	245.2	133.9	0.7150	1.4045
-103	19.48	0.01030	4.316	-111.0	245.0	134.0	0.7159	1.4029
-102	20.36	0.01031	4.138	-110.7	244.8	134.1	0.7168	1.4013
-101	21.27	0.01031	3.967	-110.4	244.6	134.2	0.7177	1.3997
-100	22.22	0.01032	3.804	-110.1	244.4	134.3	0.7185	1.3981
-99	23.20	0.01033	3.648	-109.8	244.1	134.3	0.7194	1.3965
-98	24.22	0.01033	3.499	-109.5	243.9	134.4	0.7203	1.3949
-97	25.28	0.01034	3.357	-109.2	243.6	134.4	0.7212	1.3933
-96	26.39	0.01035	3.222	-108.9	243.4	134.5	0.7221	1.3917
-95	27.54	0.01035	3.093	-108.5	243.2	134.7	0.7231	1.3901
-94	28.73	0.01036	2.970	-108.1	242.9	134.8	0.7241	1.3905
-93	29.97	0.01037	2.852	-107.8	242.7	134.9	0.7251	1.3969
-92	31.26	0.01038	2.738	-107.4	242.4	135.0	0.7261	1.3953
-91	32.69	0.01039	2.629	-107.0	242.1	135.1	0.7271	1.3937
-90	33.98	0.01040	2.525	-106.7	241.8	135.1	0.7281	1.3821
-89	35.41	0.01040	2.425	-106.3	241.5	135.2	0.7291	1.3806
-88	36.89	0.01041	2.330	-105.9	241.1	135.2	0.7302	1.3790
-87	38.43	0.01042	2.240	-105.5	240.8	135.3	0.7313	1.3774
-86	40.02	0.01043	2.153	-105.1	240.4	135.3	0.7323	1.3758
-85	41.67	0.01044	2.070	-104.6	240.1	135.5	0.7333	1.3742
-84	43.38	0.01045	1.995	-104.2	239.7	135.5	0.7344	1.3727
-83	45.15	0.01046	1.913	-103.8	239.3	135.5	0.7355	1.3711
-82	46.98	0.01047	1.839	-103.4	238.9	135.5	0.7366	1.3695
-81	48.88	0.01048	1.768	-103.0	238.6	135.6	0.7377	1.3679
-80	50.85	0.01048	1.700	-102.5	238.2	135.7	0.7399	1.3663
-79	52.89	0.01049	1.636	-102.0	237.7	135.7	0.7400	1.3648
-78	55.00	0.01050	1.575	-101.5	237.3	135.8	0.7412	1.3632
-77	57.19	0.01051	1.516	-101.1	236.9	135.3	0.7424	1.3616
-76	59.45	0.01052	1.460	-100.5	236.4	135.8	0.7436	1.3600
-75	61.79	0.01053	1.407	-100.2	236.0	135.8	0.7447	1.3584
-74	64.21	0.01054	1.356	-99.8	235.6	135.8	0.7458	1.3568
-73	66.72	0.01055	1.306	-99.3	235.1	135.8	0.7469	1.3553
-72	69.33	0.01057	1.257	-98.9	234.8	135.9	0.7481	1.3538
-71	72.03	0.01058	1.209	-98.4	234.3	135.9	0.7493	1.3523
-70	74.82	0.01059	1.162	-98.0	233.9	135.9	0.7506	1.3508
-69.9	75.10	0.01059	1.157	-97.9	233.8	135.9	0.7507	1.3506

Table 10
Saturated Carbon Dioxide

Temp. °F t	Pressure lb./in. ² p	Volume		Total Heat from -40°			Entropy from -40° plus 1	
		Liquid ft. ³ /lb. v _f	Vapor ft. ³ /lb. v _g	Liquid Btu./lb. h _f	Latent Btu./lb. h	Vapor Btu./lb. h _g	Liquid Btu./lb.°F s _f	Vapor Btu./lb.°F s _g
-69.9	75.1	0.01360	1.1570	-13.7	149.6	135.9	0.9677	1.3506
-68.0	78.6	0.01365	1.1080	-12.9	148.9	136.2	0.9688	1.3490
-66	82.4	0.01369	1.0589	-11.9	148.1	136.2	0.9711	1.3474
-64	86.4	0.01374	1.0125	-11.0	147.3	136.0	0.9734	1.3459
-62	90.5	0.01379	0.9686	-10.1	146.6	136.5	0.9757	1.3444
-60	94.7	0.01384	0.9270	-9.2	145.8	136.6	0.9777	1.3429
-58	99.1	0.01389	0.8875	-8.3	145.0	136.7	0.9802	1.3414
-56	103.7	0.01393	0.8502	-7.4	144.2	136.8	0.9824	1.3399
-54	108.4	0.01398	0.8149	-6.5	143.4	136.9	0.9847	1.3384
-52	113.2	0.01404	0.7812	-5.6	142.7	137.1	0.9869	1.3369
-50	118.2	0.01409	0.7492	-4.7	141.9	137.2	0.9892	1.3354
-48	123.4	0.01414	0.7188	-3.8	141.1	137.3	0.9913	1.3340
-46	128.7	0.01420	0.6899	-2.9	140.3	137.4	0.9935	1.3326
-44	134.2	0.01425	0.6624	-2.0	139.5	137.5	0.9957	1.3312
-42	139.9	0.01431	0.6362	-1.0	138.7	137.7	0.9978	1.3298
-40	145.8	0.01437	0.6113	.00	137.8	137.8	1.0000	1.3285
-38	151.8	0.01442	0.5876	+ .9	136.9	137.8	1.0021	1.3271
-36	158.0	0.01448	0.5649	1.8	136.2	138.0	1.0043	1.3257
-34	164.4	0.01454	0.5433	2.7	135.4	138.1	1.0064	1.3244
-32	171.0	0.01460	0.5227	3.6	134.5	138.1	1.0085	1.3231
-30	177.8	0.01466	0.5029	4.5	133.7	138.2	1.0107	1.3218
-28	184.8	0.01472	0.4841	5.4	132.9	138.3	1.0127	1.3206
-26	192.0	0.01479	0.4661	6.3	132.0	138.3	1.0148	1.3193
-24	199.4	0.01485	0.4489	7.2	131.2	138.4	1.0169	1.3180
-22	207.0	0.01491	0.4325	8.1	130.3	138.4	1.0190	1.3167
-20	214.9	0.01498	0.4168	9.1	129.4	138.5	1.0212	1.3154
-18	223.0	0.01504	0.4092	10.1	128.5	138.6	1.0232	1.3140
-16	231.2	0.01511	0.3872	11.1	127.6	138.7	1.0252	1.3127
-14	239.6	0.01518	0.3666	12.0	126.7	138.7	1.0272	1.3115
-12	248.3	0.01525	0.3600	12.9	125.8	138.7	1.0283	1.3103
-10	257.3	0.01532	0.3472	13.9	124.8	138.7	1.0314	1.3091
-8	266.5	0.01540	0.3349	14.9	123.9	138.8	1.0334	1.3078
-6	275.9	0.01547	0.3231	15.9	122.9	138.8	1.0355	1.3065
-4	285.4	0.01555	0.3118	16.9	122.0	138.9	1.0376	1.3053
-2	295.3	0.01563	0.3009	17.9	121.0	138.9	1.0397	1.3041
0	305.5	0.01570	0.2904	18.8	120.1	138.9	1.0418	1.3029
2	315.9	0.01579	0.2803	19.8	119.0	138.8	1.0439	1.3017
4	326.5	0.01588	0.2707	20.8	118.0	138.8	1.0460	1.3006
6	337.4	0.01596	0.2614	21.8	116.9	138.7	1.0481	1.2994
8	348.7	0.01605	0.2526	22.9	115.8	138.7	1.0502	1.2982
10	360.2	0.01614	0.2437	24.0	114.7	138.7	1.0536	1.2980
12	371.9	0.01623	0.2354	25.0	113.6	138.6	1.0558	1.2967
14	383.9	0.01632	0.2274	26.1	112.5	138.6	1.0580	1.2955
16	396.2	0.01642	0.2197	27.2	111.3	138.5	1.0602	1.2943
18	408.9	0.01652	0.2121	28.3	110.1	138.4	1.0625	1.2931

TRIPPLE POINT →

atm

atm

Saturated Carbon Dioxide (concluded)

Temp. °F	Pressure lb./in. ² <i>p</i>	Volume		Total Heat from -40°			Entropy from -40° plus 1	
		Liquid ft. ³ /lb. <i>v_l</i>	Vapor ft. ³ /lb. <i>v_g</i>	Liquid Btu./lb. <i>h_l</i>	Latent Btu./lb. <i>h</i>	Vapor Btu./lb. <i>h_g</i>	Liquid Btu./lb.°F <i>s_l</i>	Vapor Btu./lb.°F <i>s_g</i>
20	421.8	0.01663	0.2049	29.4	108.9	138.3	1.0648	1.2919
22	434.0	0.01673	0.1979	30.5	107.7	138.2	1.0672	1.2907
24	448.4	0.01684	0.1912	31.7	106.4	138.1	1.0696	1.2595
26	462.2	0.01695	0.1846	32.9	105.1	138.0	1.0720	1.2883
28	476.3	0.01707	0.1783	34.1	103.8	137.9	1.0744	1.2871
30	490.8	0.01719	0.1722	35.4	102.4	137.8	1.0768	1.2859
32	505.5	0.01731	0.1663	36.7	101.0	137.7	1.0792	1.2844
34	502.6	0.01744	0.1603	37.9	99.5	137.4	1.0875	1.2830
36	536.0	0.01759	0.1550	39.1	98.1	137.2	1.0838	1.2816
38	551.7	0.01773	0.1496	40.4	96.5	136.9	1.0873	1.2801
40	567.8	0.01787	0.1444	41.7	95.0	136.7	1.0884	1.2786
42	584.3	0.01801	0.1393	42.9	93.4	136.3	1.0907	1.2771
44	601.1	0.01817	0.1344	44.3	91.8	136.1	1.0932	1.2756
46	618.2	0.01834	0.1297	45.6	90.1	135.7	1.0958	1.2741
48	635.7	0.01851	0.1250	47.0	88.4	135.4	1.0996	1.2725
50	653.6	0.01868	0.1205	48.4	86.6	135.0	1.1010	1.2709
52	671.9	0.01887	0.1161	49.8	84.7	134.5	1.1036	1.2700
54	690.6	0.01906	0.1117	51.2	82.7	133.9	1.1064	1.2674
56	709.5	0.01927	0.1075	52.6	80.8	133.4	1.1075	1.2657
58	728.8	0.01948	0.1034	54.0	78.7	132.7	1.1104	1.2638
60	748.6	0.01970	0.0994	55.5	76.6	132.1	1.1145	1.2618
62	768.9	0.01994	0.0956	57.0	74.4	131.4	1.1174	1.2597
64	789.4	0.02020	0.0918	57.6	72.0	130.6	1.1202	1.2575
66	810.3	0.02048	0.0880	60.2	69.5	129.7	1.1230	1.2552
68	831.6	0.02079	0.08422	61.9	66.8	128.7	1.1260	1.2526
70	853.4	0.02112	0.08040	63.7	63.8	127.5	1.1292	1.2497
72	875.5	0.02150	0.07657	65.5	60.7	126.2	1.1324	1.2466
74	898.2	0.02192	0.07269	67.3	57.2	124.5	1.1360	1.2432
76	921.3	0.02242	0.06875	69.4	53.4	122.8	1.1399	1.2396
78	944.8	0.02300	0.06473	71.6	49.3	120.9	1.1441	1.2357
80	968.7	0.02370	0.06064	73.9	44.8	118.7	1.1486	1.2314
82	993.0	0.02456	0.05648	76.4	40.2	116.6	1.1532	1.2271
84	1017.7	0.02553	0.05223	79.4	34.5	113.9	1.1582	1.2215
86	1043.0	0.02686	0.04789	83.3	27.1	110.4	1.1646	1.2143
87.8	1066.2	0.03454	0.03454	97.0	0.0	97.0	1.1890	1.1890

Table 11. Superheated Carbon Dioxide
(Transcribed from data of Plank and Kuprianoff (6) by graphical means.)

Temp. °F	Abs. Pressure one atmosphere (Sat'n. Temp. = -110.02°F.)			Abs. Pressure 20 (Sat'n. Temp. = -103.3°F.)			30 (Sat'n. Temp. = -92.6°F.)			40 (Sat'n. Temp. = -85.9°F.)			
	<i>t</i>	<i>V</i>	<i>H</i>	<i>S</i>	<i>V</i>	<i>H</i>	<i>S</i>	<i>V</i>	<i>H</i>	<i>S</i>	<i>V</i>	<i>H</i>	<i>S</i>
at sat'n	6.39	133.3	1.414	4.70	133.5	1.403	2.70	134.5	1.387	1.99	136.0	1.375	
-100	6.41	134.7	1.419	4.71	133.7	1.405							
-90	6.50	136.7	1.424	4.77	135.8	1.411							
-80	6.60	138.7	1.429	4.84	137.9	1.417	2.80	137.1	1.395	2.01	136.3	1.380	
-70	6.70	140.7	1.434	4.92	140.0	1.423	2.90	139.2	1.400	2.08	138.4	1.386	
-60	6.82	142.7	1.438	5.00	142.1	1.429	3.00	141.3	1.405	2.15	140.5	1.392	
-50	6.96	144.7	1.442	5.10	144.2	1.435	3.10	143.4	1.410	2.22	142.6	1.398	
-40	7.10	146.7	1.446	4.20	146.3	1.440	3.20	145.5	1.415	2.30	144.7	1.404	
-30	7.26	148.7	1.450	4.36	148.4	1.445	3.30	147.6	1.420	2.38	146.8	1.410	
-20	7.45	150.7	1.454	4.55	150.5	1.450	3.40	149.7	1.425	2.46	148.9	1.415	
-10					152.6	1.455	3.50	151.8	1.430	2.52	151.0	1.420	
0					154.7	1.460	3.60	153.9	1.435	2.60	153.1	1.425	
10					156.8	1.465	3.74	156.0	1.440	2.69	155.2	1.430	
20					158.8	1.470	3.90	158.2	1.445	2.79	157.4	1.435	
30										2.89	159.5	1.440	
40										3.00	161.6	1.445	
50											3.10	163.7	1.450
60											3.20	165.8	1.455
70											3.30	167.9	1.460
80											3.40	170.0	1.465
90											3.52	172.1	1.470
100											3.65	174.4	1.475
110											3.79	176.5	1.480
Temp. °F.	50 (Sat'n. Temp. = -79.9°F.)			60 (Sat'n. Temp. = -75.2°F.)			70 (Sat'n. Temp. = -71.1°F.)			80 (Sat'n. Temp. = -66.9°F.)			
<i>t</i>	<i>V</i>	<i>H</i>	<i>S</i>	<i>V</i>	<i>H</i>	<i>S</i>	<i>V</i>	<i>H</i>	<i>S</i>	<i>V</i>	<i>H</i>	<i>S</i>	
at sat'n	1.70	135.5	1.365	1.42	136.0	1.359	1.22	136.3	1.350	1.09	136.6	1.345	
-70	1.77	137.8	1.370	1.50	137.2	1.363	1.23	136.5	1.353				
-60	1.81	139.7	1.377	1.52	139.4	1.370	1.25	138.7	1.360				
-50	1.85	142.2	1.384	1.54	141.6	1.376	1.27	140.9	1.367	1.14	140.3	1.362	
-40	1.90	144.5	1.391	1.58	143.8	1.382	1.30	143.1	1.373	1.16	142.5	1.369	
-30	1.95	146.7	1.398	1.62	146.0	1.388	1.33	145.3	1.379	1.18	144.7	1.376	
-20	2.00	148.9	1.404	1.66	148.2	1.394	1.37	147.5	1.385	1.20	146.9	1.383	
-10	2.05	151.1	1.410	1.70	150.4	1.400	1.41	149.7	1.391	1.22	149.1	1.390	
0	2.10	153.3	1.416	1.74	152.6	1.406	1.45	151.9	1.397	1.25	151.3	1.396	
10	2.15	155.5	1.421	1.76	154.8	1.412	1.50	154.1	1.403	1.28	153.5	1.402	
20	2.20	157.7	1.426	1.80	157.0	1.418	1.55	156.3	1.409	1.32	155.7	1.408	
30	2.25	159.9	1.431	1.84	159.2	1.424	1.60	158.5	1.415	1.37	157.8	1.414	
40	2.30	162.1	1.436	1.88	161.4	1.430	1.65	160.7	1.421	1.43	160.0	1.420	
50	2.35	164.3	1.441	1.92	163.6	1.435	1.70	162.9	1.427	1.50	162.3	1.425	
60	2.40	166.5	1.446	1.96	164.8	1.440	1.75	164.1	1.433	1.58	163.5	1.435	
70	2.45	168.7	1.451	2.00	167.0	1.445	1.80	166.3	1.439	1.66	165.7	1.435	
80	2.50	170.9	1.456	2.04	169.2	1.450	1.85	168.5	1.445	1.74	167.9	1.440	
90	3.55	173.1	1.461	2.08	171.4	1.455	1.90	170.7	1.450	1.82	170.1	1.445	
100	2.60	175.3	1.466	2.12	173.6	1.460	1.96	172.9	1.455	1.90	172.3	1.450	

Superheated Carbon Dioxide (continued)

Temp. °F.	100 (Sat'n. Temp. = -57.0°F.)			150 (Sat'n. Temp. = -39.0°F.)			200 (Sat'n. Temp. = -26.5°F.)			250 (Sat'n. Temp. = -13.37°F.)		
	V	H	S	V	H	S	V	H	S	V	H	S
at sat'n	.36	137.3	1.337	.59	1.332	1.327	.476	133.8	1.320	.378	139.2	1.318
-50	0.890	138.7	1.342									
-40	0.945	141.0	1.349									
-30	0.995	143.3	1.356	0.605	140.1	1.334						
-20	1.045	145.6	1.363	0.640	142.6	1.341						
-10	1.095	147.9	1.369	0.670	145.1	1.348	0.51	142.4	1.331	0.38	140.0	1.317
0	1.14	150.2	1.375	0.700	147.6	1.355	0.53	144.8	1.338	0.40	142.5	1.324
10	1.18	152.5	1.381	0.725	150.1	1.362	0.55	147.3	1.345	0.42	145.0	1.330
20	1.22	154.8	1.386	0.750	152.4	1.368	0.57	149.8	1.351	0.44	147.5	1.335
30	1.26	157.1	1.391	0.775	154.8	1.373	0.59	152.3	1.356	0.46	150.0	1.340
40	1.30	159.4	1.396	0.800	157.2	1.379	0.61	154.8	1.361	0.48	152.5	1.345
50	1.33	161.7	1.401	0.825	159.6	1.384	0.63	157.3	1.366	0.49	155.0	1.350
60	1.36	164.0	1.406	0.850	162.0	1.389	0.65	159.8	1.371	0.50	157.5	1.355
70	1.39	166.3	1.411	0.877	164.4	1.394	0.67	162.3	1.376	0.51	160.0	1.360
80	1.42	168.6	1.416	0.905	166.8	1.398	0.69	164.8	1.381	0.52	162.5	1.365
90	1.45	170.9	1.420	0.928	169.2	1.402		167.3	1.386	0.53	165.0	1.370
100	1.48	173.2	1.424	0.950	171.8	1.410	0.71	169.8	1.391	0.55	167.3	1.375
120	1.52	177.6	1.432	0.992	176.3	1.417	0.75	174.6	1.401	0.57	172.3	1.384
140	1.56	182.0	1.440	1.030	180.8	1.424	0.78	179.4	1.410	0.59	177.3	1.393
160	1.60	186.4	1.447	1.066	185.3	1.431	0.81	184.2	1.418	0.61	182.3	1.401
180	1.630	190.8	1.454	1.100	189.8	1.437	0.84	188.0	1.425	0.63	187.3	1.409
200	1.660	195.3	1.461	1.130	194.3	1.443	0.87	193.3	1.430	0.65	192.3	1.417

Temp. °F.	300 (Sat'n. Temp. = -2.0°F.)			350 (Sat'n. Temp. = 7.2°F.)			400 (Sat'n. Temp. = 15.7°F.)			450 (Sat'n. Temp. = 24.0°F.)		
	V	H	S	V	H	S	V	H	S	V	H	S
at sat'n	.30	139.4	1.305	.250	139.4	1.298	.216	139.5	1.292	.18	138.6	.288
0	0.31	139.9	1.308									
10	0.33	142.5	1.315	0.26	140.5	1.300						
20	0.35	145.1	1.324	0.28	143.5	1.307	0.22	140.5	1.295			
30	0.36	147.7	1.326	0.30	146.5	1.313	0.24	143.5	1.301	0.18	141.0	1.288
40	0.37	150.3	1.331	0.31	148.3	1.318	0.25	146.3	1.307	0.19	144.3	1.294
50	0.38	152.9	1.336	0.32	151.0	1.323	0.26	149.0	1.313	0.20	147.4	1.300
60	0.39	155.5	1.344	0.33	153.7	1.328	0.27	151.7	1.318	0.21	150.2	1.306
70	0.40	158.1	1.346	0.34	156.4	1.333	0.28	154.4	1.323	0.22	153.0	1.312
80	0.41	160.7	1.351	0.35	159.1	1.338	0.29	157.1	1.328	0.23	155.8	1.318
90	0.42	163.3	1.356	0.36	161.8	1.343	0.30	159.8	1.333	0.24	158.6	1.324
100	0.43	165.9	1.361	0.37	164.5	1.348	0.31	162.5	1.338	0.25	161.4	1.330
110	0.44	168.5	1.366	0.38	167.2	1.353	0.32	165.2	1.343	0.26	164.2	1.335
120	0.45	171.1	1.371	0.39	169.9	1.358	0.33	167.9	1.348	0.27	167.0	1.340
130	0.46	173.7	1.376	0.40	172.6	1.363	0.34	170.6	1.353	0.28	169.8	1.345
140	0.47	176.3	1.381	0.41	175.3	1.368	0.35	173.3	1.358	0.29	172.6	1.350
150	0.48	178.9	1.386	0.42	177.9	1.373	0.36	176.0	1.363	0.30	175.4	1.355
160	0.49	181.5	1.390	0.43	180.5	1.378	0.37	178.7	1.368	0.31	178.1	1.360
170	0.50	184.0	1.394	0.44	183.1	1.383	0.38	181.4	1.373	0.32	180.8	1.365
180	0.51	186.5	1.398	0.45	185.7	1.387	0.39	184.1	1.377	0.32	183.5	1.370
190	0.52	189.0	1.402	0.46	188.3	1.391	0.40	186.8	1.380	0.34	186.2	1.375
200	0.53	191.4	1.406	0.47	190.5	1.395	0.41	189.6	1.384	0.35	188.7	1.380

Superheated Carbon Dioxide (continued)

Temp. °F.	700 (Sat'n. Temp. = 55.6°F.)			800 (Sat'n. Temp. = 65.0°F.)			900 (Sat'n. Temp. = 73.8°F.)			1000 (Sat'n. Temp. = 82.1°F.)		
	V	H	S	V	H	S	V	H	S	V	H	S
at sat'n	.100	133.8	1.263	.087	130.4	1.250	.070	124.0	1.240	.05	114.8	1.218
60	0.11	137.3	1.270									
70	0.12	142.5	1.281	0.112	134.5	1.264						
80	0.130	146.2	1.291	0.120	140.1	1.274	0.082	132.0	1.246			
90	0.14	149.3	1.300	0.127	144.5	1.283	0.093	138.5	1.256	0.064	130.5	1.227
100	0.150	153.5	1.308	0.127	148.0	1.291	0.101	143.0	1.265	0.086	138.5	1.252
110	0.16	157.0	1.315	0.134	151.9	1.298	0.108	148.5	1.273	0.100	143.5	1.267
120	0.17	160.0	1.320	0.141	155.5	1.304	0.114	153.0	1.290	0.107	149.5	1.277
130	0.18	162.8	1.325	0.141	159.0	1.310	0.121	157.0	1.296	0.112	154.0	1.284
140	0.19	166.0	1.330	0.153	163.4	1.315	0.128	160.9	1.301	0.117	158.5	1.290
150	0.197	169.0	1.335	0.159	166.4	1.320	0.134	164.4	1.308	1.112	162.0	1.296
160	0.204	172.0	1.339	0.165	169.4	1.325	0.140	167.7	1.314	0.127	165.2	1.302
170	0.211	175.0	1.343	0.171	172.4	1.330	0.145	170.9	1.320	0.132	168.4	1.308
180	0.218	178.0	1.347	0.177	175.4	1.335	0.150	173.9	1.326	0.136	171.6	1.314
190	0.225	181.0	1.351	0.183	178.4	1.340	0.155	176.9	1.331	0.140	174.8	1.320
200	0.231	184.0	1.355	0.190	181.4	1.345	0.160	179.9	1.336	0.144	178.0	1.326
210	0.237	187.0	1.359	0.196	184.4	1.350	0.165	182.9	1.341	0.148	181.3	1.332
220	0.243	190.0	1.363	0.202	187.4	1.358	0.170	185.9	1.346	0.152	184.4	1.338
230	0.249	192.8	1.367	0.208	190.4	1.359	0.175	188.9	1.351	0.156	187.6	1.349
240	0.255	195.6	1.371	0.214	193.4	1.363	0.180	191.9	1.356	0.160	190.8	1.349
250	0.260	198.1	1.375	0.219	196.5	1.367	0.185	195.0	1.361		193.5	1.354

Superheated Carbon Dioxide (concluded)

Temp. °F.	1100			1200			1300			1400		
	V	H	S	V	H	S	V	H	S	V	H	S
at sat'n	--	--	--	--	--	--	--	--	--	--	--	--
0												
20												
40												
60												
80												
100	0.060	129.0	1.252	0.05	111.0	1.240						
120	0.090	143.5	1.266	0.077	137.5	1.255	0.064	131.0	1.244	0.050	124.5	1.234
140	0.100	153.8	1.280	0.09	150.0	1.270	0.074	144.0	1.260	0.070	140.5	1.252
160	0.109	161.5	1.293	0.096	158.0	1.284	0.083	155.3	1.275	0.080	152.0	1.269
180	0.118	168.5	1.306	0.104	166.3	1.298	0.090	164.3	1.289	0.087	162.5	1.285
200	0.127	176.0	1.318	0.112	174.0	1.313	0.089	172.0	1.303	0.094	170.0	1.300
220	0.136	182.0	1.320	0.120	180.2	1.325	0.107	178.3	1.317	0.101	176.5	1.314
240	0.144	188.0	1.342	0.128	186.4	1.336	0.115	184.6	1.331	0.108	183.0	1.326
260	0.152	194.0	1.354	0.138	192.6	1.347	0.124	190.9	1.343	0.115	189.5	1.356
280		200.0	1.363	0.143	198.8	1.357	0.132	196.2	1.352	0.122	196.0	1.346
300	0.160	206.0	1.372	0.150	204.8	1.367	0.140	203.6	1.361	0.129	202.5	1.355

CARBON DIOXIDE FLOW IN PIPE LINES

<u>PART NO.</u>	<u>DESCRIPTION</u>	<u>EQUIVALENT LENGTH (FEET)*</u>
1	Cylinder Valve Assembly	110 ft. 1/2" Schedule 40 Pipe
2	Time Delay	20 ft. 1/2" Schedule 40 Pipe
3	1/2" Selector Valve	20 ft. 1/2" Schedule 40 Pipe
4	3/4" Selector Valve	25 ft. 3/4" Schedule 40 Pipe
5	1" Selector Valve	30 ft. 1" Schedule 80 Pipe
6	1-1/4" Selector Valve	45 ft. 1-1/4" Schedule 80 Pipe
7	1-1/2" Selector Valve	60 ft. 1-1/2" Schedule 80 Pipe
8	2" Selector Valve	75 ft. 2" Schedule 80 Pipe
9	2-1/2" Selector Valve	125 ft. 2-1/2" Schedule 80 Pipe
10	3" Selector Valve	145 ft. 3" Schedule 80 Pipe
11	1/2" Check Valve	10 ft. 1/2" Schedule 40 Pipe
12	3/4" Check Valve	20 ft. 3/4" Schedule 40 Pipe
13	1" Check Valve	15 ft. 1" Schedule 80 Pipe
14	1-1/4" Check Valve	30 ft. 1-1/4" Schedule 80 Pipe
15	1-1/2" Check Valve	55 ft. 1-1/2" Schedule 80 Pipe
16	2" Check Valve	60 ft. 2" Schedule 80 Pipe
17	2-1/2" Check Valve	70 ft. 2-1/2" Schedule 80 Pipe
18	3" Check Valve	100 ft. 3" Schedule 80 Pipe

Note:

Adjustment can be made for a small difference in Pipe Diameter
(Such as from Schedule 80 to Schedule 40) by the formula:

$$L_1 = \frac{D_1}{D_2} 5.25$$

*values to be used in class problem calculations until other values are officially published.

NOTES ON CARBON DIOXIDE FLOW THROUGH PIPES AND ORIFICES

LIQUID-GAS FLOW IN PIPES

See pg 2

"The simultaneous flow of liquids and gases in pipes is complicated by the fact that the action of gravity tends to cause settling and slip of the liquid with the result that the gas flows at a different velocity in the pipe than does the liquid. The pressure drop is greater in liquid-gas flow than that for the single phase flow of either gas or liquid for several reasons. Some of the reasons are the irreversible work done on the liquid by the gas and that the effective cross-sectional area of flow for either fluid is reduced by the flow of the other fluid." The above quotation was taken from Lapple (1).

As explained by Hesson, page 3 (2), "Liquid carbon dioxide is discharged rather than vapor (in a fire extinguishing system) because the discharge rate is greater for a given piping system, the fire extinguishing action is better, and withdrawal of vapor would cause too large a pressure recession in the storage vessel."

Hesson continues, "When the saturated liquid carbon dioxide is discharged through the pipeline, a reduction of pressure occurs due to flow friction loss and the conversion of pressure head to velocity head. This reduction in pressure causes a flashing or boiling of the liquid to form a vapor phase and also causes a reduction in temperature of the mixture of liquid and vapor. This formation of vapor causes a progressive decrease in density and increase in velocity of the mixture of liquid and vapor as it flows down the pipeline. This decrease in density and increase in velocity causes a progressive increase in the rate of pressure drop per unit of pipe length as the two-phase mixture flows farther down the pipeline. Because of this change in density and velocity which result in a variable rate of pressure drop per unit length of pipeline, the usual formulae and tables for determining pressure loss and flow rates can not be used."

wt. rate of flow const.
but density decreases +
∴ vel. increases

Assuming continuous flow of carbon dioxide in a pipeline (steady state conditions), for a system in which the change in elevation dZ is zero or can be neglected, equations for a material balance and mechanical energy balance can be written as follows:

$G = U^2 = \text{Constant}$ wt. rate of flow (Eq. 1)

$\frac{144 dP}{\rho} + \frac{W U dU}{g} + f \frac{U^2}{2g D/12} dL = 0$ (Eq. 2)

Review
therms.

In Equation 2, the first term represents the change in pressure or head energy, the second term represents the change in velocity energy, and the third term represents the change in friction energy.

Certain aspects of the thermodynamics of the fluid system under discussion is considered by Hesson (2), page 11, "If there were no change in velocity energy, the flow would take place at constant enthalpy, or $\Delta H = 0$. If there were no change in friction energy, the flow would take place at constant entropy, or $\Delta S = 0$. Since both velocity and friction terms are not zero, the actual flow takes place somewhere between the conditions $\Delta H = 0$ and $\Delta S = 0$. However, since for all ordinary pipeline conditions the friction term is much greater than the velocity term, the condition will be much nearer $\Delta H = 0$ than $\Delta S = 0$. In addition, there will usually be heat added to the carbon dioxide during flow, since it will be below zero Fahrenheit.

This addition of heat will cause the flow condition to be nearer the isenthalpic. In addition, under the conditions involved, the results are nearly the same for either $\Delta H = 0$ (isenthalpic) or $\Delta S = 0$ (isentropic). The isenthalpic condition will be used.

Assuming the above flow conditions, together with extensive flow tests of carbon dioxide in pipes, Hesson (2) concluded that his results could best be represented by the following equation:

$$L = \frac{3647 D^{5.25} Y}{Q^2} - 8.08 D^{1.25} Z \quad (\text{Eq. 3})$$

where *length or eq length of pipe*

$$Y = \frac{100i}{\ln j} \left\{ j^{P_0/100} - j^{P/100} \right\} = \int_{P_0}^P \rho dP \quad (\text{Eq. 4})$$

and

$$Z = \ln j \left(\frac{P_0}{100} - \frac{P}{100} \right) = \int_{P_0}^P \frac{dP}{\rho} = \ln \frac{\rho_0}{\rho} \quad (\text{Eq. 5})$$

The last terms (the integrals) in Eq. 4 and Eq. 5 are included here to clarify the meaning of *Y* and *Z*, as described in the Progress Report of the Committee on Carbon Dioxide (3). A table of values of *Y* and *Z* taken from (3) are included in these notes.

parameters depending on stage pressure + line pressure

For convenience in application, Eq. 3 can be rearranged as given below:

$$\frac{L}{D^{1.25}} = \frac{3647 Y}{(Q/D^2)^2} - 8.08 Z \quad (\text{Eq. 6})$$

*Be familiar with workings of this eq. **

A table of values of $D^{1.25}$ and D^2 for various pipes (3) is also included in these notes.

Q is a weight rate of flow.

LIQUID-GAS FLOW THROUGH ORIFICES

The flow of a two-phase mixture of carbon dioxide liquid and vapor through orifices has been investigated by Hesson and Peck (5). The following information is taken from that work:

"The following are the basic equations used to compute the flow rates through an ideal nozzle for negligible approach velocity U_1 .

$$Q = 60 (A/\text{ft}^2) (U_2/v_2) \quad (\text{Eq. 9})$$

$$Q = 60 (A/\text{ft}^2) (1/v_2) \cdot \left[2g(144) \int_{P_2}^P v dP \right]^{1/2} \quad (\text{Eq. 10})$$

$$Q = 60 (A/\text{ft}^2) (1/v_2) \cdot \left[2g J (-) \Delta H_{12} \right]^{1/2} \quad (\text{Eq. 11})$$

*A = orifice area
 U = ave. vel
 v = specific volume? FT³/lb*

For critical flow, $P_2 = P_t$, $U_2 = U_t$, and $V_2 = V_t$. For subcritical flow, $P_2 = P_3$

In this investigation it was found that saturated carbon dioxide vapor can flow through a nozzle or orifice in a supersaturated condition. When flowing in a supersaturated condition, it behaves as superheated vapor with an expansion coefficient n , defined by the equation: $PV^n = P_1V_1^n$. When this equation is substituted into Eq. 10 and the integration is performed, the results for the nozzle are:

$$Q = \frac{60A [28/144]^{1/2} \left\{ (P_1/V_1) [n/(n-1)] \left[1 - (P_2/P_1)^{\frac{n-1}{n}} \right] \right\}^{1/2}}{(P_2/P_1)^{1/n}} \quad (\text{Eq. 12})$$

When P_3 is greater than P_t , $P_2 = P_3$. When P_3 is less than P_t , $P_2 = P_t$, and critical flow results,

$$Q = 60A [28/144]^{1/2} [(P_1/V_1)]^{1/2} \cdot [n/(n+1)]^{1/2} [2/(n+1)]^{1/(n-1)} \quad (\text{Eq. 13})$$

and

$$(P_t/P_1) = \left(2/(n+1) \right)^{\frac{n}{n-1}} \quad (\text{Eq. 14})$$

VALUES OF n AND P_t/P_1 FOR SATURATED VAPOR

Pressure P_1 psia	n	P_t/P_1
0 to 600	1.30	0.55
700	1.22	0.56
800	1.17	0.57
900	1.07	0.59
1000	0.94	0.62

It will be noted that one of the effects of supersaturation is to increase the density for an expansion to a given pressure. Thus the actual flow rate is greater than that computed from the usual Mollier diagram for thermodynamic equilibrium.

In this investigation it was found that saturated carbon dioxide liquid can flow through a nozzle in a superheated or metastable condition and that it behaves as a nonvolatile liquid between the limits of the initial pressure and a lower pressure. On the assumption that the liquid is incompressible in Eq. 10, the following results:

$$Q = 60A [28/144]^{1/2} \cdot [(P_1 - P_2)/V_{f1}]^{1/2} \quad (\text{Eq. 14a})$$

This equation agrees with experimental results for values of P_2 from P_1 down to near the critical throat pressure P_t .

"An equation which covers the saturated liquid, saturated vapor, and two-phase region for the nozzle was developed by making the following assumptions:

1. The initial vapor fraction of the mixture expands without heat or mass interchange with the remainder of the mixture according to the relationship

$$PV^n = P_1 V_{g1}^n$$

2. The initial liquid fraction of the mixture may undergo some evaporation, but the vapor thus formed is considered part of the volume due to the initial liquid fraction, which expands according to the relationship

$$PV^\alpha = P_1 V_{f1}^\alpha$$

3. The velocity of both phases is the same.

The equation is:

$$Q = \frac{5A \left[2g \frac{P_1}{V_{f1}} \frac{1}{x} \right]^{1/2} \left[\frac{\alpha}{\alpha-1} \left\{ 1 - \left(\frac{P}{P_1} \right)^\alpha \right\} + \frac{1-x}{x} \frac{V_{g1}}{V_{f1}} \frac{m}{m-1} \left\{ 1 - \left(\frac{P}{P_1} \right)^{m-1} \right\} \right]^{1/2}}{\left(\frac{P}{P_1} \right)^{-1/x} + \frac{1-x}{x} \frac{V_{g1}}{V_{f1}} \left(\frac{P}{P_1} \right)^{-1/m}} \quad (\text{Eq. 15})$$

VALUES OF α FOR EQUATION 15

x	α	Note: Values of n given in previous table also apply to Eq. 15.
0 to 0.80	1.0	
0.90	1.1	
0.95	1.3	
0.975	3.0	

For flow rates less than the critical, P is equal to the back pressure, P_3 . For critical flow P/P_1 is evaluated for a maximum value of Q, in which case $P = P_t$, the throat pressure.

When the initial fraction of liquid $\rightarrow 0$, $x \rightarrow 0$, and Eq. 15 reduces to Eq. 16 and 17 which further reduce to Eqs. 12 and 13 for saturated vapor,

$$Q = \frac{60A \left[2g/144 \right]^{1/2} \left[1/(1-x) \right]^{1/2} \left\{ \frac{P_1}{V_1} \frac{m}{m-1} \left[1 - \left(\frac{P_2}{P_1} \right)^{m-1} \right] \right\}^{1/2}}{\left(\frac{P_2}{P_1} \right)^{-1/m}} \quad (\text{Eq. 16})$$

and for critical flow,

$$Q = 60A \left[2g/144 \right]^{1/2} \left(\frac{P_1}{V_1} \right)^{1/2} \left[\frac{1}{(1-x)} \right]^{1/2} \left[\frac{m}{(m+1)} \right]^{1/2} \left[\frac{2}{(m+1)} \right]^{1/(m+1)} \quad (\text{Eq. 17})$$

When the initial fraction of liquid is 1.0, $x = 1.0$ and Eq. 15 reduces to Eq. 14 for saturated liquid."

The discharge rate per square inch of equivalent orifice area for Low Pressure Storage (300 psia) and for High Pressure Storage (750 psia), as given in Reference (3), are included in these notes.

NOTATION

- A = Orifice area, in².
- A_p = External surface area of pipe, ft².
- C_p = Specific heat at constant pressure, BTU/lb/°F.
- d = Differential operator.
- D = Pipe internal diameter, inches.
- D_o = Orifice diameter, inches.
- f = Friction factor, dimensionless.
- g = Acceleration due to gravity. (32.17 ft/sec.²)
- G = Mass flow, lbs/sec/ft².
- h_f = Enthalpy of liquid, BTU/lb.
- h_g = Enthalpy of vapor, BTU/lb.
- H_f = Enthalpy of liquid at initial pressure, BTU/lb.
- ΔH = Change in enthalpy.
- i and j = Constant depending upon storage pressure.
- J = Mechanical equivalent of heat, 778 ft lbs/BTU.
- L = Length or Equivalent length of pipe, feet.
- n = Vapor expansion coefficient, dimensionless, where $PV^n = P_1V_1^n$.
- P = Pressure, psia. (P_o = Storage pressure, psia.)
- P₁ = Pressure at nozzle inlet conditions, psia.
- P₂ = Pressure at nozzle throat conditions, psia.
- P₃ = Pressure at nozzle downstream conditions, psia.
- P_t = Pressure at nozzle throat conditions at critical flow rate, psia.
- q = Liquid evaporation rate due to heat input, lbs/min.
- Q = Flow rate; also corrected flow rate, lbs/min.
- S_f = Entropy of liquid, BTU/lb/°R.
- S_g = Entropy of vapor, BTU/lb/°R.
- ΔS = Change in Entropy.
- t = Temperature, °F; also average room temperature, °F; or average pipe temp., °F.
- U = Average velocity, ft/sec.
- V = Specific volume, ft³/lb; subscripts 1, 2 and 3, same as nozzle press. cond.
- V_f = Specific volume of liquid, ft³/lb; V_{f1} refers to nozzle inlet conditions.
- V_g = Specific volume of vapor, ft³/lb; V_{g1} refers to nozzle inlet conditions.
- V_t = Specific volume of mixture of liquid and vapor, ft³/lb.
- V_p = Internal volume of piping, ft³.
- W = Ratio of actual energy in the flowing fluid to the energy as computed by U²/2g per unit mass. A good average value for turbulent flow is 1.1, where Reynolds Number = 2 x 10⁴.
- W = Weight of pipe and valves in the time delay Eq. 8.
- x = Fraction, by weight, of mixture which is liquid.
- (1 - x) = Fraction, by weight, of mixture which is vapor.
- Y and Z = Parameters depending upon storage pressure and line pressure.
- α = Liquid expansion coefficient, dimensionless, where $PV^\alpha = P_1V_{g1}^\alpha$.
- ρ = Density of mixture, lbs/ft³.
- ρ_i = Density at pressure P_o, lbs/ft³.
- τ = Time; also time delay, seconds.
- ln = Natural logarithm.

TABLE A-1
A.S.A. SCHEDULE 40 (STD. WT.) PIPE

NOM. PIPE SIZE	INT. DIA. Din.	1.25 D	2 D	TRANS AREA in ²	SURFACE AREA ft ² /ft	VOLUME ft ³ /ft.	WEIGHT LBS/FT
1/2	0.622	0.5521	0.3869	0.304			
3/4	0.824	0.7850	0.679	0.533	0.275	0.0037	1.13
1	1.049	1.0615	1.100	0.864	0.344	0.0060	1.68
1 1/4	1.380	1.4960	1.904	1.495	0.435	0.0104	2.27
1 1/2	1.610	1.8130	2.592	2.036	0.497	0.0141	2.72
2	2.067	2.4750	4.272	3.355	0.622	0.0233	3.65
2 1/2	2.469	3.0900	6.096	4.788	0.753	0.0332	5.79
3	3.068	4.06	9.413	7.393	0.916	0.0513	7.58
4	4.026	5.71	16.21	12.730	1.178	0.0884	10.79
5	5.047	7.54	25.47	20.006	1.456	0.1390	14.62
6	6.065	9.50	36.78	28.891	1.734	0.2006	18.97

A.S.A. SCHEDULE 80 (X WT.) PIPE

1/2	0.516			0.234			
3/4	0.742			0.433	0.275	0.0030	1.47
1	0.957	0.9465	0.9158	0.719	0.344	0.0050	2.17
1 1/4	1.278	1.359	1.633	1.283	0.435	0.0089	3.00
1 1/2	1.500	1.660	2.250	1.767	0.497	0.0123	3.63
2	1.939	2.288	3.760	2.953	0.622	0.0205	5.02
2 1/2	2.323	2.865	5.396	4.238	0.753	0.0294	7.66
3	2.900	3.79	8.410	6.605	0.916	0.0459	10.25
4	3.826	5.34	14.64	11.497	1.178	0.0799	14.98
5	4.813	7.14	23.16	18.194	1.456	0.1263	20.78
6	5.761	8.92	33.19	26.067	1.734	0.1810	28.57


TABLE A-2. VALUES OF Y AND Z FOR 300 PSIA STORAGE PRESSURE

PSIA	Y	Z
300	0	0
290	603	0.12
280	1138	0.24
270	1613	0.36
260	2033	0.48
250	2406	0.60
225	3163	0.90
200	3723	1.20
175	4137	1.50
150	4443	1.80
125	4670	2.11
100	4837	2.41



TABLE A-3. VALUES OF Y AND Z FOR 750 PSIA STORAGE PRESSURE

PSIA	Y	Z
750	0	0
725	1200	.0825
700	2300	.165
675	3320	.249
650	4280	.333
625	5130	.417
600	5960	.501
575	6710	.585
550	7370	.672
525	7980	.760
500	8530	.849
475	9060	.939
450	9530	1.033
425	9970	1.132
400	10400	1.237
375	10740	1.350
350	11020	1.479
325	11410	1.629
300	11560	1.844
250	11950	2.164
200	12150	2.623

@ 70°F
853 psia
@ 80°F
968.7



HIGH
PRESSURE
SYS.



Liquid gas flow in piping
may start out as a liq., but
as some energy is used to overcome
friction loss + maintain hv, pressure
drops + you get some vapor.

TABLE A-5. EQUIVALENT ORIFICE SIZES

<u>Orifice Code No.</u>	<u>Equivalent Single Orifice Diameter - Inches</u>	<u>Equivalent Single Orifice Area-Sq. In.</u>
-	.026	.00053
-	1/16	.00307
-	.070	.00385
-	.076	.00454
-	5/64	.0048
-	.081	.00515
-	.086	.00581
3	3/32	.0069
3+	7/64	.0094
4	1/8	.0123
4+	9/64	.0155
5	5/32	.0192
5+	11/64	.0232
6	3/16	.0276
6+	13/64	.0324
7	7/32	.0376
7+	15/64	.0431
8	1/4	.0491
8+	17/64	.0554
9	9/32	.0621
9+	19/64	.0692
10	5/16	.0767
11	11/32	.0928
12	3/8	.1105
13	13/32	.1296
14	7/16	.1503
15	15/32	.1725
16	1/2	.1964
18	9/16	.2485
20	5/8	.3068
22	11/16	.3712
24	3/4	.4418
32	1	.785
48	1 1/2	1.765
64	2	3.14

Note: The orifice code number indicates the equivalent single orifice diameter in 1/32 inch increments. A plus sign following this number indicates equivalent diameters 1/64 inch greater than that indicated by the numbering system (e.g., No. 4 indicates an equivalent orifice diameter of 4/32 of an inch; a No. 4+ , 9/64 of an inch).

TABLE A-6. DISCHARGE RATE PER SQUARE INCH
OF EQUIVALENT ORIFICE AREA
FOR LOW PRESSURE STORAGE (300 PSIA)

<u>ORIFICE PRESSURE</u> <u>PSIA</u>	<u>DISCHARGE RATE</u> <u>LBS./MIN./SQ. IN.</u>
300	4220
290	2900
280	2375
270	2050
260	1825
250	1655
240	1525
230	1410
220	1305
210	1210
200	1125
190	1048
180	977
170	912
160	852
150	795
140	741
130	689
120	638
110	589
100	542

TABLE A-7. DISCHARGE RATE PER SQUARE INCH
OF EQUIVALENT ORIFICE AREA
FOR HIGH PRESSURE STORAGE
(750 PSIA)


<u>ORIFICE PRESSURE</u> <u>PSIA</u>	<u>DISCHARGE RATE</u> <u>LBS./MIN./SQ. IN.</u>
750	4630
725	3845
700	3415
675	3090
650	2835
625	2615
600	2425
575	2260
550	2115
525	1985
500	1860
475	1740
450	1620
425	1510
400	1400
375	1290
350	1180
325	1080
300	980
250	780
200	595

BIBLIOGRAPHY

1. LAPPEL, C. E., Fluid and Particle Mechanics, Chapter 6, "Two-Phase Flow In Pipes", by GEORGE E. ALVES, pp 95-113.
2. HESSON, J. C., "Pressure Drop For Two-Phase Carbon Dioxide Flowing In Pipe Lines," Master of Science Thesis in Chemical Engineering (unpublished), Illinois Institute of Technology, January 1953.
3. Report of the Committee on Carbon Dioxide, Progress Report Containing Proposed Revisions to Standard for Carbon Dioxide Extinguishing Systems, N.F.P.A. Pamphlet 12, Advanced Reports, N.F.P.A. (1960).
4. "Carbon Dioxide Flow In Pipe Lines," Cardox Division of Chemetron Corporation, Chicago, Illinois (1956).
5. HESSON, JAMES C. AND PECK, RALPH E., "Flow of Two-Phase Carbon Dioxide Through Orifices," A.I. Ch.E. Journal, Volume 4, No. 2, June 1956, pp 207-10.

Pg. 44 NBFU #12
 Example problem

go over



Flow Rate = 1000 #/min.

$$\frac{Q}{D^2} = \frac{1000}{4.27} = \frac{1000}{(\text{I.D. } 2" \text{ pipe})^2} = \frac{1000}{4.272}$$

$$\frac{Q}{D^2} = ~~1000~~ \underline{234} \text{ lb./min./D}^2$$

↑
 from Table A-4
 pg 46

$$\frac{L}{D^{1.25}} = \frac{500}{2.48} = 201.6$$

↑
 from Table A-4

Go to ~~Table~~ Fig A-4 pg 49

⇒ Terminal pressure = 228 psia


Pg. 18 Table 2

Orifice Pressure psia ~ 230 → Discharge 1410 lb/min/in²

$$\frac{1000}{1410} = 0.709$$

Pg. 17 find eq. orifice size

.709 \approx .785 \therefore use 1" single ORIFICE
(# 32 orifice)



WITH TWO NOZZLES


$$\frac{Q}{D^2} = \frac{500}{2.59} = 192.9$$

$$\frac{L}{D^{1.25}} = \frac{200}{1.81} = 110$$

Replace 3" pipe w. eq. length of 1 1/2" \Rightarrow will still get 228 gpm @ junction.

Table A-1 $\Rightarrow \frac{L}{D^{1.25}}$

Other table $\Rightarrow 300' = L$



OUTLINE OF CALCULATION

(Read Intro. + Ch. 1 in NFPA # 12)
+ Appendix A

Item 1613

I Tank to point A (Master Valve)

Flow Rate ----- 900 μ /min

----- " Sch. 80 pipe

Dip Tube	-----	15.0 feet long
90° Ell - eq. length	-----	5.5' eq. length
Shut off valve - eq. length	-----	1.2
Master valve - eq. length	-----	48.0
Length of pipe	-----	5.0
TOTAL EQ. LENGTH TO A	-----	74.7

Flowing Pressure at Point (A) 291.7 μ ia

Pg. 12-47 Table A-5 & A-6

II Point A - Point B

Flow Rate ----- 900 μ /min

----- 40 2" sch. to pipe

Eq. length, Tank to A ----- 102.0'

V point C to pt. # 2

Flow Rate 200 lb./min.

1 1/4 " sch 40 pipe

Eq. length tank - pt C. 1900

" " tee 7.5

" " 90° ell 3.7

pipe length 100

TOTAL EQ. LENGTH 2011.2

flowing pressure @ 2 175

VI point C to pt. # 3

Flow Rate _____ lb./min

1 1/4 " sch. 40 pipe

Eq length Tank - pt C

" " tee

" " 90° ell

pipe length _____

TOTAL LENGTH _____

flowing pressure @ 3 _____

1-13-65

Working With Numbers

Use Cardox Equip

Go to FP ~~list~~

eq. length of Master Valve = 48'

Handling elevation diff on CO₂ systems

pg. 47-48 pamphlet #12

negl. for nominal changes in elevation

Calculate all as horizontal pipe

Find "one pressure" in leg concerned

(density of CO₂ varies with pressure, ∴ use one pressure

Elevation correction psi/ft (from chart or

table on basis of "one pressure") times h, ft,
gives psi correction.

TABLE A-7 pg 48 pamphlet #12

Final - may use pamphlet #12

introduction

CH-1

new CO₂ works (generally)

portions of Appendix A

properties of CO₂

flawing

Pipe + orifice size

determinations

Sample problems + charts


Exclude later part after pg 51

hydraulic data manual

handy-cross nomograph

Conclusions from droplet size article

General knowledge



Water sprays can be used to extinguish fires in burning liquids by a number of techniques. The most reliable methods are those which depend upon the reduction of evolution of vapor from the burning liquid to a value lower than that quantity which is required to sustain a flame. A particular method of extinction which falls into this category is the cooling of the burning liquid to the fire point. To extinguish a liquid fire by cooling, it is necessary that the flow rate of the coolant be above a certain critical value. At lower rates cooling occurs at a temperature which is higher than the fire point and is, therefore, ineffective.

From a practical point of view, it is important to predict the extinction time of a fire. This feature is particularly important when designing protective installations where rapid fire extinction is quite essential. Rasbash and Rogowski have conducted tests with water sprays on burning liquid fires. They show that, for sprays which extinguish fires by cooling the liquid, there is a correlation between the extinction time and the properties of the sprays and the fires. All of their experiments were conducted with the sprays projecting downward from fixed nozzles to a horizontal surface of the burning liquid.

Liquid fires on transformer oil, kerosene, and gas oil in circular open vessels having diameters ranging from 4.3 to 47.2 in. were utilized in the experiments. Sprays were produced by single nozzles of various types or by a battery of impinging jets. The single nozzles were employed in an investigation to determine the best type of spray for the protection of factories containing oils having high boiling temperatures such as those found in stations generating electricity. The other type of spray was produced from impinging jet nozzles and from swirl nozzles. Both directional and nondirectional sprays were utilized. The nozzles were located at heights above the burning surfaces ranging from 69 to 180 in. Mean flow rates of spray to the combustion vessels were varied from 0.06 to 1.2 gal/sq ft/min. Mass median drop sizes of the spray were altered from 0.012 to 0.12 in. Nozzle pressures from 10 to 100 psi were utilized.

The main evidence used by the authors to decide whether an extinction of the fire occurred by cooling was that the temperature shown by a thermocouple placed near the liquid surface is reduced to the fire point of the liquid prior to extinction. In some instances the fire continued to burn after the indicated temperature was lower than the fire point. This deviation was ascribed partly to unevenness in the spray pattern giving rise to different degrees of cooling at various parts of the liquid surface. In addition, however, some evidence indicated that the flames under these conditions consisted of burning oil droplets that were splashed upwards by the water spray.

When the flames were extinguished by cooling, it was characteristic that after an initial upsurge, the size of the flames was reduced gradually, until in the last stages the flames were about 6 in. high and were usually present only at the edge of the test vessel. A lighted taper placed near the liquid surface did not give immediate re-ignition after the initial extinction. Time-temperature records showed that the liquid continued to cool for a considerable time after the spray was terminated, which was within several seconds after fire extinction.

The nature of liquid burning, the time of initial burning, and the diameter of the burning vessel were the main properties of the fires that were varied during the tests. To obtain an estimate of the effect of the burning liquid, experiments were conducted in which extinctions took place under conditions wherein only the liquid itself was changed.

A comparison was obtained by plotting the extinction time against the temperature difference between the fire point of the liquid under test and the ambient atmospheric temperature. The results show that there was a rapid decrease in extinction time as the temperature difference (defined above) increased; the extinction time was approximately proportional to the temperature difference raised to the -1.75 power. Despite a wide scatter of results, the extinction time was approximately proportional to the initial burning time of the liquid. There appeared to be no significant difference between the extinction time for vessels having diameters of 35 or 47 in.

Rabash and Rogowski found that, in general, it was not possible to ascertain directly from their results the effect of the various spray properties on the extinction time, since over a major portion of conditions in which extinctions by cooling occurred it was not possible to control these properties independently. In some instances a direct estimate was possible. A coarse spray took longer to extinguish the fires tested than did a fine spray. A direct indication of the effect of difference in the velocity of the entrained current of two sprays was obtained. These two sprays had nearly the same drop size and flow rate. When the spray with the low entrained air velocity was applied to the fire, the flames moved upwards against the spray. With a spray of high entrained air current, the spray pushed the flames downwards and there was a smaller extinction time. Within the residual error the extinction time was shown to be directly proportional to the drop size and inversely proportional to the rate of flow of water spray to the fire area. A significant decrease in the extinction time was noted as the entrained air velocity increased.

The extinction times in all tests where extinction was by cooling were plotted against a parameter A, where

$$A = (D/M) (Y/\Delta T^{1.75})$$

where D(mm) is the mass median drop size of the spray, $M(g \cdot cm^{-2} \cdot min^{-1})$ is the rate of flow of spray to the fire area, $\Delta T(^{\circ}C)$ is the difference between the fire point of the liquid and ambient temperature, and Y (min) is the initial burning time. The resultant curve showed that, except for two groups of tests, the data fall fairly well about a straight line having a positive slope of unity. All of the data for the groups of tests not falling on the straight line were obtained during experiments wherein the entrained air velocity was less than 8 ft/see (the approximate upward velocity of the flame gases) and it was characteristic of these tests that the flames moved upwards against the sprays. In general, it was shown that the deviation from the straight line increased as the entrained air velocity decreased.

The equation of the straight line having unit slope is $t = 34,000 A$ where t denotes the extinction time in seconds. All extinction times obtained in the tests, except for those extinction times associated with sprays having low entrained air velocities, fell within a distance of this line that was generally within the range of reproducibility of the tests. From the empirical expression for extinction time, it can be seen that under given conditions liquids with high fire points are extinguished much more rapidly than those with low fire points. Also, the efficiency of the spray, as measured by the reciprocal of the extinction time, is proportional to the flow rate of spray to the liquid surface. The efficiency of the spray increases as the drop size of the spray is reduced. This factor can be expected to hold only if the spray drops have a momentum sufficiently large to penetrate the flame and reach the burning liquid.

The size (diameter) of the fire, which varied from 4.3 to 47 in., was not an important factor in determining the extinction time. Also, the method of spray production, whether accomplished by impinging jets or swirl nozzles or even air atomization, did not affect the extinction time noticeably. Factors like the pressure at which the spray was produced and the cone angle at which the spray was directed from the nozzles affected the extinction times only insofar as they affected the properties of the spray reaching the fire, that is, the drop size, the flow rate, and the entrained air velocity in the spray.

Three mechanisms may be suggested to account for the cooling of the burning liquid: (1) heat transfer from the hot oil to the water drops, (2) mixing of hot oil near the surface with cold oil well below the surface, and (3) the formation of an oil-in-water emulsion followed or accompanied by heat transfer from the hot oil drops to the continuous water phase. The manner in which the extinction time depends upon the factors of the parameter A is most consistent with the view that the cooling to the fire point of the surface layers of the oil was due to the abstraction of heat from the liquid by water drops within the liquid. Thus, the amount of heat which had to be removed increased as the initial burning time increased; the ability of the spray drops to remove this heat increased as the flow rate of the spray increased, as the drop size decreased, and as the temperature difference between the fire point and the ambient temperature increased.

The derived empirical equation gives an estimate of the extinction time for a liquid fire burning from a horizontal layer when the spray is projected vertically downwards from a fixed system with the requirement that the water spray drops should be able to reach the liquid surface. Splash fires are not covered by this empirical equation. It is unlikely for most liquids that an increase in initial burning times beyond 10 to 20 min. will give the increase in extinction time predicted by the empirical equation since the sensible heat in the liquid above the fire-point temperature does not increase significantly after this time.

Subject Headings: Extinguishment by water sprays; Water sprays, flame extinguishment; Fires of liquids.

L. E. Bollinger

Note:

The above abstract was taken from "Fire Research Abstracts and Reviews," Volume 1, No. 1, September, 1958, Committee on Fire Research and Fire Research Conference, National Academy of Sciences, National Research Council, Washington, D.C.

420

When fire occurs in a sprinklered building, only those sprinklers directly above or very near the fire can act to control it. While control is taking place, hot gases can travel far beyond the flame envelope. Within these wide spreading gases, temperatures can be high enough to open sprinklers with "ordinary" operating temperature rating (135-165 °F), but not high enough to damage the structure or other exposed materials. As a result, sprinklers that are not needed operate. Quick operation of sprinklers - an advantage over a fire - may be a disadvantage elsewhere, wasting water and wetting down materials that might otherwise be unaffected.

This paper discusses the results of a program of 130 tests statistically designed to relate the variables of sprinkler temperature rating, ceiling temperature, number of sprinklers opened, opening time, and material burned. Two basic fire types were used, both sized to open more than five sprinklers of ordinary temperature rating: (1) a fire involving a stack of wood pallets 8 feet high, representative of the broad class of fires whose burning rate is greatly affected by sprinkler water; (2) a fire involving gasoline spray discharged at the rate of 1.5 gpm, representative of the class fire that is fixed in location and relatively unaffected by sprinkler water. Sprinklers used in the tests were of the solder type of various makes and temperature ratings ranging from ordinary (160 °F), intermediate (212 °F), high (286 °F) and extra high (360 °F). The full range of heat sensitivity and distribution effectiveness was covered.

The data show that, for the types of fires considered, there are advantages to be gained from more general use of sprinklers of higher operating temperature ratings, especially the intermediate rating. For fast, intense fires, the differences in opening time among the various ratings are negligible. For slower fires where operating time differences are noticeable, the time delay is unimportant.

Willis G. Labes
Professor of Fire Protection Engineering
Illinois Institute of Technology

I. The most favorable size drops

Water has a very high heat capacity which enables its cooling action to play a predominant part in the extinguishment of fires. The rate of heat absorption depends on the extent of the exposed surface. The first part of this report discusses the possibility of improving the fire-fighting ability of water to its maximum by increasing the speed of vaporization by means of very fine atomization. In practice it is required that water be discharged at a distance from and be brought to the surface of the burning object in sufficient quantities per unit of time to absorb the heat generated within that unit of time. Very fine droplets cannot be easily focused at an object from a distance to give proper coverage and they do not have sufficient energy to resist the upthrust of the combustion gases when entering the combustion zone.

It is possible theoretically to determine the most favorable size drops on the basis that the speed of vaporization for a drop of water is a function of its surface area and the heat transfer coefficient. In still air—a condition which prevails at the burning surface itself—this coefficient is inversely proportional to the diameter of the drop and heat will be absorbed in proportion to the extent of the exposed surface. However, when a relative motion exists between the drops of water and the surrounding air, as when water is used mainly to quench the flames, to reduce heat radiation, and to curtail the spreading of fire by cooling of the hot gases, then the heat transfer coefficient is greater and the speed of vaporization is increased. To determine the most favorable size drops under these conditions, the author makes use of Edeling's^{*} equation of the heat transfer to small drops of water in motion:

$$h = 0.75 \frac{k}{\sqrt{\alpha}} \sqrt{v} \quad (1)$$

in which the heat transfer coefficient h is shown to be a function of the ratio of the velocity v of the drop to its diameter d ; k is the thermal conductivity and α

the thermal diffusivity $\left(\frac{k}{\rho c_p}\right)$. At a constant velocity, the heat transfer coefficient will depend only on d and by assuming that the heat quantity dQ

$$dQ = h \cdot 4\pi r^2 \cdot \Delta t \cdot d\tau \quad (2)$$

transmitted within unit time $d\tau$ to the surface of the drop of radius r under a temperature difference Δt is made to vaporize a quantity dW of water, a vaporization equation can be obtained relating time of vaporization T to the radius of the drop r :

$$T = \frac{L \cdot \rho_w \cdot \sqrt{2\alpha}}{1.5 \cdot 0.75 k \Delta t \cdot \sqrt{v}} \cdot \sqrt{r^{1.5}} \quad (3)$$

where L is the heat of vaporization of water, and ρ_w its density.

A series of tests aimed at measuring the vaporization time of a drop of water in a current of air at constant values of air velocity and temperature led to the conclusion that the exponent of d must be larger than 0.5 and should lie between 0.8 and 1.0. The influence of the air velocity could be analyzed in a similar manner by keeping temperature and diameter of the drop constant. No results were available as yet and the author makes use of results reported by Schmidt ^T on the transfer of heat from heated pipes, to infer that the exponent of v would have to correspond to, if not exceed, that of d .

Assuming equal exponents for both "v" and "d," the influence of the quotient "v/d" on the heat transfer coefficient can be analyzed to determine for what value of "d" heat absorption will be maximum. For a drop of a given diameter, neglecting the loss of substance through evaporation during flight, the value of the heat transfer coefficient will be a function of the speed of the drop relative to the surrounding air. The horizontal component of this speed will decrease very rapidly to zero against the resistance of the air although there continues to exist a horizontal component of the absolute speed because of the air current created by the stream of water spray. On the other hand, the vertical component of the relative speed increases toward a limit value, the terminal speed of fall, which is unequivocally defined for any size drop and which determines the balance between the weight of the drop and the air resistance.

The author introduces this terminal speed of fall as the lower limit for the relative speed of the drop and, substituting its value for v in Edeling's equation of the heat transfer, he finds that the coefficient of heat transfer is maximum for a drop diameter of 0.35 mm. This is compared with optimum values of 0.4 to 0.6 mm. obtained in England* during tests on the extinguishment of liquid fires.

II. The range

The range of a solid stream of water is a function of the velocity of the stream at the nozzle which in turn is dependent on the pressure at that point. In the case of a stream of water spray, a certain quantity of energy "A" must be used to overcome the surface tension "σ" of the water during the atomization process:

$$A = \frac{6\sigma}{10d} \text{ kg/cm}^2 \quad (4)$$

It is calculated that the production of drops with a 0.35 mm. diameter at an absolute pressure of 5 atmospheres consumes only 0.24 per cent of the water pressure.

If this energy required for atomization is taken into account in the pressure equation, the initial velocity (or nozzle velocity) "v₀" of a drop of water of a diameter "d" (in mm.) is equal to:

$$v_0 = \sqrt{\frac{2}{\rho W} \left(P_0 - \frac{6\sigma}{10d} \right) + v_1^2} \quad (5)$$

where "P₀" is the pressure within the pipe line and "v₁" the speed of water in the line. Assuming a water flow of 100 l/min through a hose of 52 mm. diameter, "v₁" would be equal to 0.79 m/sec. Water drops of 0.35 mm. diameter would have a velocity of about 30 m/sec for a nozzle pressure of 5 atmospheres, providing friction losses within the nozzle are kept low.

To determine the range of the water spray, consideration must be given to the air resistance which is a function of the diameter of the drops and of the dynamic pressure of the air. For a sufficiently short time interval ΔT, the deceleration -Δv₀ of the drop would be

$$-\Delta v_0 = -b_0 \cdot \Delta T \quad (6)$$

where "b₀" is the retardation factor. After ΔT seconds, the speed "v₁" of the drop would be:

$$v_1 = v_0 - \Delta v_0 \quad (7)$$

and the corresponding distance travelled amounts to:

$$s_1 = \frac{v_0 + v_1}{2} \cdot \Delta T \quad (8)$$

The speed variations and the corresponding distances travelled can be integrated step by step to give the range "S" of the drop:

$$S = \sum_{l=1}^{l=n} s_l \tag{9}$$

This range is found to be about 1.50 m. for 0.35 mm. drops at an initial velocity of 30 m/sec. Loss of mass by the drop during flight would tend to reduce this value. If attempts were made to extend the range, say to 6 m., by increasing the pipe pressure, it would be found that very high pressures outside the range of practical possibilities would be required since range increases with the 4th root of the pressure. Furthermore, owing to its low mechanical stability, a drop of water is incapable of opposing very high dynamic air pressures. Whenever the dynamic pressure resulting from the speed of the drop exceeds a certain value, the drop is flattened and broken down into smaller drops. The condition of stability which exists between the upper speed limit "v_{max.}" and the diameter d of a drop is:

$$v_{max.} = \sqrt{\frac{8\sigma}{d \cdot \rho_L}} \tag{10}$$

where σ is the surface tension of the drop and ρ_L the specific density of the air. From this, it is found that a drop of 0.35 mm. diameter would become unstable and break down at velocities greater than 36.2 m/sec.

In practice, it is observed that, in a stream of water spray, the drops travel much farther than could be expected on the strength of the theoretical findings above. In a steady-state stream, only the very first drops encounter static air. They create in their path a current of air which rapidly attains a stationary state and reduces the air resistance for the following drops. For an examination of the range of a stream of water spray, the stationary state is, therefore, the determining factor.

Assuming very fine atomization of the water, a stream of water spray can be compared to a stream of air and would be expected to expand quite accurately and independently of the nozzle velocity as a cone having a vertex angle of 14° at the nozzle opening, provided the Reynold's number is sufficiently large. If the drops are not infinitely small, and assuming steady conditions of water flow, the total free surface of the water would be smaller, friction would be reduced, and a smaller amount of air would be forced along. The reduction in the amount of air to be accelerated means that the volume of the cone becomes smaller. It is concluded that in a stream of water spray, the vertex angle which is a function of drop size would lie between the limits of 0° (solid stream) and 14° (fine atomization), providing all drops are emitted at the same speed and direction.

It is found that, in practice, the nonuniformity of drop sizes complicates the dynamics of the stream since small and large drops tend to collide in flight. It would be most important to develop atomizing nozzles which produce drops of uniform sizes, regardless of pipe pressure. With a properly designed nozzle, it would be possible for 50 per cent of the water to arrive at a vertical circular surface of 1 square meter area at a distance of 8 m. from the nozzle. This corresponds to an 11.4° vertex angle of spray. It is also concluded that, for a water flow of 100 l/min and an initial velocity of the drops of 30 m/sec, the absolute velocity of the drops at a distance of 8 m. would be of 4.2 m/sec which is presumed to be sufficiently high to allow the drops to reach the focal point of the fire against the upthrust of the combustion gases. The time of flight would be 0.45 sec. Gravity would make drops having a 0.35 mm. diameter fall a distance of 0.68 m.

Subject Headings: Water, sprays for flame extinguishment; Water, sprays, range of; Extinguishment, by water sprays.

J. R. Jutras

*Edeling: Investigation of Atomization Drying (Untersuchungen zur Zerstäubungstrocknung): Diss. 1949, Karlsruhe, Verlag Chemie, Weinheim, Germany.

Schmidt: Introduction into Thermo-Dynamics (Einführung in die Thermodynamik) Berlin 1944.

*Rasbash, Rogowski, Skeet: "Some tests on the effect of water sprays on a hexane fire." F. C. Note #45/1951. Rasbash: "The effect of water sprays in burning kerosene." F. C. Note #41/1951.

Note: The above abstract was taken from "Fire Research Abstracts and Reviews," Committee on Fire Research and Fire Research Conference, National Academy of Sciences - National Research Council, Washington, D.C., Volume 1, Number 2, January, 1959.

U.L.
ROBERT BRADER

11/30/3


DANGER SLEWS
(DETECTIVES)

ALBUM OF PUBLIC SAFETY

WLM. HENRY MERRILL FOUNDED UL

I BEGINNING

- A. ELECTRICAL 1893
- B. FIRE PROT 1893-98 (?)
- C. LABEL SERVICE 1905
- D. CHEMICAL 1900-1920 (?)
- E. GASES & OILS 1906 (?)
- F. CASUALTY 1915
- G. AUTOMOTIVE 1918
- H. BURGLARY PROT. 1921



HISTORY

OUTCROPPING OF WORLD COLOMBIAN EXPOSITION

Western Union League sent Merrill to Exposition to see why the displays were burning. Started in 1893 his own "U.L." & test new fangled. Merrill first pres. \swarrow Electrical Bureau for NBFU
Fire prot \rightarrow Robinson first VP

1904 they were approached by Insurance & codes to label. He said he would if he had inspectors. So Label Service Dept. started in 1905. first label was rigid conduit

Now have

1. Elec. Dept.
2. Fire prot Dept
3. Label. Dept.

Then comes Chem Dept.

Then abt. 1906-1910 oil burner dept

1915 Casualty Dept. (Refug, air cond etc)

1918 - Requested to test Autos
prompted use of safety glass
" safe carb.

Now ~~most~~ mainly concerned
with lift trucks.

1921 - Insurance, safe makers requested
Burglary dept.

Started in one area & expanded
at request

In 1905 Menill got idea to be
Independent & in 1917 U.K.

& NBFU donated \$250,000 equipment
they had purchased for U.K.
Started charging mfg.

+ semi charge for each label issued
& cover inspectors expenses etc.

Excess & refunded at end of yr.

Unique QUALITIES OF U.L.

1. Non PROFIT
2. follow up service
3. Create own stds. of safety
 - a. Industry & many diff people come to comment.
 - b. Councils vote on stds & comment
had U.L. decides on its adoption.
a.e. go to people for help.
4. Own Engrs.
Own Test Equipment

Government of U.L.

1906 Charte drawn up & stocks issued in ILL.
1936 found out ILL. didn't have
provision for non profit orgs.
So chartered in Delaware.

NBFU


So now have CHARTER

CHARTER

SET UP NBFU AS TRUSTEES
(BOARD OF DIRECTORS)

PRES.

LONG RANGE BUSINESS ENGINEERING PROBLEMS NOT HANDLED BY NBFU
" " HANDLED BY NBFU



EACH DEPT. HAS. MANAGING ENGR. answering to pres.
each dept broken into Assoc. Managing Engrs.

Label Service works out of Chgo.

Starting to work on some Atomic

Non Profit - NO DIVIDENDS.

1955 first Billion mark for labels.

9,200 factories visited/yr.

RE-EXAMINATION SERVICE

FLAT RATE

\$ INSPECTOR

VISITS 41M 1-4

times/yr.

little change
in product

LABEL SERVICE


Inspectors visit W.R.T.
volume of production.

SPECIAL PROBLEMS.

Identification

1. LIST.
2. LABEL.

Under Label Service Characteristics.



Under Re-examination
Service

In Book gives
of ~~assessments~~
or identification.

DIE ~~ASSA~~ LABELED UND. LAB. INC.

Write Paper on U.L.

UL 723

- 1. Overall Purpose ✓
- 2. History ✓
- 3. Operating Depts. ✓
- 4. Financial (Income) ✓
- 5. Followup Services
- 6. Identification of Listed Products
- 7. Method(s) of submittal of Prod. ✓
- 8. Usefulness to you as an F.P.E.

+ ??

+

UNDERWRITERS' LABORATORIES, INC.

DAVID LUCHT

OCT. 5, 1963

F.P.E. 303A

95

Purpose - Testing for Public Safety

Underwriters' Laboratories, Inc. is a nonprofit corporation organized to determine the relative hazards of various devices, materials, and construction methods with respect to life, fire, and casualty loss. Further, having determined the relative hazards of these items, it is the purpose of Underwriters' Laboratories to classify, identify and list those which may reduce and prevent loss of life and property from fire, crime and casualty.

The seed of Underwriters' Laboratories, Inc. was sowed in 1893 by the Western Union League which sent Mr. William Henry Merrill to the World Columbian Exposition in Chicago for the purpose of determining the causes of the frequent fire losses incurred at the Exposition. After surveying the problem, Mr. Merrill saw the need for an organization which could test the safety of the new electrical devices such as those which seemed to be causing the fires at the Exposition. Thus, in 1893 Mr. Merrill formed his own "Electrical Bureau" in connection with the National Board of Fire Underwriters. Next, some time between 1893 and 1898, a Mr. Robinson entered the Bureau as Vice President, and brought with him the Fire Protection Department of the Electrical Bureau. Later, in 1904, the men were approached by insurance companies and building codes people who urged them to label and identify the products which the Bureau had tested. Hence, in 1905, the Label Department of the Electrical Bureau was formed. This expansion continued -- next a Chemical Department was formed, then an Oil Burner Department, and in 1915 a Casualty Department. In 1917 the Bureau became an independent nonprofit corporation, with the National Board of Fire Underwriters donating \$250,000 worth of equipment which they had purchased for the work of the Bureau. This was Underwriters' Laboratories, Inc. In 1918 the Automotive Department was formed, and in 1921 the Burglary Department. Working with all of the above departments, Underwriters' Laboratories has grown until today it has four testing stations across the United States with representatives around the world.

Paragraphing

Underwriters' Laboratories, Inc., as previously mentioned, is a nonprofit organization. The corporate income is received in the form of fees charged to the manufacturer for examinations, tests, reports, and follow-up service on his product. This income is then used to finance testing expenses and facilities, salaries, and clerical services, and the remainder (except for any lay-away for future or emergency use) is returned to the people for whom services were performed.

The submitter who is interested in obtaining a report, test, and listing of his product writes to Underwriters' Laboratories and gives a complete description of the product in order that its character, purpose, size, rating and other

features may be evaluated and the product may be classified as close as possible as to the extent of tests and examinations necessary. After this classification, an application form is sent to the submitter giving in detail the limitations and responsibilities of Underwriters' Laboratories, the amount of deposit necessary, the type examination and test to be performed, and the type follow-up service to be employed if and when the product is found acceptable. Final Listing is contingent upon acceptance of actual production samples only. Further, some products may be tested and examined on the site of production in some instances where shipment to the Laboratories is impractical.

If and when the product is accepted under Laboratories' standards or requirements, it is identified as being Listed. Further, a follow-up service is employed by the Laboratories as a check to insure that all listed products are produced to conform with standards or requirements.

One type of follow-up service is known as the Reexamination Service, which constitutes continued Listing of a product together with visits to the factory one or more times yearly, by a member of the Laboratories' staff, for the selection, examination, and test of representative samples of the most recent production of the Listed product. If this product fails to meet the Laboratories' requirements upon Reexamination, it must be corrected by the manufacturer on further production as a condition of continued Listing. These products Listed under the Reexamination Service are marked with the manufacturers identification and catalog numbers which correspond with identification in the Laboratories' published records. Only those products which actually bear the Listed identification are covered by the Reexamination Service.

Another type of follow-up service is the Label Service. Here the manufacturer conducts his own tests and examinations to insure that his product complies with Underwriters' Laboratories requirements, and attaches registered labels to them. However, as in the Reexamination Service, the Laboratories' representatives make frequent visits to the factory to check the efficiency of the manufacturers inspection program. Should the representative find the program substandard, the manufacturer must correct defective items or remove labels from the product. Often products purchased by Underwriters' Laboratories in the open market are tested in the Laboratories as a countercheck on the factory inspection. The label of Underwriters' Laboratories, Inc. attached to the product is the only way to identify products produced under the Label Service. This label bears the Label Service Symbol together with the classification of the product involved.

A limited number of products are Listed under the Die-Label Service whereby the Label Service Symbol is stamped, cast, or moulded in the product. Also, a Certificate may be signed by both manufacturer and the Laboratories, which lists definite quantities of material intended for specific job sites, under the Certificate Service.


The services of Underwriters' Laboratories are very valuable to the Fire Protection Engineer, as well as the manufacturer. Underwriters' Laboratories is quite diversified as to the various fields into which it extends, as is the Fire Protection Engineer; in this respect both can often work hand in hand. The results arrived at by Underwriters' Laboratories can be used by the Fire Protection Engineer as a basis of standard upon which he can solve various engineering problems with confidence. Listed materials, devices, and construction methods may be employed without the engineer having to go into a large amount of personal research on the hazards involved. Further, as Underwriters' Laboratories Listed products are so widely accepted by insurance organizations and building codes authorities etc., the engineer can be assured that his client will receive the most appropriate service in this aspect.

Howard Engerman

LaSalle Hotel fire created much interest in Hazard classif. People wanted a way of measurement. Had to choose 2 math - one incident & 1 comb. for basis.

CLASSIFICATION

1. Flame Squad most important - obscured
2. Fuel Cont. - recorded
3. Smoke Developed - recorded



40 \pm 5% rel. Humidity
70 \pm 5 $^{\circ}$ C

Methane gas used.

the 240/min established using R.O.
⇒ flame goes 19½' in 5½ min. = 15 sec. → F.S. 100

10 min test

See 3 formulae

Majority of math based on distance formula since most don't reach end.


MEASURE From Burner and subtract 4½' for calculations.
DATA is 4½ too big.

Ambiguity in formulae

$$F.S. = \frac{5.5}{T} + \frac{1}{2} \left[100 - \frac{5.5(100)}{T} \right]$$

there must be some way to recognize math which burn ~~some way~~ some dist. & stop & also to recognize flash over & then recede. this formula set up takes it into account.

Fuel cent: At 23' TC 1-2" below ∇ ACB



ACB is incand, so TT curve results from fuel of burner.

$$\frac{\text{Time}}{\text{Temp}} \Rightarrow \text{BTU}$$

$$\text{F.C.}_{\text{ACB}} \Rightarrow 0$$


$$\text{AREA}_{\text{RO}} - \text{AREA}_{\text{ACB}} \Rightarrow 26.6 \text{ IN}^2 - 14 \text{ IN}^2 = 12.6 \text{ IN}^2$$

↓
100

$$A_x - 14 \text{ IN}^2 = 6.3 \text{ IN}^2 \text{ (ARB)}$$

$$\frac{6.3}{12.6} \times 100 \Rightarrow \text{F.C. of } 50$$

$$S.D. = \frac{A_x}{1.29}$$



* Readings aren't absolute

* Furnace calibrated \Rightarrow

F.S.	$\Rightarrow 0_{ACB}$	$\Rightarrow 100_{RO}$
F.C.	$\Rightarrow 0_{ACB}$	$\Rightarrow 100_{RO}$
S.D.	$\Rightarrow 0_{ACB}$	$\Rightarrow 100_{RO}$




Walter Haas.


Glass Block

U.L. 9

Glass blocks suitable for
 $\frac{3}{4}$ in. of exterior openings.

Cannot exceed 120 ft² opening
nor 12' max dimension






lintel (3 top angles)
(shaded)

carries load
above window


JAMB.

15 Glass Block wide
17 block high



1 part cement, 1 part hydrated lime
4 parts sand (by volume)
for mortar

Reinforcing #9 gauge wires ~~with~~
 with #14 ga. mesh. 8" apart
 2" apart with #14 wire





every 3rd row of block starting
 at bottom

More Stream Test

band on area
 you can hit with stream.

$137\frac{2}{16}$ " height

$117\frac{1}{4}$ " width



$$\frac{137\frac{2}{16}}{12} \times \frac{117\frac{1}{4}}{12} \times 0.6$$

time in seconds
 to be applied

$\frac{175}{55}$ 137 high
 A mesh


$$9 \sqrt{\frac{34}{137}} \frac{12}{14}$$

Observations-

1. Exposed side
2. unexposed side- deflection ~~the~~
meas with wire stretched across.
3. Instrument to read temp
in furnace.
4. Control gas valves.

chattering of glass?

No limitation on temp transmission



FIRE DOORS

to protect a wall opening
See mimeo notes from 309

Class A - fire walls 3 HR.
usually one door on ea. side
B - next shafts - stair cases,
rubbish chutes etc.
 $1\frac{1}{2}$ or 1 HR.


100 in² VISION PANEL PER OPENING.
MAX 12" dimension
↓
if 2 doors
not > 100 in²
total

C - corridors & room partitions
NOT LABELED FIRE DOORS.

1296 in² MAX

could have 1296 in ea
of a pair of doors.

OR



except not mullions for
N

Why jets in rear?

Kimble GLASS

2 min cracking 0



3 min " +

" " flying glass.

4 " blocks exploding

" " all blocks cracked

except *



5 min meas defl. 10" S
 10 1/4" C
 10" N

6 min observed pin holes in exposed side
 colored block, can't tell on clear

10 min - defl 10" S
 10 1/2" C
 10 1/4" N

15 min framing secure
 18 " defl 10 7/8" S
 11" C
 10 5/8" N

x

25 min 11" S
 11 $\frac{1}{4}$ C
 10 $\frac{5}{8}$ N

angle sag on inside

30 min 10 $\frac{3}{4}$ S
 11 $\frac{1}{4}$ C
 10 $\frac{1}{2}$ N

Results

1. Stayed in frame.
2. ?

Doors Card

"D" ext wall 1 $\frac{1}{2}$ hr.

"E" door + window

not > 720 m² glass

"F" $\frac{3}{4}$ Hr. 1296 m² window

34 HOLES

8:30

NORTH BROOK

Deflections

Time	S	C	N
0	$9\frac{1}{4}$	$9\frac{1}{4}$	$9\frac{1}{4}$
5	10	$10\frac{1}{4}$	10
10	10	$10\frac{1}{2}$	$10\frac{1}{4}$
15	$10\frac{5}{8}$	11	$10\frac{1}{4}$ $10\frac{5}{8}$
20	11	$11\frac{1}{8}$	$10\frac{5}{8}$ $10\frac{3}{4}$
25	11	$11\frac{1}{8}$	$10\frac{3}{4}$ $10\frac{5}{8}$
30	$10\frac{3}{4}$	11	$10\frac{1}{2}$
35			
40			

wholly
deflected
inward

inner surface
until outer side
gets hot

D. LUCHT


igniting flame to adjusted so that

1. the primary requirement for calibration of the tunnel as set forth by the U.L. 723 is that the flame ^{will} spread on red oak lumber is $19\frac{1}{2}$ feet in $5\frac{1}{2}$ min \pm 15 sec. [also preheat using A.C.B.]
- Major Controls:

1. DRAFT 210 ± 5 ft/min
2. AMBIENT TEMP: $70 \pm 5^\circ\text{F}$
3. REL. HUMIDITY 30-40%
4. PREHEAT - Thermocouple reading $105 \pm 5^\circ\text{F}$
5. FUEL - METHANE GAS @ 5000 Btu/min
6. $3" \times 17\frac{1}{2}"$ DRAFT OPENING

2. not necessarily, the flame may spread very rapidly or flash and will ~~to~~ exhibit very low smoke and full contributed characteristics.
- etc.

3.



$$F.C. = \frac{A_u - A_{RO}}{A_{RO} - A_{ACB}} \times 100$$

where A_u = AREA UNDER UNKNOWN CURVE ("A" or "B")
 A_{RO} = AREA UNDER RED OAK "
 A_{ACB} " " " ASBESTOS CEM. BRD. CURVE

4.

1. MOISTURE CONTENT OF SAMPLE

2. AIR VELOCITY OF DRAFT

3. INTENSITY OF IGNITION FLAME.

4. AMBIENT ROOM TEMP.

5. STRUCTURAL CHARACTERISTICS OF THE MATL ITS SELF

(2)

F.S. = $(100 \times \frac{5.5}{T})$ for $t \leq 5\frac{1}{2}$

5. TIME: F.S. = $(100)(\frac{5.5}{T}) + \frac{1}{2}(100 - \frac{550}{T})$ $t = 5\frac{1}{2} \approx 10$ min.

DISTANCE: F.S. = $(100)(\frac{L}{19\frac{1}{2}})$

$\frac{100L}{19.5} = 90$

$L = .9(19.5) \approx 17.6'$

$\frac{19.5}{.9} = 21.67$
 $\frac{21.67}{1.2} = 18.06$

~~$\frac{550}{T} = 90$~~

~~$40T = 550$~~

~~$T = \frac{550}{40}$~~

$9 \overline{) 550}$
 100

~~$\frac{275}{T} = 90$~~

$\frac{550}{T} + 50 - \frac{275}{T} = 90$

$\frac{275}{T} = 40$

$40T = 275$

$T = 6.87$ min.

$\frac{250}{25} = 10$

$\frac{550}{275} = 2$

$40 \overline{) 275}$
 200
 350
 320
 300

(-)

* ~~90~~, which burns faster, F.S. of 90 determined by time indicates that the flame has spread over the end of the sample (19 1/2' FS) in about 6.9 min. Determined with respect to distance, the flame has only spread 17.6 feet in 10 min.

6.

the material may ~~exhibit~~ provide a very irregular time temperature curve or exhibit very peculiar burning characteristics. e.g. styrofoam board - this matl melted before it burned

10 X

D. LUCHT

FPE 303
D. LUCHT

83

$$C_2 = 100 \left(\frac{P_2}{P_1} \right)^{\frac{\gamma}{\gamma-1}} = 100 \left(\frac{100 - 22}{100} \right)^{\frac{1.4}{1.4-1}} = 27$$

$$C_2 = 100 \left(\frac{P_2}{P_1} \right)^{\frac{\gamma}{\gamma-1}} = 100 \left(\frac{100 - 22}{100} \right)^{\frac{1.4}{1.4-1}} = 27$$

$$C_2 = 100 \left(\frac{P_2}{P_1} \right)^{\frac{\gamma}{\gamma-1}} = 100 \left(\frac{100 - 22}{100} \right)^{\frac{1.4}{1.4-1}} = 27$$

$$C_2 = 100 \left(\frac{P_2}{P_1} \right)^{\frac{\gamma}{\gamma-1}} = 100 \left(\frac{100 - 22}{100} \right)^{\frac{1.4}{1.4-1}} = 27$$

$$C_2 = 100 \left(\frac{P_2}{P_1} \right)^{\frac{\gamma}{\gamma-1}} = 100 \left(\frac{100 - 22}{100} \right)^{\frac{1.4}{1.4-1}} = 27$$

$$C_2 = 100 \left(\frac{P_2}{P_1} \right)^{\frac{\gamma}{\gamma-1}} = 100 \left(\frac{100 - 22}{100} \right)^{\frac{1.4}{1.4-1}} = 27$$

$$C_2 = 100 \left(\frac{P_2}{P_1} \right)^{\frac{\gamma}{\gamma-1}} = 100 \left(\frac{100 - 22}{100} \right)^{\frac{1.4}{1.4-1}} = 27$$

$$C_2 = 100 \left(\frac{P_2}{P_1} \right)^{\frac{\gamma}{\gamma-1}} = 100 \left(\frac{100 - 22}{100} \right)^{\frac{1.4}{1.4-1}} = 27$$

$$C_2 = 100 \left(\frac{P_2}{P_1} \right)^{\frac{\gamma}{\gamma-1}} = 100 \left(\frac{100 - 22}{100} \right)^{\frac{1.4}{1.4-1}} = 27$$

A DISCUSSION OF FLUID PRESSURE

6th Semester

1. GENERAL

The purpose of this session is to discuss the theory of fluid pressure, fluid pressure measurement and to familiarize the student with instrumentation used for fluid pressure measurement.

The discussion includes a review of the definition of fluid pressure, the common units for expressing both absolute and gauge pressure, variation of pressure in a fluid, Pascal's Law, etc. Discussion of instruments for measuring pressure includes the piezometer, the simple manometer, the differential manometer and the Bourdon Gauge, as well as the location and connection of these instruments to actual systems. Since these instruments will be used in subsequent laboratory work, the students are expected to familiarize themselves with the design and construction of this equipment.

The calibration of a Bourdon Gauge by means of a dead-weight gauge tester is discussed, demonstrated and performed by the students.

2. References

- A. Chapter 1 and Sections 2.1, 2.2 and 2.3, Hydraulic Systems for the Fire Protection Engineer.

3. Discussion Session

- A. See Item 1 above.

4. Tests

One or more Bourdon Gauges are provided the students for calibration by means of a dead-weight gauge tester.

5. Report

No report is required on the work done during this class session.

FLOW MEASUREMENT I -
A STUDY OF THE VENTURI METER AND THE ORIFICE PLATE METER

SHORT FORM REPORT

1. GENERAL

The purpose of this session is to provide an understanding of the techniques and instrumentation for the measurement of fluid flow, with emphasis on the theory and calibration of the Venturi Meter and the Orifice Plate Meter.

A combination of material balance and energy balance is applied to a water system in steady flow to determine the calibration coefficients of a Venturi Meter and an Orifice Plate Meter. Differential manometers are used to determine the pressure drop across each meter. Since the meters are installed in series in the same pipe system, the measurement of flow rate at any condition of adjustment applies simultaneously to both meters. Flow rate is determined by collection of water in either a volume tank, or a weight tank for a known period of time. As the work proceeds by varying the pressure drop across the meters, and measuring the flow rate for each adjustment, the data is checked by plotting flow rate versus pressure drop on log-log graph paper. Reruns are made to correct unsatisfactory data. The equations of the curves representing the data are determined.

2. References

- A. Sections 2.4, 2.5, 3.1, 3.2 and 3.3, Hydraulic Systems for the Fire Protection Engineer.

3. Discussion Session

- A. General discussion of flow measurement and fluid metering in most engineering problems, and fire protection engineering in particular.
- B. Classification of fluid flow meters.
- C. General discussion of calculations, graphs and report.

4. Tests

- A. Adjust the flowing system to produce a number of suitable pressure drops across the flow meters. For each adjustment determine the flow rate by collecting the water in either a volume tank, or a weight tank for a suitable length of time. Calculate the flow rate in gallons per minute and the pressure drop across each meter in pounds per square inch and feet of head of water. The points should lie on a straight line when plotted on log-log graph paper. Check unsatisfactory data. Determine the equations of the curves which describes the data for each meter. Calculate the average calibration coefficient for each meter.

5. Report

- A. Prepare a report as assigned by the instructor.
- B. Conclusions should include a comparison of the behavior of the two meters, as well as the behavior of the meters as individuals of a class of meters.

FLOW MEASUREMENT II -
A STUDY OF THE FLOW NOZZLE METER AND THE PITOT TUBE METER

1. GENERAL

The purpose of this session is to provide an understanding of the techniques and instrumentation for the measurement of fluid flow, with emphasis on the theory and calibration of the Flow Nozzle Meter and the Pitot Tube Meter.

A combination of material balance and energy balance is applied to a water system in steady flow to determine the calibration coefficients of a Flow Nozzle Meter and a Pitot Tube Meter. The nozzle is arranged to discharge downward into the atmosphere, while the pitot tube inlet is fixed in the nozzle stream. Bourdon Gauges are used to measure the pressure upstream of the nozzle, as well as the pitot tube pressure, both gauges being arranged in the same reference plane at the level of the nozzle outlet. Since the meters are in effect installed in series in the same flow system, the measurement of flow rate at any condition of adjustment applies simultaneously to both meters. Flow rate is determined by collection of water in either a volume tank, or a weight tank for a known period of time. As the work proceeds by varying the pressure upstream of the nozzle, and measuring the flow rate for each adjustment, the data is checked by plotting flow rate versus pressure on log-log graph paper. Reruns are made to correct unsatisfactory data. The equations of the curves representing the data are determined.

2. References

- A. Sections 3.4 and 3.5, Hydraulic Systems for
The Fire Protection Engineer.

3. Discussion Session

- A. A continued discussion of flow measurement and fluid metering in engineering problems, and fire protection engineering in particular.
- B. General discussion of calculations, graphs and report.

4. Tests

- A. Adjust the flowing system to produce a number of suitable pressures, as measured by the Bourdon Gauge upstream of the nozzle. For each nozzle pressure a pitot tube pressure is measured and recorded. For each adjustment, determine the flow rate by collecting the water in either a volume tank or a weight tank for a suitable length of time. Calculate the flow rate in gallons per minute and convert the gauge pressures from pounds per square inch to feet of head of water. The points should lie on a straight line when plotted on log-log graph paper. Check unsatisfactory data. Determine the equations of curves which describes the data for each meter. Calculate the average calibration coefficient for each meter.
- B. Repeat the above procedure for at least three nozzles of different types.

5. Report

- A. Prepare a report as assigned by the instructor.
- B. Conclusions should include a comparison of the behavior of the two meters, as well as the behavior of the meters as individuals of a class of meters.

A Study of Friction Head Loss in Pipe

1. GENERAL

The purpose of this session is to provide an understanding of the techniques and instrumentation for the determination of the friction head loss in pipe and to demonstrate the applicability of the Darcy-Weisbach and Hazen-Williams equations to the flow of water in pipes. D-W

H+W

A combination of material balance and energy balance is applied to a water system in steady flow to determine the pressure drop between two points a measured distance apart on a pipe. The inside pipe diameter listed in the appropriate ASA Specification is assumed to apply for new pipe. Flow rate is determined by collection of water in either a volume tank, or a weight tank for a known period of time. As the work proceeds by varying the pressure drop across a known length of pipe, and measuring the flow rate for each adjustment, the data is checked by plotting flow rate versus pressure drop on log-log graph paper. Reruns are made to correct unsatisfactory data. A comparison is made between the measured friction loss and the calculated friction loss for new pipe. For each run a calculation is made of the Friction Factor (f) in the Darcy-Weisbach equation and of the Roughness Coefficient (C) in the Hazen-Williams equation.

2. Reference

- A. Section 2.8 Calculation of Friction Head Losses in Pipes and Fittings, and Section 2.9 Williams and Hazen Formula: An Empirical Equation for Pipe Flow, Hydraulic Systems for the Fire Protection Engineer.

Johnston eeee SPS

3. Discussion Session

- A. General discussion of pipe friction and the ageing of pipe.
- B. Discussion of the use of the Darcy-Weisbach and Hazen-Williams equations.
- C. General discussion of calculations, graphs and report.

4. Tests

- A. Adjust the flowing pipe system to produce a number of suitable pressure drops across a known length of pipe. For each adjustment, determine the flow rate by collecting the water in either a volume tank, or a weight tank for a suitable length of time. Calculate the flow rate in gallons per minute and the pressure drop in pounds per square inch and feet of head of water. The points should lie on a straight line when plotted on log-log graph paper. Check unsatisfactory data. Compare the results with the friction loss for new pipe and calculate the per cent change in friction loss based on new pipe. For each run calculate the Friction Factor (f) in the Darcy-Weisbach equation and the Roughness Coefficient (C) in the Hazen-Williams equation.
- B. Repeat the above procedure for at least three pipes of different sizes.

5. Report

- A. Prepare a report as assigned by the instructor.
- B. Conclusions should include a comparison of the results with that of new pipe, as well as the applicability of the Darcy-Weisbach and Hazen-Williams equations to the experimental results.

A Study of Dry Pipe Systems, Dry Pipe Valves and Quick-Opening Devices

I. GENERAL

The purpose of this session is to acquaint the student with the characteristics of dry pipe systems and with the performance of dry pipe valves and quick-opening devices.

NFPA Standard No. 13 outlines the requirements for the design and installation of automatic sprinkler systems. Only the general features of the design and installation of dry pipe sprinkler systems are considered in this work; the details of design, installation and hydraulic calculation of sprinkler systems is treated in another course.

A dry pipe sprinkler system is a special purpose system to be used only in unheated buildings subject to freezing temperatures. The layout of sprinklers and piping arrangement for a dry pipe system is similar to a wet-pipe system; the water flow into the piping system is controlled by a dry pipe valve (protected from freezing.) Compressed air in the piping above the valve holds the dry pipe valve closed, preventing water from entering the sprinkler piping until the air pressure has dropped below a predetermined value.

Dry pipe systems are subject to a time delay in application of water on the fire and are, therefore, restricted in size and under certain conditions dry pipe valves are required to be equipped with a quick-opening device to reduce the time delay. The behavior of dry pipe valves is studied when installed on systems of various sizes, with and without a quick-opening device.

2. References

- A. Read Chapter IX, and Part B of Chapter III, Section 16, Fire Protection Handbook, NFPA, Twelfth Edition.

3. Discussion Session


- A. General discussion of dry pipe sprinkler systems
- B. Discussion of differential and mechanical type dry pipe valves; and accelerator and exhauster type quick-opening devices.

4. Tests


- A. For various water supply pressures determine the air pressure at the trip point of a dry pipe valve and the time from the opening of a sprinkler until the valve trips and until the simulated application of water upon the fire. Perform these tests with the dry pipe valve equipped with and without an accelerator and exhauster.

5. Report


- A. Prepare a report as assigned by the instructor.
- B. Conclusions should include a comparison of the results with and without a quick-opening device, for the various sizes of dry pipe systems.



To indicate pressure
but would req. a
hell of a tall pipe or tube.



Pascal's Law says pressure @ a pt
in fluid is transmitted in all dir.
⊥ to surface. a.e. **STATIC PRESSURE HEAD**




Pressure @ a pt = height of
col. H_2O above. times w (sp. wt.)

ABSOLUTE vs. GAGE?

Now, all gauges read zero @ atm. pressure.

PIEZOMETER
TUBE



gauge reads psi
whereas h_p read
sp. wt. in feet.

$$P^* \text{ Pressure } \text{psf} = (h_p \text{ ft}) (\gamma \text{ lb./ft}^3) \quad (\gamma = \text{sp. wt. conventional})$$


$$P^* = \text{psf} \quad (W = \text{sp. wt. lakes})$$

$$P = \text{psi} \quad P^* = h_p W$$


ABSOLUTE PRESSURE = GAUGE + ATM. (barometer)

Vacuum Gauges read "Hg (below atm.)"

Some Gauges



Sp. Wt. $H_2O = 62.4 \text{ LB./FT}^3 @ \approx 52^\circ F$



? pressure on $1 \text{ sq.} ?$


$$P = \frac{62.4 \text{ LB.}}{144 \text{ IN}^2} = .433 \text{ psi/ft.}$$

$$\frac{.433}{12} = \underline{\underline{.0361 \text{ psi/IN}_{H_2O}}}$$

a.c. a col. of
 H_2O 1 FT high \Rightarrow .433 psi

$$\frac{1}{.433} = \underline{\underline{2.31 \text{ FT}_{H_2O}/\text{PSI}}}$$

SIMPLE MANOMETER



$$h_n = \frac{P_A}{w} = 0(\text{gauge}) + S y + z \quad \text{only if } A \text{ is water.}$$


\swarrow sp. gravity.
 \nwarrow sp. grav. Hg.

Hg - Sp. grav = 13.6

~~13.6~~ .0361 psi/in. water

$(13.6)(.0361) = \underline{\underline{.49 \text{ psi/in. Hg.}}}$

DIFFERENTIAL MANOMETER



Can't be any Bubbles in H₂O ∴ Bleed it off

$$z_A - z_B = -y$$

$$\frac{P_A}{w} - z_A - S y + z_B = \frac{P_B}{w}$$

$$\frac{P_A}{w} - \frac{P_B}{w} = S y - y = y(S-1)$$

If A + B differ in elevation by
 x ,

$$z_B = z_A + x + y$$

Now $z_A - z_B = -y - x$

$$\text{"Hg. } \& \text{ psi} = .491$$

But in this Manometer have to take into account fact that water is on top of Hg.


$$\text{Now "Hg to psi} = .491 - .036 = .455$$

Can't call it "Hg on differential Manometer since it has water on it.

must convert -

Take ~~so~~ scale reading in " + mult by .455


Bourdon Gauge



Calibration

Dead wt.


Usually calibrated at centre of dial
a.e. 250 psi gauge set @ 125



most accurate in middle or near middle
of scale.

\therefore Choose a gauge that will read
desired pressure in middle.

Data:



1. Manometer Reading - in.
2. Δh - psi = Manometer level (.455)
3. Sage Readings
 - a. upstream
 - b. downstream
4. GAL. Collected H_2O
5. time (min)
6. GPM
7. K

$$Q = K\sqrt{\Delta h}$$

Differential

1. 3"

3"	1.4"	#1	#2	#3	#4
		73	70	72	71
7	3.2	71 72	67 68	71 70	69 68
11	5.2	69 68	64	68	66
15	7.1	67	60	66	63
19	9	66	65 57	64	61 60
26		64	52	63 63	57 56

Short form report

Canned " + psi Hg.

Readings 1, 2, 3

Venturi pressure recovers well but does have pressure loss -

5' of 3" pipe after venturi to next pressure meas.

a.e. 5' from outlet of venturi to inlet of orifice

$$\therefore \Delta h_f - h_{frict} = \text{loss due to Venturi}$$


* V

Hydraulic Data Manual — Q vs. h_f chart

@ 65 = Q \rightarrow .011' head / ft of pipe

.055' head lost due to frict after outlet of Venturi

Good GRAPH Δh




Different kinds of Sprinkle Nozzles.


~~1. Grinnell~~

1. Grinnell B - Smooth Tapered Nozzle 0.432" dia.


↓
descending
efficiency



2. Rockwood D - Shoulder type 0.500" dia.



3. Grinnell A (Mfg. 1932) - Thin Plate Nozzle 0.495" dia.




Calculate C_d

EQ. 3-15

C_d = flow coeff. for nozzle or orifice

~~$Q = 29.83$~~



Slows down water to convert vel. head to pressure head (meas.) which is all converted back to vel. head at the orifice in free space.

EQ. 3-15

$$Q_{gpm} = 29.83 C_d d_{in}^2 \sqrt{\Delta P_{psi}} = Q_{gpm} = K \sqrt{\Delta P_{psi}}$$

↑
dimensionless

$$K = 29.83 C_d d_o^2$$

Can use C_d to compare to other nozzles.

→ find C_d besides K

measure Q
 " ΔP

Short
 Form.

at 200 psi
 reads $+ \frac{1}{2} \text{ lb./in}^2$

Set known pressure on pressure head
 gauge & let vel. head follow.

Plot ΔP v. Q


Set. Pressure Head	Pitot head.	Q	T
8 psi	7.8	100 gal	6:40
12 psi	11.0	100 gal	5:26
16 psi		100	
22 psi	22.0	100 gal	3:55
30 psi	29.0	150 gal	5:11

Pressure Head	Pitot head.	Q	T
8 psi	8 psi	100 gal	5:52
12 psi	11 psi	100 gal	4:51
22	22	150 "	5:22
30	30	150 "	4:36

Pressure Head	Pitot head.	Q	T
8 psi	7.5 psi	100 gal	6:10
12	11.5 psi	100 gal	5:01
22	22	150 "	5:34
30	29	150 "	4:45

Wet Pipe Systems have been found to require fewer heads than dry.
 See PG 16-16 - HANDBOOK

WET SYSTEM




CITY H₂O
 not on public property
 - don't want it tampered with

Generally don't put both inside shut off valve AND Post Indicator Valve.


Install alarm system \Rightarrow people know when system is in operation for some reason.
 People must be taught what to do when the alarm does go

ALARMS


1 WATER FLOW INDICATOR



2. ALARM CHECK VALVE



Alarm Check Valve with auxiliary valve seat



All alarms must be desensitized \rightarrow
water surges won't send alarm.


Water Taps

Wet Pipe Systems

"Flexibility" of Wet Pipe System -

At a given initial pressure P_1 , measured at the alarm check value, the system flexibility, X_f , is defined as the quantity of water, in gallons, which must be drained out of the system to reduce the initial pressure by 10 psi.

$$P_1 - P_2 = 10 \text{ psi} \quad \text{EQ. (1)}$$



$$\text{GAL.} = \text{TOTAL VOLUME} = V_T = V_W + V_A \quad \text{EQ. (2)}$$

WATER + AIR

$$\text{@ } P_1 \quad V_T = V_{W_1} + V_{A_1}$$

$$\text{@ } P_2 \quad V_T = V_{W_2} + V_{A_2}$$

$$\text{@ } P_1 - P_2 \quad V_{W_1} - V_{W_2} = X_f = V_{A_2} - V_{A_1} \quad \text{EQ. (3)}$$

By Gas Laws: (Pressure in ABSOLUTE)

$$\frac{P_1 V_{A1}}{T_1} = \frac{P_2 V_{A2}}{T_2} \quad \text{EQ. (4)}$$

CONSIDER $T_1 = T_2$ for short time interval

~~EQ. (4)~~

$$P_1 V_{A1} = P_2 V_{A2} \quad \text{EQ. (5)}$$

$$\frac{P_2}{P_1} = \frac{V_{A1}}{V_{A2}} \quad \text{EQ. (5-A)} \quad \text{~~EQ. (5)~~}$$

DIVIDE (5) BY P_1 :

$$\frac{P_2}{P_1} = \frac{P_2}{P_1} = \frac{10}{P_1} \quad \text{EQ. (6)}$$

OR

$$\frac{P_2}{P_1} = 1 - \frac{10}{P_1} \quad \text{EQ. (6A)}$$

DIVIDE (3) BY V_{A1}

$$\frac{V_{A2}}{V_{A1}} - \frac{V_{A1}}{V_{A1}} = \frac{X_F}{V_{A1}} \quad \text{EQ. (7)}$$

$$\frac{V_{A2}}{V_{A1}} = 1 + \frac{X_F}{V_{A1}} \quad \text{EQ. (7A)}$$

COMBINE (6A), (7A) + (5A)

$$\frac{X_F}{V_{A1}} + 1 = \frac{P_1}{P_1 - 10}$$

Solve for X_f

$$X_f = V_{A_1} \left(\frac{10}{P_1 - 10} \right)$$

Max Size of System - Pg. 104 - Pamphlet 13

(Max size \Rightarrow there won't be too much time delay)

max 600 heads OR 750 GAL. CAP.

↑
volume of Pipes

Quick Opening Devices Required if $\left. \begin{array}{l} \nearrow \\ \searrow \end{array} \right\}$
if > 500 GAL. CAP.


DRY PIPE VALVE

1. DIFFERENTIAL DPV

2. OLD MECHANICAL DPV


3. NEW MECHANICAL DPV

1. DIFFERENTIAL DPV



THEOR \rightarrow Differential $\approx \frac{\text{AIR SEAT AREA}}{\text{H}_2\text{O SEAT AREA}}$ e.g. 6 to 1

Working Differential @ trip pt. $\frac{\text{air pressure}}{\text{H}_2\text{O pressure}}$




$\frac{\text{H}_2\text{O pressure}}{\text{AIR pressure}}$
 $\approx 5 \text{ or } 6 \text{ to } 1$

Working Differential = SLOPE

Mainly interested in plot so we can check older valves with original plot + see how it compares if it needs new valve etc

Quick Opening Device useable ONLY
with Differential DPV.


ACCELERATOR Q.O.D.



Decrease in air pressure
of system decreases pressure
in lower chamber faster
than it can leak out
of upper chamber \Rightarrow diaphragm
lowers and allows
pressure into intermediate
chamber

now air is pushed out by
 H_2O rather than just
expanding out.


NEW MECH. DPV.



Air Pressure Alone
isn't enough to
hold valve closed.

EXTRA FORCE NEEDED.


Air
Press
psi



Force sides of air
pressure - A GIVEN
air pressure will trip

Clapper usually latched &
released with 1 drop of air pressure.

EXHAUSTER - WORKS ON ANY VALVE.



Exhauster must close when water comes -

SEE PG. 16-151

EXPT.

START WITH 750 GAL CAP.

Build up 35 psi air each time
Open "sprinkler" to bleed air pressure
Time when:

1. Open sprinkler
2. DPV TRIPS

4. AIR PRESSURE @ TRIP
INITIAL AIR PRESSURE.

3. WATER BUILDS UP TO
CERTAIN LEVEL (EACH TIME SAME LEVEL)
(\approx WATER ON FIRE)

A Study of Deluge and Preaction Systems and Deluge and Preaction Valves

1. GENERAL

The purpose of this session is to acquaint the student with the characteristics of deluge and preaction systems and with the performance of deluge and preaction valves.

NFPA Standard No. 13 outlines the requirements for the design and installation of automatic sprinkler systems. Only the general features of the design and installation of deluge and preaction sprinkler systems are considered in this work; the details of design, installation and hydraulic calculations of sprinkler systems is treated in another course.

Deluge and preaction sprinkler systems are special purpose systems; a deluge system is designed to wet down an entire fire area by admitting water to sprinklers that are open at all times; a preaction system is designed primarily to protect properties where there is danger of serious water damage as a result of damaged automatic sprinklers or broken piping. The behavior of deluge and preaction valves are demonstrated in this work.

2. References

- A. Read Chapter X, and Parts C, D and E of Chapter III, Section 16
Fire Protection Handbook, NFPA, Twelfth Edition.

3. Discussion Session

- A. General discussion of deluge and preaction systems.

4. Tests

- A. Demonstration of the operation of a deluge and preaction system.

5. Report

- A. Prepare a report as assigned by the instructor.

Preaction & Deluge Systems

DELUGE SYSTEM

all sprinklers flow at once
no links

Special control valve in riser

- need strong water supply.

Max. size allowable for one valve

pg. 116 pamphlet 13

not > 150 heads on 6" riser

consider min 15-20 gpm/head = 2250 gpm. (total)

If more than one system opens = lot of H₂O

By proper arrangement, can reduce
systems which would open for
one fire.

Used where conventional type system would
be too slow & ~~over~~ overloaded if all
heads did open.

Heat detection devices -

e.g. rate of rise detector
very fast - 30 sec. is long time for
deluge response.

pg 16-162-3 Handbook.
Mechanical Valve

FIG. 16-165

HAD = Heat Actuated Device

Air Chamber - heats & builds

up air pressure in tubes to sensitive diaphragms

Compensating Vent in diaphragm
is calibrated / leak \Rightarrow normal temp
pressure won't actuate.
 \rightarrow Calibrated to suit occy + desires
Must be careful — False actuation
would be costly.

HAD usually located 50' on centre
& 25' from wall.

FIG 16-166

map of HAD's GROUP

FIG 16-182B upstairs


FIG 16-180

FLASH POINTS

DEF. Pg. 4-8 NFPA Handbook

Mixt must be at certain temp \Rightarrow
vapor pressure will give off vapor
@ mixture in explosive range.

Below flash point temp, vapors
will still come off a.e. will still
be vapor pressure
Must be sufficient to attain lower
explosion limit.



Total mixture must be 100%

IGNITABLE MIXTURE = mixture capable of
propagating flame away from
source.

Will be a reaction below LEL +
above UEL, but won't be a prop.
of flame away from source of ignition
Not enough fuel in one case, not
enough air in other case

FIRE Pt. - Temp @ wh. flame
begins + remains.

ASTM ~~1916~~ 1916 Race St., Phila 3

STD. METHOD OF TEST FOR
Flash & Fire Points by Cleveland
Open Cup.

ASTM Designation D92-57

OR

TENTATIVE METHOD OF TEST FOR
Flash Point by PENSKY-MARTENS
Closed TESTER

ASTM Designation D93-58T

F.P.E. 304