



# WPI

## Characterization of a Well-Type HPGe Detector Using Standards

A Major Qualifying Project Report  
Submitted to the faculty of  
WORCESTER POLYTECHNIC INSTITUTE  
In partial fulfillment of the requirements for the  
Degree of Bachelor of Science

Submitted to:  
Stephen J. Kmiotek

By:  
Jolina T. Alonzo

11 December 2022

Advised by:  
Dr. Bruce D. Pierson (PNNL)

*This report represents work of WPI undergraduate students submitted to the faculty as evidence of a degree requirement. WPI routinely publishes these reports on its web site without editorial or peer review. For more information about the projects program at WPI, see <http://www.wpi.edu/Academics/Projects>.*

## ABSTRACT

The characterization of the WELL3 detector, a well-type detector, at Pacific Northwest National Laboratory (PNNL) is an important and necessary capability for performing high-precision, low-intensity radio-isotope measurements. The characterization of the WELL3 detector provided the Advanced Radio-Emission Spectroscopy (ARES) team with another detector to analyze and obtain data for weak radioactive isotopes. A benchmarked calibrated and characterized model of the WELL3 detector was created using the CERN C++ particle simulation framework GEANT4<sup>1</sup> with a PNNL developed utility, the Geant4-Cascade Summing Correction tool<sup>2</sup>. This benchmark was constructed by conducting quantitative intercomparison of the modeled and measured detector response to a National Institute of Standards & Technology (NIST) traceable mixed gamma standard mix 7503 from Eckert & Zeigler and a medical isotope standard of Molybdenum-99 (Mo-99) from the National Physical Laboratory. The mixed gamma standard, NIST traceable measured detection efficiency, was used to optimize the model parameters before conducting an independent validation using the Mo-99 standard. A comparison of peak ratios was performed between the measured and simulated spectra of Mo-99 to analyze the accuracy of the decay cascade summing probabilities predicted by the model. From the counted Mo-99 sample the half-life ( $T_{1/2}$ ) was obtained for each relevant gamma ray energy lines and compared against the Evaluated Nuclear Structure Data Files (ENSDF) available from the National Nuclear Data Center. The analysis of the true-coincidence summing (TCS) corrections of the Mo-99 response from the benchmarked model show large corrections were made to simulate the spectrum from Mo-99 on WELL3. The future work will encompass further optimization of the calibrated detector model on GEANT4 with G4CSC. The current characterization of the WELL3 detector shows promise for the counting of Tb-161, an important nuclide in medical physics. Overall, the characterization of the WELL3 detector at PNNL now provides the ARES team a new capability for the high-efficiency detection of weak samples.

---

<sup>1</sup> S. Agostinelli *et al.*, “Geant4—a simulation toolkit,” *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, vol. 506, no. 3, pp. 250–303, Jul. 2003, doi: 10.1016/S0168-9002(03)01368-8.

<sup>2</sup> B. Pierson, B. Archambault, A. Hagen, and C. Soren, “G4CSC.” Accessed: Nov. 30, 2022. [Online]. Available: <https://gitlab.pnnl.gov/ares/g4csc>

# SUMMARY

## Introduction

A well-type high purity germanium (HPGe) detector has the capability to place samples inside the detector. This distinct characteristic results in a high detection efficiency for the activity measurement of gamma ray emissions from the decay scheme of a radioactive sample. This detector is the most sensitive form of the HPGe detector since provides the maximum feasible sensitivity for weak samples of radioactive isotopes. The characterization of the WELL3 detector, a well-type detector, at Pacific Northwest National Laboratory (PNNL) is important to provide the capability of a well-type detector for sample analysis. Overall, the characterization of the WELL3 detector at PNNL provides the Advanced Radio-Emission Spectroscopy (ARES) team with another detector to analyze and obtain data for a wide range of radioactive isotopes.

## Experimental Description

A calibration sample was obtained to start the process of the characterization of the WELL3 detector. The calibration sample was then counted on the WELL3 detector. A benchmarked calibrated and characterized model of the WELL3 detector was created using GEANT4[1, p. 4] software. The process was based on creating an optimized detector model using the instrument specifications sheet from the manufacturer and physical measurements taken in the laboratory. With the benchmarked model of the WELL3 detector, Molybdenum-99 (Mo-99) was simulated to produce a spectrum of the detector model response. A single-isotope nuclide gamma standard of Mo-99 was counted on the WELL3 detector over ~40 days to produce 26 resulting spectra. Over 10 half-life ( $T_{1/2}$ ) occurred over the counting period. The  $T_{1/2}$  was obtained for each relevant gamma ray energy line and compared against the National Nuclear Data Center's Evaluated Nuclear Structured Data File (ENSDF) value available. A comparison of relevant nuclear data was performed between the measured and simulated spectra of Mo-99. The peak area of the measured spectrum and bin counts of the simulated spectrum were compared as peak ratios to analyze the accuracy of the benchmarked detector model. An analysis of the true-coincidence summing (TCS) corrections was performed, based upon measuring geometry, detector dimensions and the decay scheme of the radioactive isotope.

### Initial WELL3 Detector Model

Once the input script to the detector modeling software was complete with detector measurements and required nuclear data of the calibration isotopes, it was then modeled to produce a representation of the measured spectrum. Iterative comparisons between the overall detection efficiency of the measurement and simulated detector models were performed to find an optimized representation of the detection system. Model estimates derived from the manufacturer specification sheet, detailed in *Appendix B*, indicated the detector model was inadequate since the overall detection efficiency did not match between the simulated and the measured data. The calibration and characterization of the detector model was not complete, therefore multiple iterations with adjustments to detector dimensions were performed using GEANT4 with G4CSC.

### Benchmarked WELL3 Detector Model

The creation of a benchmarked detector model required adjustments to the can gap, dead layer thickness and sample placement from educated predictions for the detector response. The process method described previously to produce the detector model response of the calibration sample was performed. A comparison between the overall detection efficiency of the measured and simulated detector model was performed. The analysis indicated the initial detector model under-estimated the inner dead-layer thickness and sample positioning. After making several adjustments the model was effectively benchmarked by demonstrating good agreement between the measured detector efficiency and simulation. The WELL3 detector was deemed effectively characterized through this comparison and was then used in the analysis of the Mo-99 radioactive isotope.

### Mo-99 Comparison Analysis

A single-isotope gamma standard of Mo-99 was obtained from the National Physical Laboratory and counted on the WELL3 detector at PNNL. The sample was counted for approximately 40 days, where over 10  $T_{1/2}$  occurred during that period. The sample counting resulted in 26 spectra which were analyzed using the Mirion Genie2000 software. The measured spectrum of Mo-99 was also generated using the benchmarked detector model for comparison to the measured results. The peak area of the measured spectrum and bin counts of the simulated spectrum were compared as peak ratios to analyze the accuracy of the benchmarked detector model. The inter-comparison of the peak ratios showed adequate agreement. The predicted true-

coincidence summing corrections for Mo-99 counting derived from the benchmarked model show large corrections were necessary to accurately quantify Mo-99 using a well-type HPGe detector as expected.

### **T<sub>1/2</sub> Analysis of Mo-99**

An analysis of T<sub>1/2</sub> was performed for the mixed gamma sample of Mo-99 using the WELL3 detector at PNNL. The sample was counted for ~40 days, where over 10 T<sub>1/2</sub> occurred during that period. The sample counting resulted in 26 spectra which were analyzed using the Mirion Genie2000 software, with regions of interest from ~40keV to ~1200keV. The Genie2000 software was used for peak analysis of all single and complex spectral features. After the peak fitting was complete, the T<sub>1/2</sub> at each significant gamma ray energy line was calculated. Overall, the disadvantages of peak summing in the WELL3 detector make it less than ideal for the measurement of Mo-99, nevertheless, the T<sub>1/2</sub> isotope was accurately measured and agreed well with the known published value while also serving as an excellent test reference for the consistency performance of the WELL3 detector at PNNL.

### **Conclusion**

The characterization of the WELL3 detector was performed with a mixed gamma standard and a single-isotope standard of Mo-99. To calibrate the WELL3 detector, a benchmarked model was created using GEANT4 and G4CSC. Future work will encompass further optimization of the calibrated detector model on GEANT4 with G4CSC. The current characterization of the WELL3 detector shows promise for the counting of Tb-161 an important nuclide for emerging medical physics studies. Overall, the characterization of the WELL3 detector at PNNL now provides the ARES team a new capability for the high efficiency counting of weak radioisotopes.

## **ACKNOWLEDGEMENTS**

I would like to thank PNNL for the opportunity to use their laboratories and technologies and work alongside other researchers. A special thanks to Dr. Bruce Pierson for his support, guidance, and mentorship in performing radiation detection and measurement studies, as well as Ms. April Augustine for an enriching program. I would also like to acknowledge and thank DTRA for sponsoring my project and giving me this opportunity. Finally, I would like to extend my gratitude to WPI for this unique opportunity and to Professor Stephen Kmiotek for his unwavering support and all the subsequent work he has undertaken to make this project site a success.



# **WPI**



## **NOMENCLATURE**

ARES – Advanced Radio-Emission Spectroscopy

CERN C++ - Analyzing petabytes of data, scientifically for high energy physics

ENSDF – Evaluated Nuclear Structured Data File

GEANT4 with G4CSC - Toolkit for the simulation of the passage of particles through matter

HPGe – High Purity Germanium

keV – kiloelectronvolts

Mo-99 – Molybdenum-99

NIST - National Institute of Standards and Technology

PNNL – Pacific Northwest National Laboratory

ROI – Region of Interest

sec – seconds

TCS – True Coincidence Summing

# TABLE OF CONTENTS

<b>ABSTRACT</b> .....	II
<b>SUMMARY</b> .....	III
Introduction .....	III
Experimental Description.....	III
Initial WELL3 Detector Model .....	IV
Benchmarked WELL3 Detector Model .....	IV
Mo-99 Comparison Analysis .....	IV
T <sub>1/2</sub> Analysis of Mo-99 .....	V
Conclusion.....	V
<b>ACKNOWLEDGEMENTS</b> .....	VI
<b>NOMENCLATURE</b> .....	VII
<b>1.0 INTRODUCTION</b> .....	1
<b>2.0 EXPERIMENTAL DESCRIPTION</b> .....	2
<b>3.0 INITIAL WELL3 DETECTOR MODEL</b> .....	3
3.1 GEANT4 Modeling with G4CSC Response.....	3
3.2 Comparison of Measured vs. Simulated Response .....	4
<b>4.0 BENCHMARKED WELL3 DETECTOR MODEL</b> .....	6
4.1 GEANT4 Modeling with G4CSC Response.....	6
4.2 Comparison of Measured vs. Simulated Response .....	7
<b>5.0 MO-99 COMPARISON ANALYSIS</b> .....	9
5.1 Mo-99 Counted on WELL3 .....	9
5.2 Mo-99 Simulated Response on Benchmark Model.....	9
5.3 Comparison of Mo-99 Measured vs. Simulated Response .....	10
<b>6.0 T<sub>1/2</sub> Analysis of Mo-99</b> .....	12
<b>7.0 CONCLUSION</b> .....	14
<b>APPENDICES</b> .....	15
Appendix A – Counted Samples .....	15

Appendix B – Canberra Specification Sheet..... 16  
Appendix C – WELL3 Detector..... 17  
Appendix D – GEANT4 with G4CSC Script File ..... 18  
Appendix E -  $T_{1/2}$  Raw Data Calculations ..... 20

## TABLE OF FIGURES


Figure 1. General model of a HPGe Well-type detector.....	1
Figure 2. Initial WELL3 detector model with GEANT4.....	3
Figure 3. Initial simulated gamma-ray energy line spectrum of calibration sample from CERN C++ .....	4
Figure 4. Overall Detection Efficiency vs. Energy (keV) .....	5
Figure 5. $\ln \ln(\text{Overall Detection Efficiency})$ vs. Energy (keV).....	5
Figure 6. Benchmarked WELL3 detector modeled with GEANT4 .....	6
Figure 7. Benchmarked simulated gamma-ray energy line spectrum of calibration sample from CERN C++.....	7
Figure 8. Overall Detection Efficiency vs. Energy (keV) .....	8
Figure 9. $\ln \ln(\text{Overall Detection Efficiency})$ vs. Energy (keV).....	8
Figure 10. A spectrum the first count of Mo-99 from WELL3, displayed by Genie2000 .....	9
Figure 11. A simulated spectrum of Mo-99 produced with the benchmarked model, displayed by CERN C++.....	10
Figure 12. T1/2 comparisons with the corresponding gamma ray energy lines .....	13

## **TABLE OF TABLES**

Table 1. Comparison of measured and simulated peak ratio to the main gamma ray energy line at 739.5 keV .....	11
Table 2. Measured activity from Mo-99 detector model response with TCS corrections .....	12

## 1.0 INTRODUCTION

A high purity germanium (HPGe) detector provides a researcher with reliable information to accurately identify radioactive isotopes based on passive gamma ray emissions from the decay scheme. A HPGe detector requires the sample to be placed on top, while a well-type HPGe detector has the capability to place samples inside the detector. This distinct characteristic results in high detection efficiency for the activity measurement of gamma ray emissions from the decay scheme of a radioactive isotope sample. A well-type detector can be considered one of the more sensitive forms of an HPGe detector since it is capable of achieving very high counting efficiency.



*Figure 1. General model of a HPGe Well-type detector<sup>3</sup>*

The characterization of the WELL3 detector, a well-type detector, at PNNL is important to provide the capability and usability of a well-type detector for samples. The Advanced Radio-Emission Spectroscopy (ARES) team at Pacific Northwest National Laboratory (PNNL) wants to maintain a broad range of detectors to measure relevant radioactive isotopes. The ability to detect low- and high-activity samples is needed by the Advanced Radio-Emission Spectroscopy (ARES) team to support research & development at PNNL. However, a disadvantage to the WELL3 detector is that it is most difficult to use for quantitative analysis due to complex detector physics effects induced by nested nuclear decay chains. This type of analysis is a technique that uses

<sup>3</sup> Carvalho Conti, C. (n.d.). *Schematic figure of HPGE well detector cross section*. Research Gate. Retrieved July 18, 2022, from [https://researchgate.net/figure/Schematic-figure-of-HPGe-well-detector-cross-section\\_fig1\\_265109579](https://researchgate.net/figure/Schematic-figure-of-HPGe-well-detector-cross-section_fig1_265109579)

mathematical and statistical modeling, measurement, and research to understand the behavior of the samples. Overall, the characterization of the WELL3 detector at PNNL provides the ARES team with another detector to analyze and obtain data for weak samples.

## **2.0 EXPERIMENTAL DESCRIPTION**

A calibration sample was obtained to start the characterization process of the WELL3 detector. A National Institute of Standards and Technology (NIST) traceable standard was obtained. The ARES team created a secondary standard derived from the primary standard mixture received from the Eckert & Zeigler. Production of internal secondary standards at PNNL is facilitated by the Analytical Support Operations service center which maintains a HASQARD compliant quality assurance program. The calibration sample was then counted on the WELL3 detector.

A benchmarked calibrated and characterized model of the WELL3 detector was created using GEANT4 modeling software. The process was based on creating an optimized detector model starting from the detector vendor specification sheet from the manufacturer, detailed in *Appendix B*, and physical measurements taken in the lab. Once all required measurements were obtained, it was applied to the model. The detector and calibration source model were created to predict the spectral response of the instrument for comparison to measurements. The detector spectral response was predicted for each isotope in the standard and combined using the data analysis framework CERN C++. The combined simulated spectrum and efficiency were used to evaluate the accuracy of the model.

A single nuclide gamma standard of Molybdenum-99 (Mo-99) was counted on the WELL3 detector over approximately 40 days to produce 26 spectra. Over 10 half-lives ( $T_{1/2}$ ) occurred during the counting period. Each spectrum was analyzed using Mirion's Genie2000 software for peak fitting of the relevant gamma ray energy lines produced by the sample. The  $T_{1/2}$  was obtained for each relevant gamma ray energy lines and compared against the Evaluated Nuclear Structured Data File (ENSDF) value.


A comparison of relevant nuclear data was performed between the measured and simulated spectra of Mo-99. The peak area of the measured spectrum and bin counts of the simulated spectrum were compared as peak ratios to analyze the accuracy of the benchmarked detector

model. An analysis of the true-coincidence summing (TCS) corrections was also performed based upon measuring geometry, detector dimensions, and the decay scheme of the radioactive isotope. TCS occurs when two or more photons are emitted from the decay scheme from the same decay of the radioactive isotope and subsequently detected simultaneously within the resolving time of the detector. This phenomenon occurs prolifically within well-type HPGe detectors and required to correct measurement data from such instruments.

### **3.0 INITIAL WELL3 DETECTOR MODEL**

#### **3.1 GEANT4 Modeling with G4CSC Response**


The data required for the GEANT4 script input included the detector type, detector name, position in space (x, y, and z coordinates), rotation in space ( $\phi$  and  $\theta$ ), hole depth, hole diameter, inner dead layer, outer dead layer, detector diameter, detector length, detector bevel radius, detector can gap, can thickness, can diameter, can material, and manufacturer. The script required the measurements and characteristics of the sample as well – sample name, position in space, rotation in space, source diameter, container diameter, container base thickness, source height, source material, and container material. Once the input script was complete, it was then run with the GEANT4 software to produce the initial detector model.



*Figure 2. Initial WELL3 detector model with GEANT4*

An input script that contained the relevant nuclear data of the 12 radioactive isotopes in the calibration sample was used to estimate the detector response. The contents of this standard

included Co-60, Pb-210, Am-241, Te-123m, Cd-109, Co57, Sn-113, Sr-85, Mn-54, Y-88, Zn-65, and Cs-137. After the script was run through the appropriate software, individual spectra of each calibration isotope were produced. For each spectrum, the gamma ray energy line with the largest bin count was extracted and scaled appropriately into a resulting spectrum of the calibration sample utilizing CERN C++. The scaling was based upon the ratio of the bin count in the simulated spectrum to the peak area in the measured calibration sample spectrum. The process was done for each of the 12 radioactive isotopes of the calibration sample.



*Figure 3. Initial simulated gamma-ray energy line spectrum of calibration sample from CERN C++*

### 3.2 Comparison of Measured vs. Simulated Response

A comparison between the overall detection efficiency of the measured model and simulated detector model was performed. The appropriate files which provided the overall detection efficiency at the relevant gamma ray energy lines were obtained for analysis. A scatter plot was created in Excel<sup>®</sup> to show the overlapping of the measured and simulated response.




Figure 4. Overall Detection Efficiency vs. Energy (keV)




Figure 5.  $\ln \ln(\text{Overall Detection Efficiency})$  vs. Energy (keV)


The scatter plots indicate the detector model was inadequate since the overall detection efficiency did not match between the simulated and the measured data. The two data sets show minimal overlapping further verifying the previous statement. The calibration and characterization of the

detector model required multiple iterations with adjustments to multiple detector dimensions to obtain good agreement between the modeled and measured efficiency.

## **4.0 BENCHMARKED WELL3 DETECTOR MODEL**


### **4.1 GEANT4 Modeling with G4CSC Response**

The creation of a benchmarked detector model required adjustments to the can gap, dead layer thickness and sample placement using expert judgement and additional measurements. A thicker dead layer and an increased sample placement height was the result to create the benchmarked detector model. The dead layer thickness and can gap were unknown since they were measurements not initially recorded when the WELL3 detector was made. The sample placement needed educated predictions since the sample is placed in a plastic bag when inserted into the detector hole. The plastic bag creates uncertainty to where the sample is placed inside the hole. The benchmarked dimensions of the detector model were inputted into the script and run using GEANT4 with G4CSC to produce the calibration sample response.



*Figure 6. Benchmarking WELL3 detector modeled with GEANT4*

The process method described above in *Section 3.1* to create the resulting spectrum of the calibration sample from the benchmarked model utilizing CERN C++ was repeated.



*Figure 7. Benchmarked simulated gamma-ray energy line spectrum of calibration sample from CERN  
C++*

#### 4.2 Comparison of Measured vs. Simulated Response

A comparison between the overall detection efficiency of the measured model and simulated detector model was performed. The appropriate files which provided the overall detection efficiency at the relevant gamma ray energy lines were obtained for analysis. A scatter plot was created in Excel<sup>®</sup> to show the overlapping of the measured and simulated response.




Figure 8. Overall Detection Efficiency vs. Energy (keV)





Figure 9.  $\ln \ln(\text{Overall Detection Efficiency})$  vs. Energy (keV)

The scatter plots indicate the detector model was effectively benchmarked based on the good comparison between the overall detector efficiency of the measured and simulated data. The WELL3 detector was deemed effectively characterized through this comparison and validation was performed using as separate set of metrics and a different source.

## 5.0 MO-99 COMPARISON ANALYSIS

### 5.1 Mo-99 Counted on WELL3

A single nuclide gamma standard of Mo-99 was obtained to be counted on the WELL3 detector at PNNL. The sample was counted for approximately 40 days, where over 10  $T_{1/2}$  occurred during that period. The sample counting resulted in 26 spectra which were analyzed using the Mirion Genie2000 software, with regions of interest (ROI) spanning ~40keV to ~1200keV.




*Figure 10. A spectrum the first count of Mo-99 from WELL3, displayed by the Mirion Genie2000*

A simulated response of Mo-99 on the benchmarked detector was obtained using the input script described in *Section 4.1*, including the required nuclear data of Mo-99. A simulated response with TCS corrections was produced using GEANT4 with G4CSC.

### 5.2 Mo-99 Simulated Response on Benchmarked Model

A simulated response of Mo-99 on the benchmarked detector was obtained using the input script described in *Section 4.1*, including the required nuclear data of Mo-99. A simulated response with TCS corrections was produced using GEANT4 with G4CSC.



*Figure 11. A simulated spectrum of Mo-99 produced with the benchmarked model, displayed by CERN C++*

### 5.3 Comparison of Mo-99 Measured vs. Simulated Response

The comparison required obtaining data from measured counts of Mo-99 on WELL3 and the simulated response of Mo-99 on the benchmarked model. For an in-depth analysis, measured counts of Mo-99 had to meet the following requirements – contained all the significant gamma ray energy lines and was chosen at different times of counting. The spectrum of counts 1, 2, 3 and 12 were compared against the simulated Mo-99 response, using a peak ratio comparison.

The peak area of the measured spectrum and bin counts of the simulated spectrum were compared as peak ratios to analyze the accuracy of the benchmarked detector model. To compare the peak ratios, the peak areas/bin counts of interest corresponded to the following gamma ray energy lines: 40.52, 181.1, 366.5, 528.6, 739.5, 778.1, 880.0, and 920.6 keV. The 739.5 keV gamma ray energy line was used for reference during the calculation of the peak ratios for each spectrum of interest, referenced in the equation below.

$$peak\ ratio = \frac{count_n}{count_{739.5keV}} [1]$$

*Table 1. Comparison of measured and simulated peak ratio to the main gamma ray energy line at 739.5 keV*

		40.52	181.1	366.5	528.6	739.5	778.1	880.0	920.6	1004.0
<b><i>Gamma Ray Energy Line (keV)</i></b>										
<b><i>1</i></b>	-	0.2450	0.4105	0.5723	0.01928	1*	1.036	0.4760	0.7280	0.00796
<b><i>2</i></b>	-	0.2280	0.3950	0.5750	0.01870	1*	0.9770	0.4400	0.6720	0.00793
<b><i>3</i></b>	-	0.2250	0.3840	0.5570	0.01940	1*	0.9810	0.4500	0.6990	0.00737
<b><i>12</i></b>	-	0.2240	0.3830	0.5640	0.02020	1	0.9940	0.4570	0.6990	0.00710
<b><i>Sim.</i></b>	-	0.1370	0.3949	0.5941	0.01803	1*	1.034	0.6341	0.8604	0.00830

An analysis of the calculated peak ratios showed adequate agreement for the most intense gamma-ray emissions, but some discrepancy was observed for the more uncertain gamma-lines (880, 920.6, and 1004 keV). A clear discrepancy at 40.52 keV is likely the by-product of errors in the model dead-layer but could possibly point to issues in the decay feeding of this gamma-line.

The final analysis between the simulated response of Mo-99 was based on the TSC corrections obtained from the data file produced from GEANT4 with G4CSC.

*Table 2. Measured activity from Mo-99 detector model response with TCS corrections*


<i>Gamma Ray Energy Line (keV)</i>	<i>TCS Corrections</i>
40.47	0.1137
140.4	0.3664
158.8	0.1765
181.1	0.3669
366.4	0.9862
528.6	1.074
739.6	0.2339
778.0	1.002

The analysis of the TCS corrections of the Mo-99 response from the benchmarked model show large corrections were made to simulate the spectrum from Mo-99 on WELL3. If the TCS corrections were small, the numbers would be closer to 1, indicating less corrections were done. However, most gamma ray energy lines show a large TCS correction factor. For low energy samples in combination with another photon, the TCS corrections are more pronounced for a detector that has a high efficiency for low energy photons, like a well-type detector. If TCS corrections were not corrected for, the activity of the sample could be over- or underestimated.

## **6.0 $T_{1/2}$ Analysis of Mo-99**

An analysis of  $T_{1/2}$  was performed for the mixed gamma sample of Mo-99 using the WELL3 detector at PNNL. The sample was counted for approximately 40 days, where over 10  $T_{1/2}$  occurred during that period. Peak fitting required careful analysis of the spectral features in the Mo-99 spectra. The insignificant peaks that did not match criteria were had to be removed as well. To further improve peak fitting, some ROIs of the peaks were adjusted to the correct region for the peak. The technique was used to clean up the inconsistency of the peaks in the spectrum due to the complexity and overlap in the spectrum from TCS effects. Another factor that contributed to complex peaks was peak summing, a phenomenon that occurs when only one detector is used; the detector will sum together two peaks to create random “sum peaks.”

After the peak fitting was complete, the  $T_{1/2}$  at each significant gamma ray energy line was calculated. The following data was needed from each count to perform the  $T_{1/2}$  calculation: energy (keV), net peak area, realtime (sec), livetime (sec), and the time difference based on the initial count. The data needed to be analyzed for each count to ensure the proper net peak area was chosen for the corresponding gamma line.



*Figure 12.  $T_{1/2}$  comparisons with the corresponding gamma ray energy lines*

The ENDF value, 65.924 hours, is shown on the graph which compares well to the  $T_{1/2}$  calculated at 142 keV. The  $T_{1/2}$  obtained at 142 keV, 65.990 +/- 0.0733 hours, shows comparability to the ENDF value, verified by the smallest standard deviation, which is within  $1\sigma$  of the ENDF value. The average  $T_{1/2}$  calculated for the significant gamma ray energy lines compares relatively well to the ENDF value at 65.888 +/- 0.246 hours. Overall, given the disadvantages of peak summing in the WELL3 detector it is not ideally suited for measuring the Mo-99 but the performance of the instrument over this protracted count period served as a test of the consistent reliable operation of this instrument.

## 7.0 CONCLUSION

The characterization of the WELL3 detector was performed with a mixed gamma standard of Mo-99. To calibrate the WELL3 detector, a benchmarked model was created using GEANT4 with G4CSC. The benchmarked model required adjustments of the can gap, increased dead layer thickness, and higher sample placement through educated predictions of the detector model response. A relevant piece of nuclear data for Mo-99 obtained by WELL3 was the  $T_{1/2}$  analysis. It was an adequate detector for the analysis however the variation can be attributed to the counting statistics and the peak fitting uncertainty.

The future work will encompass further optimization of the calibrated detector model on GEANT4 with G4CSC. This will require more iterations of educated predictions of the sample placement and crystal size. The current characterization of the WELL3 detector shows promise for the counting of Tb-161 which is a relevant nuclide to nuclear forensics and medical physics. The nuclide is also an important fission product for estimating the total fissions in experimental samples. Overall, the characterization of the WELL3 detector at PNNL now provides the ARES team a new capability for the high efficiency counting of weak samples, a capability not initially available.

## APPENDICIES

### Appendix A – Counted Samples



*Mo-99 Sample*

*Calibration Sample*

# Appendix B – Canberra Specification Sheet



*Replaces Orscot Det WELL3  
New Det 3*

Rev. 6/15/99

## DETECTOR SPECIFICATION AND PERFORMANCE DATA

### Specifications

DETECTOR MODEL GCW3523S SERIAL NUMBER 11051527  
 CRYOSTAT MODEL 7500SL/RDC/ULB PREAMPLIFIER MODEL 2002CSL

The purchase specifications, and therefore the warranted performance, of this detector are as follows:  
 (Electric cooling may degrade performance by as much as 10%.)

Active Volume          cc Relative Efficiency 35 %  
 Resolution ≤ 2.0 keV (FWHM) at 1.33 MeV  
≤ 1.4 keV (FWHM) at 1.33 MeV  
         keV (FWHM) at 122KeV  
         keV (FWHM) at         

Peak/Compton          Cryostat well diameter 14.5 mm Cryostat well depth 40 mm

Cryostat description (if special) 3.25" Ø End Cap, 4" long RDC and Vertical Slimline dipstick cryostat and Ultra low Background cryostat hardware.

### Physical Characteristics

Geometry Closed-end coaxial well  
 Diameter 61.5 mm Active Volume          cc  
 Length 63 mm Well Depth 40.586 mm 1.590"  
 Distance from window 10 mm Well Diameter 14.1478 mm 0.557"

### Electrical Characteristics

Depletion voltage (+2600) V dc  
 Recommended bias voltage (+3000) V dc  
 Test point voltage at recommended bias (-)0.81 V dc (RC preamp only)  
 Reset interval at recommended bias          sec. (Reset preamp only)  
 Capacitance at recommended bias -43 pF

### Resolution and Efficiency

With amp time constant of 6 microseconds

Isotope	<sup>57</sup> Co	<sup>60</sup> Co			
Energy (keV)	122	1332			
FWHM (keV)	1.25	2.00			
FWTM (keV)	2.27	3.69			
Peak/Compton		50.9:1			
Rel. Efficiency %		35.3			


Cool Down Time 8 hours. Cryostat Liquid Nitrogen Consumption Rate <1.8 Liters per Day.

Tested by: Stephen Bishop Date: 11/23/05

Approved by: Wesley Moss Date: 11/23/05

800 Research Parkway, Meriden, CT USA 06450 • Tel. 203-238-2351/Fax. 203-639-2420

Appendix C – WELL3 Detector



*WELL detector*



*Standard in WELL detector*

## Appendix D – GEANT4 with G4CSC Script File

```
Open user.mac
-Applications/g4csc-build
Save

1 # -----
2 # ***** SOURCE SELECTION *****
3 # -----
4 # DL=deadlayer
5 # -----
6 /vis/multithreading/actionOnEventQueueFull discard
7
8
9
10
11 #
12 #/g4csc/src/cylindricalshape <name> <x> <y> <z> <phi> <theta> <source_dia> <container_dia> <container_base_thickness> <source_height> <source_material>
13 <container_material>
14 /g4csc/src/cylindricalshape p0psv2mlw 0 0 28 0 0 9.627 11. 0.762 30. G4_WATER G4_POLYETHYLENE
15 # -----
16 # ***** DETECTOR SELECTION *****
17 # -----
18 # DL=deadlayer D,K, is PGT (bevel both sides)
19 # -----
20 #####/g4csc/det/detectorshape <type> <name> <x> <y> <z> <phi> <theta> <hole depth> <hole dia> <inner DL> <outer DL> <detector dia> <detector length> <detector bevel radius>
21 <detector can gap> <can thickness> <can dia> <can material> <manuf.>
22 /g4csc/det/detectorshape Well WELL3 0 0 0 180 0 40.37 14.15 0.0003 0.7 61.5 63.
23 1.5 2. 1.0 100 G4_Al canberra
24 # -----
25 # ***** ISOTOPE SELECTION *****
26 # ***** PARTICLE HISTORIES *****
27 # CERN root histogram definitions used for output of spectrum predictions
28 # -----
29 /gun/particle ion
30
31 ##Co-60
32 /g4csc/gun/target co60 1 86400. 27 60 0. 1
33 /run/beamOn 1000000
34
35 ##Pb-210
36 /g4csc/gun/target pb210 1 86400. 82 210 0. 1
37 /run/beamOn 1000000
38
39 ##Am-241
40 /g4csc/gun/target am241 1 86400. 95 241 0. 1
41 /run/beamOn 1000000
42
43 ##Te-123m
44 /g4csc/gun/target te123m 1 86400. 52 123 247.5 1
45 /run/beamOn 1000000
46
47 ##Cd-109m
48 /g4csc/gun/target cd109 1 86400. 48 109 462.7 1
49 /run/beamOn 1000000
50
51 ##Co-57
52 /g4csc/gun/target co57 1 86400. 27 57 0. 1
53 /run/beamOn 1000000
54
55 ##In-113m
56 /g4csc/gun/target sn113 1 86400. 49 113 391.7 1
57 /run/beamOn 1000000
```

```



58
59 ##Sn-113
60 /g4csc/gun/target sn113 1 86400. 50 113 0. 1
61 /run/beamOn 1000000
62
63 ##Sr-85
64 /g4csc/gun/target sr85 1 86400. 38 85 0. 1
65 /run/beamOn 1000000
66
67 ##Mn-54
68 /g4csc/gun/target mn54 1 86400. 25 54 0. 1
69 /run/beamOn 1000000
70
71 ##Y-88
72 /g4csc/gun/target y88 1 86400. 39 88 0. 1
73 /run/beamOn 1000000
74
75 ##Zn-65
76 /g4csc/gun/target zn65 1 86400. 30 65 0. 1
77 /run/beamOn 1000000
78
79 ##Ba-137m
80 /g4csc/gun/target ba137m 1 86400. 56 137 661.7 1
81 /run/beamOn 1000000
82
83 # -----
84 # ***** COLORING *****
85 # -----
86 # visualization commands used to setup the coloring.
87 # -----
88 # Set visibility of logical volumes
89 /vis/drawVolume
90 /vis/geometry/set/visibility World 0 false
91 /vis/geometry/set/visibility active_Ge_logical 1 true
92 /vis/geometry/set/visibility cu_coldfinger_logical 1 true
93 /vis/geometry/set/visibility inner_deadlayer_logical 1 true
94 /vis/geometry/set/visibility outer_deadlayer_logical 1 true
95 /vis/geometry/set/visibility Ge_can_logical 1 true
96 /vis/geometry/set/visibility lead_annulus_logical 1 true
97 /vis/geometry/set/visibility G4_Fe_inner_cover_1_logical 1 true
98 /vis/geometry/set/visibility G4_Cu_inner_cover_2_logical 1 true
99 /vis/geometry/set/visibility sample_logical 1 true
100 /vis/geometry/set/visibility sample_holder_logical 1 true
101
102 # Set color of logical volumes: surface view
103 /vis/vviewer/set/style surface
104 /vis/geometry/set/colour World 0 0.95 0.95 0.95 1
105 /vis/geometry/set/colour active_Ge_logical 1 0.42 0.92 0.99 0.2
106 /vis/geometry/set/colour cu_coldfinger_logical 1 0.99 0.27 0.00 1
107 /vis/geometry/set/colour inner_deadlayer_logical 1 0.50 1.00 0.00 1
108 /vis/geometry/set/colour outer_deadlayer_logical 1 0.99 0.00 0.99 0.2
109 /vis/geometry/set/colour Ge_can_logical 1 0.51 0.51 0.51 0.1
110 /vis/geometry/set/colour lead_annulus_logical 1 0.71 0.71 0.71 0.05
111 /vis/geometry/set/colour G4_Fe_inner_cover_1_logical 1 0.51 0.51 0.51 1
112 /vis/geometry/set/colour G4_Fe_inner_cover_2_logical 1 0.51 0.51 0.51 1
113 /vis/geometry/set/colour G4_Cu_inner_cover_2_logical 1 0.99 0.27 0.00 1
114 /vis/geometry/set/colour sample_logical 1 1.00 0.00 0.00 0.9
115 /vis/geometry/set/colour holder_logical 1 1.00 1.00 1.00 0.2
116 /vis/geometry/set/colour window_logical 1 1.00 1.00 0.00 0.1
117
118 # Set color of logical volumes: wireframe w/ cut plane view
119 /vis/vviewer/set/style wireframe
120 /vis/geometry/set/colour World 0 0.95 0.95 0.95 1
121 /vis/geometry/set/colour active_Ge_logical 1 0.42 0.92 0.99 1
122 /vis/geometry/set/colour cu_coldfinger_logical 1 0.99 0.27 0.00 1
123 /vis/geometry/set/colour inner_deadlayer_logical 1 0.50 1.00 0.00 1
124 /vis/geometry/set/colour outer_deadlayer_logical 1 0.99 0.00 0.99 1
125 /vis/geometry/set/colour Ge_can_logical 1 0.51 0.51 0.51 1
126 /vis/geometry/set/colour lead_annulus_logical 1 0.71 0.71 0.71 1
127 /vis/geometry/set/colour G4_Fe_inner_cover_1_logical 1 0.51 0.51 0.51 1
128 /vis/geometry/set/colour G4_Cu_inner_cover_2_logical 1 0.99 0.27 0.00 1
129 /vis/geometry/set/colour sample_logical 1 1.00 0.00 0.00 1
130 /vis/geometry/set/colour sample_holder_logical 1 1.00 1.00 1.00 1
131 /vis/enable
132 /vis/vviewer/refresh

```

# Appendix E - T<sub>1/2</sub> Raw Data Calculations


Note – All rows with cells highlighted in RED are omitted from calculations

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select												
2	Count	Count Start Date/Time	Time Diff. (days)	Realttime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit							
3	1	5/25/2022 19:25	0	72870.9	62850.9	796700	12.67603169			2.539712942			0	2.539713		-2.5396E-01	2.5298E+00
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	647500	9.992283951			2.30181319			0.852928	2.301813		5.2059E-04	6.6737E-03
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	527900	8.146604938			2.097601268			1.715266	2.097601		9.9996E-01	1.4519E-02
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	506300							4.963646	1.280108		2.3797E+05	1.0000E+01
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	400100							5.918623	1.012022			
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	284700	3.597026862			1.280107633			6.971887	0.750498		Half-life (hrs)	65.5056
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	237700	2.751157407			1.012021699			8.615266	0.333492		+/.	0.1340
10	8	6/1/2022 18:44	6.971886574	88584	86400	183000	2.118055556			0.750498477			12.86723	-0.73885			
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	120600	1.395833333			0.333491608			13.91772	-0.98032			
12	10	6/4/2022 14:49	9.8084375	87463	86400	93500							14.9169	-1.2472			
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	41270	0.477662037			-0.738851832			22.91881	-3.31476			
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	23290	0.375189488			-0.98032408			26.05416	-4.07782			
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	18740	0.287308742			-1.247197886							
16	14	6/10/2022	15.84828704	86639.7	86400	1464				0.016944							
17	15	6/11/2022 16:59	16.89908565	86590.7	86400												
18	16	6/13/2022 11:12	18.65796296	14087.3	14087.3	5663				0.402748							
19	17	6/14/2022 16:20	19.8721412	86518.9	86400												
20	18	6/15/2022 16:59	20.88989306	86499.8	86400												
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	3140	0.036342593			-3.314764876							
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	1464	0.016944444			-4.07781526							
23	21	6/22/2022 15:06	27.82043981	86447.2	86400												
24	22	6/24/2022 17:06	29.90413194	86440.8	86400												
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9								0	140.4276		4.944692	
26	24	6/29/2022 16:15	34.86866898	86436.7	86400								0.852928	109.6914		4.697671	
27	25	6/30/2022 16:49	35.89172454	86434.2	86400								1.715266	88.65741		4.48478	
28	26	7/5/2022 18:17	40.95304398	86418.8	86400								2.853669				
29													3.914236	59.93765		4.093305	
30													4.963646	45.74933		3.823177	
31													5.918623	30.16204		3.406584	
32													6.971887	27.31481		3.307429	
33													8.615266	16.99074		2.832669	
34													9.808437	13.19444		2.579796	
35													12.86723	5.409722		1.688198	
36													13.91772	4.251288		1.447222	
37													14.9169	3.333027		1.203881	
38													15.84829				
39													16.89909				
40													18.65796				
41													19.87214				
42													20.89899				
43													22.91881	0.430208		-0.84349	
44													26.05416	0.190278		-1.65927	





Gamma ray energy line 42 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select	142											
2	Count	Count Start Date/Time	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit							
3	1	5/25/2022 19:25		0	72870.9	62850.9	370900000	5901.267921		8.682922509			0	8.682923		-2.5209E-01	8.6552E+00
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	302700000	4671.296296			8.449191892			0.852928	8.449192		2.8048E-04	5.9763E-03
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	243800000	3762.345679			8.232797893			1.715266	8.232798		9.9998E-01	1.6380E-02
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	234100000			2738.636				3.914236	7.648181		8.0783E+05	1.8000E+01
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	180200000				7.648181391			4.963646	7.394688			
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	128800000			2096.828808	7.394687731			5.918623	7.142864		Half-life (hrs)	65.9899
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	109300000			1627.316684	7.142863998			6.971887	6.878393		+/.	0.0733
10	8	6/1/2022 18:44	6.971886574	88584	86400	83900000			1265.046296	6.878393217			8.615266	6.46461			
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	55470000			642.0138889	6.464609937			9.808437	6.16234			
12	10	6/4/2022 14:49	9.8084375	87463	86400	41000000			474.537037	6.16233967			12.86723	5.417129			
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	19460000			225.2314815	5.41712868			13.91772	5.173659			
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	10960000			176.5597589	5.173659396			14.9169	4.925787			
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	8988000			137.7978107	4.925787471			22.91881	2.88055			
16	14	6/10/2022 15:46	15.84828704	86639.7	86400	6994000							26.05416	2.091235			
17	15	6/11/2022 16:59	16.89908565	86590.7	86400	#REF!			8.094907	#REF!			27.82044	1.644242			
18	16	6/13/2022 11:12	18.65796296	14087.3	14060.9	804400			57.20829				29.90413	1.118475			
19	17	6/14/2022 16:20	19.8721412	86518.9	86400	#REF!							33.87206	0.113904			
20	18	6/15/2022 16:59	20.89899306	86499.8	86400	#REF!							34.86867	-0.14083			
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	1540000			17.82407407	2.88055002			35.89172	-0.39923			
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	699400			8.094907407	2.091235149			40.95304	-1.66844			
23	21	6/22/2022 15:06	27.82043981	86447.2	86400	447300			5.177083333	1.644241835							
24	22	6/24/2022 17:06	29.90413194	86440.8	86400	264400			3.060185185	1.118475432							
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9	95360			1.120644371	0.113903851							
26	24	6/29/2022 16:15	34.86866898	86436.7	86400	75050			0.868634259	-0.140833118							
27	25	6/30/2022 16:49	35.89172454	86434.2	86400	57960			0.670833333	-0.399234558							
28	26	7/5/2022 18:17	40.95304398	86418.8	86400	16290			0.188541667	-1.668436253							




Gamma ray energy line 142 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	
	Count	Count Start Date/Tim	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit								
2	1	5/25/2022 19:25		0	72870.9	62850.9	996900	15.86134805		2.763885209			0	2.763885		-2.5367E-01	#####	
3	2	5/26/2022 15:53	0.852928241	72838.1	64800	805100	12.42438272			2.51966089			0.852928	2.519661		1.5306E-03	1.6213E-02	
4	3	5/27/2022 12:34	1.715266204	71216.6	64800	638100	9.847222222			2.287189408			1.715266	2.287189		9.9967E-01	3.4732E-02	
5	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	602300		7.046051					3.914236	1.681057		2.7467E+04	#####	
6	5	5/29/2022 17:21	3.914236111	90627	85939.3	461600	5.371232952			1.681057482			4.963646	1.428067				
7	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	330100	4.170630724			1.428067277			5.918623	1.160688		Half-life (hrs)	65.5805	
8	7	5/31/2022 17:27	5.918622685	89247.6	86400	275800	3.19212963			1.16068829			6.971887	0.896655		+/.	0.3933	
9	8	6/1/2022 18:44	6.971886574	88584	86400	211800	2.451388889			0.896654757			12.86723	-0.54537				
10	9	6/3/2022 10:10	8.615266204	87840.1	86400	137300		1.58912					13.91772	-0.8008				
11	10	6/4/2022 14:49	9.8084375	87463	86400	101000		1.168981					14.9169	-1.05066				
12	11	6/7/2022 16:13	12.8672338	86930.5	86400	50080	0.57962963			-0.545365949			22.91881	-3.10289				
13	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	27870	0.448970847			-0.800797323								
14	13	6/9/2022 17:25	14.91689815	65471.1	65226	22810	0.349707172			-1.050659126								
15	14	6/10/2022	15.84828704	86639.7	86400	1445												
16	15	6/11/2022 16:59	16.89908565	86590.7	86400													
17	16	6/13/2022 11:12	18.65796266	14087.3	14060.9	2293		0.163076										
18	17	6/14/2022 16:20	19.8721412	86518.9	86400													
19	18	6/15/2022 16:59	20.89899306	86499.8	86400													
20	19	6/17/2022 17:28	22.91880787	86469.1	86400	3881		0.044919		-3.102894823								
21	20	6/20/2022 20:42	26.05415509	86451.1	86400	1445		0.016725										
22	21	6/22/2022 15:06	27.82043981	86447.2	86400													
23	22	6/24/2022 17:06	29.90413194	86440.8	86400													
24	23	6/28/2022 16:20	33.87206019	85129.2	85093.9													
25	24	6/29/2022 16:15	34.86866898	86436.7	86400			0	15.86135	2.763885209								
26	25	6/30/2022 16:49	35.89172454	86434.2	86400			0.852928	12.42438	2.51966089								
27	26	7/5/2022 18:17	40.95304398	86418.8	86400			1.715266	9.847222	2.287189408								
28								2.853669										
29								3.914236	5.371233	1.681057482								
30								4.963646	4.170631	1.428067277								
31								5.918623	3.19213	1.16068829								
32								6.971887	2.451389	0.896654757								
33								8.615266	1.58912	0.463180637								
34								9.808437	1.168981	0.156132841								
35								12.86723	0.57963	-0.545365949								
36								13.91772	0.448971	-0.800797323								
37								14.9169	0.349707	-1.050659126								
38								15.84829										
39								16.89909										
40								18.65796	0.163076									
41								19.87214										
42								20.89899										
43								22.91881	0.044919	-3.102894823								
44								26.05416	0.016725									
45																		
46																		
47																		
48																		
49																		
50																		
51																		
52																		
53																		
54																		
55																		
56																		
57																		




Gamma ray energy line 160 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select	182											
2	Count	Count Start Date/Tim	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit							
3	1	5/25/2022 19:25		0	72870.9	62850.9	13340000	212.2483528					0	5.357757		-2.5309E-01	#####
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	11909000	172.6851852			5.15470198			0.852928	5.15147		5.4973E-04	1.1870E-02
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	9009000	139.0277778			4.934673753			1.715266	4.934674		9.9992E-01	3.2085E-02
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	8644000		101.1225					3.914236	4.348731		2.1196E+05	#####
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	6650000	77.38019742			4.348730901			4.963646	4.088236			
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	4720000	59.63458654			4.088235717			5.918623	3.843774		Half-life (hrs)	65.7294
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	4035000	46.70138889			3.843773905			6.971887	3.58017		±/±	0.1425
10	8	6/1/2022 18:44	6.971886574	88584	86400	3100000	35.87962963			3.580169715			8.615266	3.164654			
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	2046000	23.68055556			3.164654271			9.808437	2.864778			
12	10	6/4/2022 14:49	9.8084375	87463	86400	1520000	17.59259259			2.86477938			12.86723	2.10388			
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	708300	8.197916667			2.103880057			13.91772	1.861114			
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	399200	6.430899247			1.86111438			22.91881	-0.42157			
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	328400	5.034802073			1.616374215			26.05416	-1.22266			
16	14	6/10/2022 15:46	15.84828704	86639.7	86400	25440		0.294444					27.82044	-1.67336			
17	15	6/11/2022 16:59	16.89908565	86590.7	86400	#REF!							29.90413	-2.21552			
18	16	6/13/2022 11:12	18.65796296	14087.3	14060.9	29360		2.08806					33.87206	-3.17963			
19	17	6/14/2022 16:20	19.8721412	86518.9	86400	#REF!							34.86867	-3.44339			
20	18	6/15/2022 16:59	20.89899306	86499.8	86400	#REF!							35.89172	-3.68564			
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	56680	0.656018519			-0.421566261			40.95304	-5.11311			
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	25440	0.294444444			-1.222664937							
23	21	6/22/2022 15:06	27.82043981	86447.2	86400	16210	0.187615741			-1.67335934							
24	22	6/24/2022 17:06	29.90413194	86440.8	86400	9426	0.109097222			-2.215515847							
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9	3540	0.041601102			-3.179628625							
26	24	6/29/2022 16:15	34.86866898	86436.7	86400	2761	0.031956019			-3.443394743							
27	25	6/30/2022 16:49	35.89172454	86434.2	86400	2167	0.025801019			-3.685643953							
28	26	7/5/2022 18:17	40.95304398	86418.8	86400	519.9	0.006017361			-5.113106469							




Gamma ray energy line 182 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select	367											
2	Count	Count Start Date/Time	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit							
3	1	5/25/2022 19:25		0	72870.9	62850.9	1860000	29.5938483					0	3.38757		-2.5072E-01	#####
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	1629000	25.13888889			3.224416005			0.852928	3.22442		1.0410E-03	#####
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	1307000		20.1698		3.004184111			1.71527	3.00418		9.9974E-01	#####
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	1258000		14.7168					3.91424	2.42097		5.8009E+04	#####
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	967400	11.2567824			2.420970827			4.96365	2.16565			
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	690200	8.720294837			2.165653049			5.91862	1.91978		Half-life (hrs)	66.3522
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	589200	6.819444444			1.919778009			6.97189	1.65226		±/±	0.2744
10	8	6/1/2022 18:44	6.971886574	88584	86400	450900	5.21875			1.65225791			8.61527	1.23205			
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	296200	3.428240741			1.232047226			9.80844	0.93918			
12	10	6/4/2022 14:49	9.8084375	87463	86400	221000	2.55787037			0.939175026			12.8672	0.18348			
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	103800	1.201388889			0.183478295			13.9177	-0.05523			
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	58740	0.946270095			-0.05527238			14.9169	-0.31021			
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	47830	0.733296538			-0.310205105			18.658	-1.155			
16	14	6/10/2022	15.84828704	86639.7	86400	3747		0.04337					22.9188	-2.30827			
17	15	6/11/2022 16:59	16.89908565	86590.7	86400								26.0542	-3.13803			
18	16	6/13/2022 11:12	18.65796296	14087.3	14060.9	4430	0.315058069			-1.154998312			27.8204	-3.52722			
19	17	6/14/2022 16:20	19.8721412	86518.9	86400								29.9041	-4.16781			
20	18	6/15/2022 16:59	20.89899306	86499.8	86400												
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	8591	0.09943287			-2.308272532							
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	3747	0.043368056			-3.138032156							
23	21	6/22/2022 15:06	27.82043981	86447.2	86400	2539	0.029386574			-3.527217373							
24	22	6/24/2022 17:06	29.90413194	86440.8	86400	1338	0.015486111			-4.167811714							
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9												
26	24	6/29/2022 16:15	34.86866898	86436.7	86400												
27	25	6/30/2022 16:49	35.89172454	86434.2	86400												
28	26	7/5/2022 18:17	40.95304398	86418.8	86400												




Gamma ray energy line 367 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select		528										
2	Count	Count Start Date/Time	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit							
3	1	5/25/2022 19:25	0	72870.9	62850.9	1860000	29.5938483			3.387566512			0	3.38757		-2.5077E-01	#####
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	1629000	25.13888889			3.224416005			0.852928	3.22442		1.2645E-03	#####
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	1307000	20.16975309			3.00418411			1.71527	3.00418		9.9977E-01	#####
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	1258000		14.7168					3.91424	2.42097		3.9331E+04	#####
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	967400	11.2567824			2.420970827			4.96365	2.16565			
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	692000	8.720294837			2.165653049			5.91862	1.91978	Half-life (hrs)	66.3381	
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	589200	6.819444444			1.919778009			6.97189	1.65226	*/-/	0.3328	
10	8	6/1/2022 18:44	6.971886574	88584	86400	450900	5.21875			1.65225791			8.61527	1.23205			
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	296200	3.428240741			1.232047226			9.80844	0.93918			
12	10	6/4/2022 14:49	9.8084375	87463	86400	221000	2.55787037			0.939175026			12.8672	0.18348			
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	103800	1.201388889			0.183478295			13.9177	-0.05523			
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	58740	0.946270095			-0.05522724							
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	47830											
16	14	6/10/2022	15.84828704	86639.7	86400	1502											
17	15	6/11/2022 16:59	16.89908565	86590.7	86400												
18	16	6/13/2022 11:12	18.65796296	14087.3	14060.9	4430											
19	17	6/14/2022 16:20	19.8721412	86518.9	86400												
20	18	6/15/2022 16:59	20.89899306	86499.8	86400												
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	8591											
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	1502											
23	21	6/22/2022 15:06	27.82043981	86447.2	86400												
24	22	6/24/2022 17:06	29.90413194	86440.8	86400												
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9												
26	24	6/29/2022 16:15	34.86866898	86436.7	86400												
27	25	6/30/2022 16:49	35.89172454	86434.2	86400												
28	26	7/5/2022 18:17	40.95304398	86418.8	86400												




Gamma ray energy line 528 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select		741										
2	Count	Count Start Date/Time	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit							
3	1	5/25/2022 19:25	0	72870.9	62850.9	3250000	51.70968117			3.945645021			0	3.945645		-2.5374E-01	#####
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	2834000	43.7345679			3.778138817			0.852928	3.778139		7.2328E-04	1.3880E-02
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	2348000	36.2345679			3.590013578			1.715266	3.590014		9.9987E-01	3.7161E-02
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	628600		7.353724					3.914236	3.007999		1.2308E+05	#####
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	1740000	20.24684865			3.007999159			4.963646	2.75315			
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	1242000	15.69198231			2.753149901			5.918623	2.50136	Half-life (hrs)	65.5608	
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	1054000	12.19907407			2.501360053			6.971887	2.23582	*/-/	0.1863	
10	8	6/1/2022 18:44	6.971886574	88584	86400	808200	9.354166667			2.235821877			8.615266	1.823466			
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	535100	6.193287037			1.82346597			9.808437	1.522427			
12	10	6/4/2022 14:49	9.8084375	87463	86400	396000	4.583333333			1.522426535			12.86723	0.752136			
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	183300	2.121527778			0.752136479			13.91772	0.517964			
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	104200	1.678606467			0.517963965			14.9169	0.260785			
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	84660	1.297948671			0.260785073			22.91881	-1.7725			
16	14	6/10/2022 15:46	15.84828704	86639.7	86400	6558		0.075903					26.05416	-2.5783			
17	15	6/11/2022 16:59	16.89908565	86590.7	86400								29.90413	-3.58394			
18	16	6/13/2022 11:12	18.65796296	14087.3	14060.9	4430		0.315058					33.87206	-4.63601			
19	17	6/14/2022 16:20	19.8721412	86518.9	86400								34.86867	-4.77878			
20	18	6/15/2022 16:59	20.89899306	86499.8	86400								35.89172	-5.1793			
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	14680	0.169907407			-1.772501653							
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	6558	0.075902778			-2.578301997							
23	21	6/22/2022 15:06	27.82043981	86447.2	86400												
24	22	6/24/2022 17:06	29.90413194	86440.8	86400	2399	0.027766204			-3.583935692							
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9	825.1	0.009696347			-4.636006041							
26	24	6/29/2022 16:15	34.86866898	86436.7	86400	726.3	0.00840625			-4.778779802							
27	25	6/30/2022 16:49	35.89172454	86434.2	86400	486.6	0.005631944			-5.179300524							
28	26	7/5/2022 18:17	40.95304398	86418.8	86400												




Gamma ray energy line 741 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select	778.7											
2	Count	Count Start Date/Time	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit							
3	1	5/25/2022 19:25	0	72870.9	62850.9	3367000	53.57122969			3.981012164			0	3.981012		-2.5256E-01	#####
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	2769000	42.73148148			3.75493592			0.852928	3.754936		7.0763E-04	1.3968E-02
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	2303000	35.54012346			3.570662296			1.715266	3.570662		9.9987E-01	3.7433E-02
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	1592000		18.62413					3.914236	2.983565		1.2738E+05	#####
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	1698000	19.75813161			2.983565134			4.963646	2.728699			
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	1212000	15.31294892			2.728698805			5.918623	2.479279		Half-life (hrs)	65.8688
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	1031000	11.93287037			2.479296808			6.971887	2.214942		+/-	0.1840
10	8	6/1/2022 18:44	6.971886574	88584	86400	791500	9.16087963			2.214942204			8.615266	1.798488			
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	521900	6.040509259			1.798488323			9.808437	1.499437			
12	10	6/4/2022 14:49	9.8084375	87463	86400	387000	4.479166667			1.499437017			12.86723	0.634149			
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	162900	1.885416667			0.63414884			13.91772	0.512189			
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	103600	1.668940786			0.512189166			14.9169	0.256049			
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	84260	1.291816147			0.256049094			22.91881	-1.78002			
16	14	6/10/2022	15.84828704	86639.7	86400	6623		0.076655					26.05416	-2.56844			
17	15	6/11/2022 16:59	16.89908565	86590.7	86400								27.82044	-2.99365			
18	16	6/13/2022 11:12	18.65796296	14087.3	14060.9	7616		0.541644					29.90413	-3.58937			
19	17	6/14/2022 16:20	19.8721412	86518.9	86400								33.87206	-4.55056			
20	18	6/15/2022 16:59	20.89899306	86499.8	86400								34.86867	-4.89931			
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	14570	0.168634259			-1.78002306			35.89172	-5.10106			
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	6623	0.076655093			-2.56843924							
23	21	6/22/2022 15:06	27.82043981	86447.2	86400	4329	0.050104167			-2.99365111							
24	22	6/24/2022 17:06	29.90413194	86440.8	86400	2386	0.027615741			-3.58936935							
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9	898.7	0.010561274			-4.55056136							
26	24	6/29/2022 16:15	34.86866898	86436.7	86400	650.3	0.00752662			-4.88930916							
27	25	6/30/2022 16:49	35.89172454	86434.2	86400	526.2	0.006090278			-5.10106159							
28	26	7/5/2022 18:17	40.95304398	86418.8	86400												





Gamma ray energy line 778.7 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select	881											
2	Count	Count Start Date/Time	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit							
3	1	5/25/2022 19:25	0	72870.9	62850.9	1547000	24.61380824			3.203307596			0	3.20331		-2.5305E-01	#####
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	1257000	19.39814815			2.965177605			0.852928	2.96518		5.3314E-04	#####
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	1056000	16.2962963			2.790937861			1.71527	2.79094		9.9993E-01	#####
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	284200		3.32473					3.91424	2.20321		2.2528E+05	#####
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	778100	9.054064904			2.203213818			4.96365	1.94728			
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	554800	7.009590808			1.947279327			5.91862	1.69438		Half-life (hrs)	65.7406
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	470300	5.443287037			1.694383113			6.97189	1.42989		+/-	0.1382
10	8	6/1/2022 18:44	6.971886574	88584	86400	361000	4.178240741			1.429890283			8.61527	1.01664			
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	238800	2.763888889			1.016638706			9.80844	0.71716			
12	10	6/4/2022 14:49	9.8084375	87463	86400	177000	2.048611111			0.717162057			12.8672	-0.01846			
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	84820	0.981712963			-0.01845631			13.9177	-0.26426			
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	47660	0.7677772			-0.26425569			14.9169	-0.51455			
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	38990	0.597767761			-0.51455296			22.9188	-2.57056			
16	14	6/10/2022	15.84828704	86639.7	86400	2913		0.03372					26.0542	-3.3898			
17	15	6/11/2022 16:59	16.89908565	86590.7	86400								29.9041	-4.36186			
18	16	6/13/2022 11:12	18.65796296	14087.3	14060.9	7745		0.55082					33.8721	-5.38665			
19	17	6/14/2022 16:20	19.8721412	86518.9	86400								34.8687	-5.63275			
20	18	6/15/2022 16:59	20.89899306	86499.8	86400												
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	6609	0.076493056			-2.57055532							
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	2913	0.033715278			-3.3898042							
23	21	6/22/2022 15:06	27.82043981	86447.2	86400												
24	22	6/24/2022 17:06	29.90413194	86440.8	86400	1102	0.01275463			-4.36186097							
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9	389.5	0.004577296			-5.38664677							
26	24	6/29/2022 16:15	34.86866898	86436.7	86400	309.2	0.003578704			-5.63275464							
27	25	6/30/2022 16:49	35.89172454	86434.2	86400												
28	26	7/5/2022 18:17	40.95304398	86418.8	86400												




Gamma ray energy line 881 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select	922											
2	Count	Count Start Date/Tim	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec BAD			Log-Linear Fit							
3	1	5/25/2022 19:25		0	72870.9	62850.9	2366000	37.64464789		3.62819079			0	3.628191		-2.5245E-01	#####
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	1905000	29.39814815			3.380931684			0.852928	3.380932		9.0727E-04	1.7909E-02
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	1620000	25			3.218875825			1.715266	3.218876		9.9978E-01	4.7993E-02
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	437200		5.114617					3.914236	2.630585		7.7424E+04	#####
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	1193000	13.88189106			2.630585189			4.963646	2.380591			
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	855700	10.8112957			2.380591486			5.918623	2.122622		Half-life (hrs)	65.8967
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	721700	8.353009259			2.122621864			6.971887	1.859259		+/-	0.2360
10	8	6/1/2022 18:44	6.971886574	88584	86400	554600	6.418981481			1.859259457			8.615266	1.445011			
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	366500	4.241898148			1.445010846			9.808437	1.135724			
12	10	6/4/2022 14:49	9.8084375	87463	86400	269000	3.113425926			1.135723704			12.86723	0.416973			
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	131100	1.517361111			0.416972715			13.91772	0.159368			
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	72800	1.172769201			0.159367791			14.9169	-0.07621			
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	60440	0.926624352			-0.076207025			22.91881	-2.12297			
16	14	6/10/2022	15.84828704	86639.7	86400	4722		0.054653					26.05416	-2.90676			
17	15	6/11/2022 16:59	16.89908565	86590.7	86400								27.82044	-3.36271			
18	16	6/13/2022 11:12	18.65796296	14087.3	14060.9	3487		0.247993					29.90413	-3.8835			
19	17	6/14/2022 16:20	19.8721412	86518.9	86400								33.87206	-4.97597			
20	18	6/15/2022 16:59	20.89899306	86499.8	86400								34.86867	-5.09273			
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	10340	0.119675926			-2.122967807			35.89172	-5.5583			
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	4722	0.054652778			-2.906755237							
23	21	6/22/2022 15:06	27.82043981	86447.2	86400	2993	0.034641204			-3.362711447							
24	22	6/24/2022 17:06	29.90413194	86440.8	86400	1778	0.020578704			-3.883498539							
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9	587.3	0.006901787			-4.975974869							
26	24	6/29/2022 16:15	34.86866898	86436.7	86400	530.6	0.006141204			-5.092734513							
27	25	6/30/2022 16:49	35.89172454	86434.2	86400	333.1	0.003855324			-5.55830021							
28	26	7/5/2022 18:17	40.95304398	86418.8	86400												
29																	
30								0	37.64465	3.628191							
31								0.852928241	29.39815	3.380932							
32								1.715266204	25	3.218876							
33								2.853668981									
34								3.914236111	13.88189	2.630585							
35								4.963645833	10.8113	2.380591							
36								5.918622685	8.353009	2.122622							
37								6.971886574	6.418981	1.859259							
38								8.615266204	4.241898	1.445011							
39								9.8084375	3.113426	1.135724							
40								12.8672338	1.517361	0.416973							
41								13.91771991	1.172769	0.159368							
42								14.91689815	0.926624	-0.07621							
43								15.84828704									
44								16.89908565									
45								18.65796296	0.247993	-1.39436							
46								19.8721412									
47								20.89899306									
48								22.91880787	0.119676	-2.12297							
49								26.05415509	0.054653	-2.90676							
50																	
51																	
52																	
53																	
54																	
55																	
56																	




Gamma ray energy line 922 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select	1005											
2	Count	Count Start Date/Tim	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit							
3	1	5/25/2022 19:25		0	72870.9	62850.9	25870	0.411609062		-0.88768126			0	-0.88768		-2.5614E-01	-8.6801E-01
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	22480	0.34691358			-1.05867958		0.85293	-1.05868			1.3730E-03	1.0611E-02
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	17300	0.266975309			-1.3205991		1.71527	-1.3206			9.9974E-01	2.0238E-02
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	4565		0.0534				3.91424	-1.88946			3.4803E+04	9.0000E+00
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	12990	0.151153198			-1.8894614		4.96365	-2.10904				
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	9605	0.121353857			-2.10904457		5.91862	-2.38355			Half-life (hrs)	64.9472
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	7968	0.092222222			-2.38355416		6.97189	-2.64906			±/-	0.3463
10	8	6/1/2022 18:44	6.971886574	88584	86400	6110	0.070717593			-2.6490609		8.61527	-3.09647				
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	3906	0.045208333			-3.09647384		9.80844	-3.36038				
12	10	6/4/2022 14:49	9.8084375	87463	86400	3000	0.034722222			-3.36037539		12.8672	-4.17682				
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	1326	0.015347222			-4.17682078		13.9177	-4.42959				
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	739.9	0.011919395			-4.4295884							
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	431.1		0.00661									
16	14	6/10/2022	15.84828704	86639.7	86400	586.1		0.00678									
17	15	6/11/2022 16:59	16.89908565	86590.7	86400												
18	16	6/13/2022 11:12	18.65796296	14087.3	14060.9	5335		0.37942									
19	17	6/14/2022 16:20	19.8721412	86518.9	86400												
20	18	6/15/2022 16:59	20.89899306	86499.8	86400												
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	10340		0.11968									
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	4722		0.05465									
23	21	6/22/2022 15:06	27.82043981	86447.2	86400												
24	22	6/24/2022 17:06	29.90413194	86440.8	86400												
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9												
26	24	6/29/2022 16:15	34.86866898	86436.7	86400												
27	25	6/30/2022 16:49	35.89172454	86434.2	86400												
28	26	7/5/2022 18:17	40.95304398	86418.8	86400												




Gamma ray energy line 1005 keV

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1					Energy (keV) select	1145											
2	Count	Count Start Date/Tim	Time Diff. (days)	Realtime (sec)	Livetime (sec)	Net Peak Area	Net Count-rate (1/sec)	BAD		Log-Linear Fit							
3	1	5/25/2022 19:25		0	72870.9	16840	0.267935702			-1.317008246			0	-1.31701		-2.5321E-01	-1.3257E+00
4	2	5/26/2022 15:53	0.852928241	72838.1	64800	13980	0.215740741			-1.533677867		0.85293	-1.53368			1.8766E-03	1.3155E-02
5	3	5/27/2022 12:34	1.715266204	71216.6	64800	11480	0.177160494			-1.730699212		1.71526	-1.7307			9.9956E-01	2.4480E-02
6	4	5/28/2022 15:54	2.853668981	91600.8	85480.5	3283		0.038406				3.91423	-2.32529			1.8206E+04	8.0000E+00
7	5	5/29/2022 17:21	3.914236111	90627	85939.3	8401	0.097755043			-2.325290487		4.96364	-2.59468				
8	6	5/30/2022 18:32	4.963645833	82500.2	79148.7	5910	0.074669578			-2.59468253		5.91862	-2.82661			Half-life (hrs)	65.6975
9	7	5/31/2022 17:27	5.918622685	89247.6	86400	5116	0.059212963			-2.826614792		6.97188	-3.11273			±/-	0.4833
10	8	6/1/2022 18:44	6.971886574	88584	86400	3843	0.044479167			-3.112734364		8.61526	-3.5395				
11	9	6/3/2022 10:10	8.615266204	87840.1	86400	2508	0.029027778			-3.539502053		9.80843	-3.82241				
12	10	6/4/2022 14:49	9.8084375	87463	86400	1890	0.021875			-3.822410847		13.9177	-4.80641				
13	11	6/7/2022 16:13	12.8672338	86930.5	86400	940.7	0.010887731										
14	12	6/8/2022 17:26	13.91771991	62379.4	62075.3	507.6	0.008177165			-4.806409707							
15	13	6/9/2022 17:25	14.91689815	65471.1	65226	353.4		0.005418									
16	14	6/10/2022 15:46	15.84828704	86639.7	86400	451.6											
17	15	6/11/2022 16:59	16.89908565	86590.7	86400			0.005227									
18	16	6/13/2022 11:12	18.65796296	14087.3	14060.9	5335											
19	17	6/14/2022 16:20	19.8721412	86518.9	86400												
20	18	6/15/2022 16:59	20.89899306	86499.8	86400												
21	19	6/17/2022 17:28	22.91880787	86469.1	86400	10340											
22	20	6/20/2022 20:42	26.05415509	86451.1	86400	4722											
23	21	6/22/2022 15:06	27.82043981	86447.2	86400												
24	22	6/24/2022 17:06	29.90413194	86440.8	86400												
25	23	6/28/2022 16:20	33.87206019	85129.2	85093.9												
26	24	6/29/2022 16:15	34.86866898	86436.7	86400												
27	25	6/30/2022 16:49	35.89172454	86434.2	86400												
28	26	7/5/2022 18:17	40.95304398	86418.8	86400												



Gamma ray energy line 1145 keV



Compiled  $T_{1/2}$  calculations