

## VOLUME III

6. FPE 403 FPE LAB (UL)

7<sup>TH</sup> Sem. A

7. FPE 421 FIRE EXT. & DET. SYS.

8<sup>TH</sup> Sem. A

8. FPE 404 FPE LAB (UL)

8<sup>TH</sup> Sem. A

9. FPE 415 INDUST. HAZARD CONTROL.

7<sup>TH</sup> Sem. A

UL


403

303

Oct	3	Fire Pumps
OCT	17	F.P. H <sub>2</sub> O Supplies
OCT	31	Auto. Sprink.
Nov	14	Hydraulics of Sprink. Systems
DEC	5	" " " "
DEC	19	Extinguishers

horiz. centrifugal pumps

"Runner" = moving horiz part




inboard & outboard bearings?

Double suction balances  
horiz forces on shaft.

except Multistage

Voluts = internal passageway in case



Pump imparts energy to water  
Pump PUSHES  $\therefore$  must deliver  $H_2O$   
TO pump.

Pusher = 14.7 psi

Allow 15' max draft tho could possibly  
draw 20-22 ft.

Don't mean 15' CL<sub>pump</sub> to H<sub>2</sub>O level


15' = distance between  $\phi$  of pump + water  
+ hf of hose or pipe to pump

15' TOTAL @ certain flow - usually  
(hf depends on Q)

check @ 150% rated flow


Req. every listed pump  
to pump 150% rated cap @ 65%  
rated pressure @ 15' lift.

always use eccentric connections



Watch dia. when tapping pressure  
gages.

NET HEAD = Bernoulli's ~~in~~ <sup>out</sup> eq. - Bernoulli's in eq.



Pamphlet 20 req.: 1. 0 flow

2. Rated flow

3. 150% Rated flow

TDH OR RNHP  
(Ft. H<sub>2</sub>O)  
Vertic. ~~140%~~ 140% rated pressure  
Horiz. 120% rated pressure

≅ rated pressure

65% rated pressure


rated pressure is min pressure @ rated head.  
curve always above rated pressure → if  
pump becomes less efficient will still  
meet req.

e.g. pump rated @ 1000 gpm 100 psi = 231'

Assume pump produces 125 psi = 289'


0 flow allow 120

0 flow	150%
psi	120
psi	150
	<del>150</del> 81



Want flat curve -----


Unstable pump curve - wait list



REF → Centrifugal pumps + blowers - CHURCH

# Typical Horiz. Centrifugal Pump

AT CONSTANT SPEED



Dotted H-C curves are "break off curves" representing changes in suction conditions.

HP will sometimes taper out also, but won't go up.  $\therefore$  can over load on driver because of too much pos. suction head.

Characteristic H-C curve is @ zero suction when you add lift, it breaks off H-C curve to left & under characteristic curve.

## Similarity Relationships

$$N = \text{rpm}$$

used to  
relate to  
constant speed

$$\left\{ \begin{array}{l} \frac{N_1}{N_2} = \frac{Q_1}{Q_2} \\ \left( \frac{N_1}{N_2} \right)^2 = \frac{H_1}{H_2} \\ \left( \frac{N_1}{N_2} \right)^3 = \frac{HP_1}{HP_2} \end{array} \right.$$

HP = horsepower

Most trouble occurs due to RPM & suction cond.

## Calculation of horsepower

$$\frac{\text{WORK}}{\text{TIME}} = \text{HP}$$

$$K \frac{Q \times \text{height}}{\text{min}} = K \frac{\text{gal} \cdot \text{ft}}{\text{min}}$$

$$\Rightarrow \frac{\text{ft} \cdot \text{lb}}{\text{min}}$$

OUTPUT HP

$$\frac{\text{ft} \cdot \text{GAL}}{\text{min}} \approx \Rightarrow$$

QP

put in sample  
calculations

convert to HP

INPUT HP

$$\text{HP} = \text{Watts} = EI \quad \text{convert to hp.}$$

on 3 $\phi$  HP( $\sqrt{3}$ )

assume motor 90% eff.

$$\text{HP} = \frac{VA(\text{eff})(\text{PF})\sqrt{3}}{746} \quad \text{PF} \approx 90\%$$



must meas. amps in ea. phase  
and take ave. meas volts  
phase to phase.

(N = rpm.)

D. A. LUCHT

1.  $\frac{N_1}{N_2} = \frac{Q_1}{Q_2}$  (Q = gpm)

$\left(\frac{N_1}{N_2}\right)^2 = \frac{H_1}{H_2}$  (H = head  $\pm$  ft of water)

$\left(\frac{N_1}{N_2}\right)^3 = \frac{HP_1}{HP_2}$  (HP = horsepower) ✓

2. vertical turbine pumps. (centrifugal)  
horizontal shaft (centrifugal) pumps. ✓

3. HEAD VS. FLOW CURVE.

EFFICIENCY VS. FLOW CURVE

INPUT ~~HP~~ HORSEPOWER VS. FLOW CURVE. ✓

4. 1. must develop 150% of rated capacity  
at  $\geq 65\%$  of rated pressure

2. must not develop  $> 150\%$  rated ~~pressure~~ pressure  
at zero flow 170% max - vertical  
140% max - horizontal

3. must develop rated flow at  $\geq$  rated pressure.

5. NET HEAD MEASURE (1) DISCHARGE PRESSURE (2) ✓

NET HEAD =  $\left(\frac{V_2^2}{2g} - \frac{V_1^2}{2g}\right) + \left(\frac{P_2}{w} - \frac{P_1}{w}\right) + (h_2 - h_1)$

how? where  $V$  is converted to flow and other appropriate unit conversions calculated

- (2) " FLOW
- (3) DISCHARGE ELEVATION
- (4) ENTRANCE PRESSURE  $\pm$
- (5) " FLOW
- (6) " ELEVATION.

D. LUCHT

(90)

Pipe & Fittings Listed under Fire main equip. Page 53 (1964) Fire Prot. List

Two Categories of Hyd.

1. Wet Barrel
2. Base Valve

Pipe

CI  
Ductile Iron  
⋮

} check usually against ASA std.

Under ground pipe must be designed for the situation — Forces to which it will be subjected

1. The primary advantage to the Williams + Hazen formula is that through experiment it has been found to be the most accurate as compared to other empirical formulae. The disadvantage is that it requires a large amount of calculations (+ time) to get the answers, as compared to slide rule methods etc, (though most hydraulic slide rules are based on Williams + Hazen.) and multiple loop methods.

pipe size  
+ velocity  
limited

Factors to be known:

1. Williams - Hazen pipe coefficient.
2. diam. of pipe.
3. Flow OR friction loss, depending on which of the two is being solved for.

pipe length

16

$$H_f = K \frac{Q^{1.85}}{C^{1.49} D^{4.87}} \quad \text{or} \quad Q = \left( \frac{H_f C^{1.49} D^{4.87}}{K} \right)^{0.54}$$

If the friction loss is found on basis of  $C_1$  at a given flow, an "equivalent" value of flow may be found on the hydraulic of slide rule

And a new friction loss found  
in the same pipe for this  
equivalent flow.

how 10

3. Would test:

1. Available water supply from ~~the~~ each individual source with all others shut off.
2. Available water supply from all supplies working together.

flow tests,


3

Minimum Data to be taken:

1. how many Flows at various points of interest.
2. how many residual pressures (to find friction losses)
3. elevation difference


1. First of all ~~all~~, all pipes would be converted to equivalent lengths of 8" pipe. <sup>@ C=100</sup>
2. all sources would be connected to another source and/or the point of withdrawal of water by imaginary pipes having zero flow.

e.g.





3. The ~~old~~ D'Arcy method would be used to find the flow in each pipe.
4. The friction loss in each pipe would be calculated knowing the flow in each pipe, length, diameter, and C value.
5. These friction losses would be added together using any path ~~flow~~ between the pts.

5.



$2100' \text{ } 6'' \text{ } C=100$   
 $1200' \text{ } 6'' \text{ } C=75$   
 $1000' \text{ } 8'' \text{ } C=120$   
 $500' \text{ } 8'' \text{ } C=100$   
 $720' \text{ } 8'' \text{ } C=100$   
 $h_f = 15 \text{ psi}$   
 $460 \text{ } 340$   
 $700 \text{ gpm} = 1000 \text{ gpm}$   
 $C=100 \text{ } C=75$   
 $1100 \text{ gpm} = 1300 \text{ gpm}$   
 $C=100 \text{ } C=120$

$\Rightarrow \begin{array}{r} 1300 \\ 340 \\ \hline 1640 \text{ gpm } h_f = 15 \text{ psi} \end{array}$   
 $= 470' \text{ } 8'' \text{ } C=100$




@ 1000 gpm  $h_f = 12.8 \text{ psi}$



Use any books or references you wish.

- 1) What are the practical advantages and limitations of use of the Williams & Hazen formula? What factors must be known to effectively use the formula?
- 2) Explain how friction loss values obtained by use of some given roughness coefficient ( $C_1$ ) can be determined for some other roughness coefficient ( $C_2$ ). You may refer to the basic formula or to the hydraulic slide rule.
- 3) What test (s) would you make to analyze an available water supply system for fire protection purposes? What minimum data must be taken?
- 4) Describe the method of calculating friction loss (pressure drop) between two points in a loop system, having two sources of supply and three different sizes (I.D.) of pipe.

5)



Given the following information:


A flow test of 1500 gpm at point A gives a static pressure of 80 psi and a residual of 60 psi. The static pressure at point C is measured as 100 psi and at point E is measured as 80 psi. Calculate the supply available (supply curve) for a sprinkler system connection at point E.



FILE NO. \_\_\_\_\_ PROPERTY \_\_\_\_\_ LOCATION \_\_\_\_\_ DATE \_\_\_\_\_ BY LUCHT

NO CORRECTION FOR ELEVATION MADE  
AS PT. A IS AT SAME ELEVATION  
AS PT E.

PRESSURE-LBS. PER SQ. IN.



HIGHEST SPRINKLER BLDG. NO. \_\_\_\_\_  
\_\_\_\_\_ FT. ABV. RESIDUAL PRESSURE.

110  
100  
90  
80  
70  
60  
50  
40  
30  
20  
10  
0  
TOP LINE



**HYDRAULICALLY DESIGNED SYSTEMS**

HAZARD \_\_\_\_\_ LOCATION \_\_\_\_\_ TYPE SYSTEM \_\_\_\_\_ DESIGN DENSITY G.P.M./SQ.FT. \_\_\_\_\_  
CALCULATED SYSTEM DEMAND G.P.M. \_\_\_\_\_ LBS. \_\_\_\_\_ ACTUAL SYSTEM DISCHARGE TEST G.P.M. \_\_\_\_\_ LBS. \_\_\_\_\_ DATE \_\_\_\_\_

D. LUCHT

DESIGN SPEED 2.5 KNOTS PER HOUR  
DESIGN DEPTH 500 FATHOMS


DESIGN SPEED 2.5 KNOTS PER HOUR  
DESIGN DEPTH 500 FATHOMS



102  
 110  
 118  
 130  
 LIFE NO.



# Loop System Problem



$P_1 - P_2$  over  $l_1 = P_1 - P_2$  over  $l_2 = P_1 - P_2$  over equiv. pipe of length  $l_3$  & Dia.  $D_3$

$$P_1 - P_2 = \Delta P \approx \frac{l_1 K_1 Q_1^{1.85}}{C_1 D_1^{4.87}} \Rightarrow \frac{l_2 K_2 Q_2^{1.85}}{C_2 D_2^{4.87}} = \frac{l_3 K_3 Q_3^{1.85}}{C_3 D_3^{4.87}}$$

$C_1, C_2, C_3$  are known  
 $K_1 = K_2 = K_3$

$$\frac{l_1 Q_1^{1.85}}{D_1^{4.87}} = \frac{l_2 Q_2^{1.85}}{D_2^{4.87}} = \frac{l_3 Q_3^{1.85}}{D_3^{4.87}}$$

$$Q_3 = Q_1 + Q_2$$

$l_1, l_2$  are known

$D_1, D_2$  are known

Thus  $Q_3$  and  $D_3$  can be computed

For any assumed <sup>known</sup> value of  $Q_3$ ,  ~~$Q_3$~~  it is possible

to compute  $Q_1, Q_2, D_3, l_3$

Since  $l_3, D_3$  are known the loss/ft. can be computed for any given value of  $Q_3$

and the avail flow & pressure loss can be calculated for any segment.

Learn Color codes

## Calibration Test

70 Water is to be discharged through the test foam-water sprinkler at selected pressures and the rate-of-flow for each pressure in gallons per minute is to be determined by observation of a flowmeter. The water discharge rates (gallons per minute) shall be within the range of such rates as shown in Table I.

## Distribution Test—Rotating Table

- 71 This is a test to determine the concentration of water over the discharge pattern of foam-water sprinklers of either the upright or pendent styles.
- 72 A sample foam-water sprinkler is to be installed in its normal position (either upright or pendent) 4 feet above a row of ten 1-foot square test pans mounted on a rotating table (1 revolution per minute) which has its pivot placed directly below the test sprinkler.
- 73 With the table and its pans rotating, water is to be discharged for 3 minutes from the test sprinkler at a rate of 15 gallons per minute. The water caught in each pan is to be measured and calculations made to determine the rate at which water reached the several areas in terms of gallons per minute per square foot for concentric circular areas at several horizontal distances from the discharging sprinkler.
- 74 The results obtained in the rotating-table tests shall have values in terms of gallons per minute per square foot which will approximate or be in excess of the values indicated by the curve shown on Figure 5.

### ROTATING-TABLE DISCHARGE VALUES

In gallons per minute per square foot at indicated horizontal distances from vertical line through centerline of foam-water sprinkler located 4 feet above test pans on rotating table.




FIGURE 5

75 The curve shown on Figure 5 does not include value points at distances of 1 and 2 feet from the center. In this area, discharge values are purposely not specified and may be higher than or lower than the trend suggested by the curve.

## Water Distribution Tests—16-Pan Arrangement

- 76 To further evaluate the distribution pattern of the discharge from foam-water sprinklers, distribution tests are to be made employing four test sprinklers installed at the corners of a rectangular piping grid measuring 7½ feet by 12 feet (maximum spacing under Extra-Hazard Occupancy) (Section 7, NBFU No. 13) and 10 feet by 10 feet. The piping grid is to be located 7½ feet above a group of 16 pans (arranged to form a 4-foot square), representative of the areas of the top of the wood crib used in the fire tests of sprinklers described in a following section. Water is to be discharged from the test sprinklers for 10 minutes at an average flow rate of 15 gallons per minute per sprinkler. The water caught in the pans is to be measured and calculations made to determine the average quantity of water reaching the test pans in terms of gallons per minute per square foot.
- 77 The average concentration of water reaching the 16 pans shall be not less than 0.166 gallons per minute per square foot for the 7½- by 12-foot spacing and not less than 0.150 gallons per minute for the 10- by 10-foot spacing. The average concentration of water reaching any individual pan shall be not less than 90 percent of the average concentration required for all 16 pans.

## Foam Quality Tests

- 78 Foam quality tests shall be made using a single test sample foam-water sprinkler installed in its normal position (upright or pendent) at an elevation of 3 feet above the floor.
- 79 Air-foam solution (premixed) employing either 3 percent or 6 percent air-foam liquid concentrates shall be supplied under inlet pressures of 20, 30, 50, and 75 pounds per square inch to the test sprinkler.
- 80 The air-foam discharging from the test sprinkler under the above conditions shall be subjected to the following examinations and tests, with the data being recorded for evaluation.
- Visual evaluation of the quality of the foam based on its blanket-forming characteristics.
  - Analyses of samples of the foam to develop values of foam "expansion" and "25 percent time." Definitions of these terms and description of the test methods to be followed in making the analyses are given in Section IV of this Standard.
    - "Expansion" values of foams produced by foam-water sprinklers have ranged from 4 to 10. "25 percent time" values have ranged from 15 seconds to 1 minute.
    - These "value" ranges were developed when producing foam, under "no-fire" conditions, from foam-water sprinklers at inlet water pressures ranging from 20 to 100 pounds per square inch; when using water taken from two sources which ranged in temperature from 40 to 90 F; and with test foam-water sprinklers located from 3 to 20 feet above the floor.

## Fire Tests—Class A

## WATER DISCHARGE

- NOT DONE*
- 81 Two Class A fire tests of foam-water sprinklers are to be made, employing water discharging from the sprinklers as the extinguishing agent at the rate of 15 gallons per minute per sprinkler in one test and at the rate of 25 gallons per minute in the second test.
- 82 The standard Class A fires normally used in fire tests of automatic sprinklers are to be employed in similar tests of foam-water sprinklers.
- 83 The test setup is to consist of four foam-water sprinklers installed at the corners of a 10- by 10-foot piping grid on the ceiling near the center of a fire-test room, 60 by 60 feet in dimensions and 16 feet high from floor to ceiling. The piping grid is to be connected to the test-station water-supply piping system and also is to be pipe-connected to a source of air-foam liquid concentrate.
- 84 The standard Class A fires employed in these tests combine the use of a gasoline torch with a crib of wood weighing approximately 350 pounds.
- 85 The gasoline torch, supplied with gasoline at the rate of 1 gallon per minute, is to be directed vertically upward from under the center of the wood crib which is 4 feet square and 21½ inches high, with its top area 7½ feet above the floor and 7½ feet below the deflectors of the test sprinklers.
- 86 The test routine to be followed starts with the ignition of the gasoline torch (1 gallon per minute of gasoline) which is to be allowed to burn for 1 minute before manual establishment of flow of water from the test sprinklers at the predetermined rate of 15 gallons per minute from each sprinkler in one test and at 25 gallons per minute in a second test.
- 87 The fire test is to be continued for 30 minutes.
- 88 At the end of the 30-minute period, the gasoline flow to the torch is to be stopped and water flow to the sprinklers shut off.
- 89 The wood test crib, which was weighed prior to the tests, is to be again weighed 24 hours after test completion to determine the weight loss during the fire exposure.
- 90 The temperatures existing at the ceiling level are to be recorded on a chart-type recorder to which a thermocouple centrally located above the test crib is to be connected. The recorded temperatures are to be reviewed for determination of maximum temperatures and the time of occurrence after start of the fire exposure and before extinguishing agent discharge; and for the controlled ceiling temperatures during extinguishing-agent discharge.
- 91 Performance of foam-water sprinklers in Class A fire tests discharging water is to be considered acceptable when the wooden crib weight loss does not exceed 20 percent and the ceiling temperature following application of water recedes to a value not exceeding 600 °F throughout the remainder of the 30-minute test period.

## Fire Tests—Class B

## AIR-FO

- 92 Class B fire tests of foam-water (1) fuel consisting of a 2-inch diameter in a 10- by 10-foot by 16-inch diameter concentrates of either 3 percent or 10 percent (the concentration of both is required; and the number) installed at the corners of a 100-square foot protection area.
- 93 The test piping grid should be installed above the test sprinklers 20 feet above the floor.
- 94 The test setup locates the test sprinklers.
- 95 The Class B fire-test routine is as follows:
- A. A 15-second preburn of the fuel.
  - B. Employment of test air-foam solutions in accordance with the requirements of paragraph 92. If only one type of solution is to be considered, only one solution is to be used. If additional liquid concentrates are to be used, a separate fire test for each concentrate is to be conducted.
  - C. A discharge of air foam solution from the test sprinklers at a foam-solution flow rate of 60 gallons per minute for 15 minutes.
  - D. Continuation of the air-foam solution per minute during which time period the following are to be determined:
    1. Ability of the discharge to extinguish the burning-fuel surface.
    2. Cohesiveness of the foam.
    3. Time elapsing to produce a continuous film of foam.
    4. Time elapsing to extinguish the flames in the test area.
    5. Time elapsing to complete the test.
    6. At completion of the test, the measurement of the foam.
    7. The air-foam discharge rate of water discharged from the test sprinklers at the rate of 15 gallons per minute to continue for 20 minutes.


77  
68

D. LUCHT


-23

X 1. 35 feet

-10



✓ 3.  $.4(30) = 12 \text{ B}$



5. No, the extinguisher should not freeze up.

-10

6. Stored pressure. ✓ X

Pump tank.

Cartridge Operated ✓ X

Soda-acid.

Foam

ABC multi purpose dry chemical

-10

7. yes, ~~bulk fell~~  $> 4\frac{1}{2}'$   
over 80% disch. on tilt test

Jim Kern



8. Potassium Bicarbonate  
Sodium Bicarbonate  
Mono-Ammonium Phosphate  
Bi-Ammonium Phosphate ✓

9. Class A test  
(Crib, enclosure, wood wall)

Class B test  
Flammable liquid test

Class C

✓ Electrical Conducting properties  
of the unit. ✓

10. a. one unit for each 2500<sup>#</sup> floor  
area, with ~~max~~ maximum travel  
distance of 100'

b. one unit for each 1250<sup>#</sup> floor  
area, with maximum travel  
distance of 50'

c. } one unit / 625<sup>#</sup> floor area in vicinity  
d. } not > 50' travel distance.

- 1

- 2

- ✓ 1. What are the range requirements for soda-acid and foam extinguishers?
- ✓ 2. Give the reaction for soda-acid extinguisher.
3. What fire extinguishing classification would be assigned a stearate treated sodium bicarbonate type dry chemical extinguisher that successfully extinguished three 30 sq. ft. test fires in 8.2, 7.6, and 7.9 seconds respectively?
- ✓ 4. Give the reaction for a foam extinguisher.
5. A 10 lb. CO<sub>2</sub> extinguisher discharges 7 lb. 9 oz. of agent to gas point when conditioned at 70 F. When conditioned at -40 F, the extinguisher discharges 7 lb. 10 oz. when the discharge is stopped by a freeze-up. Is this acceptable? Why or why not?
- ✓ 6. Name 6 types of extinguishers suitable for use on Class A fires.
- ✓ 7. A 5 lb. dry chemical extinguisher discharges 4 lb. 1 oz. in 7.6 seconds when operated at an angle of 45 degrees backward from vertical and conditioned at 70 F. The bulk of the discharge fell beyond 4-1/2 ft. from the nozzle with a maximum range of 11 ft.  
Is this test result acceptable? Why or why not?
- ✓ 8. What are four types of dry chemical?
9. What types of tests are used to determine the fire extinguishing classification of a 10 lb. Multi-Purpose (ABC) type extinguisher?
10. What are the requirements for spacing of extinguishers in the following?
  - (a) Class A - Light Hazard Occupancies
  - (b) Class A - Ord Hazard Occupancies
  - (c) Class B - Spill Fire Conditions
  - (d) Class B - Deep Layer Fire Conditions

Crane Technical Bulletin #410  
- hydraulic manual -

Abstract: Brief explanation of what one might expect to find in report

1. purpose of expt. (very general & brief)
2. what was done - " " "
3. what Results Indicate w.r.t

purpose  
the last thing you write for the report.

Ratings


Classification of Extinguishers - fire

A, B, C, D

A - ord. combustibles

B - flammable liq. gases & greases.

rate on relative extinguishing effectiveness using expert fire fighter



6" freeboard + 2" fuel mandatory - H<sub>2</sub>O follows  
∴ can't use < 8" pan

amt of deep <sup>layer</sup> ~~solid~~ fire wh. can consistently be ext. by expert fire fighter.

$$\frac{F_T^2}{2\frac{1}{2}} = \text{extinguishing rating}$$

safety factor, since operator is an expert, (40%)

fuel is a std. fuel, but isn't gasoline

it is "Standard Stone & lighting fuel"

### Class C

Based on ability to be safe of an extinguisher for use on electrical fire.  
eg. can't use metal horn

rating is numerical  
Classif. is type

### Class A:



relative ext. potential on 3 types of fire

	INDOOR	OUTDOOR
Panel	1-6A	
Crib	1- <del>40</del> 6A	10, 20, 30, 40
Office	1-6A	

~~Handwritten~~

Panels	1A	8'x8'	} 1x6 tongue & groove backing w. rows of furring strips
	2A	10'x10'	
	3A	12'x12'	
	4A	14'x14'	
	6A	18'x18'	

N 50 # / unit of rating



# Extinguishers.

Anti-freeze ext.  
4 mats. used.

Stored Pressure, Cartridge Operated, Mech. Pump.

copper	} 350 500psi factory test pressure	Stainless Stl. CuNi	350	Steel
brass		500psi		
bronz				
<del>Stainless Steel</del>		fiberglass	225psi	
<del>Cu Ni</del>		factory test pressure		
<del>filite glass.</del>				

6 X Stored pressure  
strength req.

5 X normal op.  
pressure strength  
req.

## CO<sub>2</sub> EXTINGUISHERS.

must have safety relief 2650-3000psi


## D.C.

Cart. op.  
Stored Pressure  
Disposable



NaHCO<sub>3</sub> — regular  
KHCO<sub>3</sub> ⊆  
(NH<sub>3</sub>)<sub>2</sub>PO<sub>4</sub> ⊆ } Same  
NH<sub>3</sub>PO<sub>4</sub> ⊆

∴ 8 Dry Chemical

S/A




Foam



FPE 403

12-5-64



Pipe put in  
in 1955  
schedule 40  
Black Steel Pipe